



Metropolitan Edison Company
Post Office Box 480
Middletown, Pennsylvania 17057
717 944-4041

Writer's Direct Dial Number

December 9, 1980
TLL 620

Office of Nuclear Reactor Regulation
Attn: T. M. Novak, Assistant Director of
Operating Reactors
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Sir:


Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
TMI-1 Fuel Assembly Holddown Springs

Per our letter of September 10, 1980 (TLL 447), in response to your letter of July 1, 1980, we are forwarding a final letter upon completion of the examination.

The fuel assembly holddown spring examination was completed on all fuel assemblies in the spent fuel pool and no failed springs were found.

Based on these results the commitments made in our previous response will not be modified and no further correspondence is deemed necessary.

Sincerely,


H. D. Hukill
Director, TMI-1

HDH:DGM:hah

- cc: B. H. Grier
- R. W. Reid
- L. H. Barrett
- B. J. Snyder
- D. DiIanni
- H. Silver

SEARCHED

NOV 11 1980

A001
S
1/0

8012170 481