LICENSEE EVENT REPORT

CONTROL BLOCK:
0 1 T N S N P 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 57 CAT 56
CON'T SOURCE L 6 0 5 10 10 10 15 2 17 7 1 1 1 2 4 8 0 8 1 2 2 3 8 0 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 At 1615 c with unit in Mode 3 (547 degrees & 2235 psig), the pump motor breaker for
[0]3] component cooling water pump C-S (aligned for B train) failed to close rendering
0 4 B-train component cooling water inoperable. The plant entered the action statement
o 5 of LCO 3.7.3.1. There was no effect on public health or safety. No previous
0 6 occurrences.
071
7 8 9 SYSTEM CAUSE CAUSE COMP. VALVE
CODE SUBCODE S
LER/RO EVENT YEAR REPORT NO. 17 REPORT 8 0 1 9 1 20 23 1 1 1 1 1 1 1 1 1
The breaker failed to close due to a blown fuse in the control circuit. The fuse was
replaced at 1630 c and B train was declared operable. Subsequent investigation deter-
mined that circuit amperage is acceptable. Failure has been attributed to fuse failure.
1,4
STATIC: SPOWER OTHER STATUS (30) METHOD OF DISCOVERY DESCRIPTION (32) 1 5 B (28) 0 0 0 (29) NA C (31) Operator observation
7 8 4 10 12 17 44 45 46 80 ACTIVITY CONTENT AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
1 6 Z 33 Z 3 NA
NUMBER TYPE DESCRIPTION (39)
7 8 9 PERSONNEL INJURIES 13
NUMBER DESCRIPTION (41) NA NA NA
LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION NA
PUBLICITY (AS)
Z O N 4 NA
Name of Preparer: W.T.Cottle/A.M.Wilkey Phone: (615) 842-8317
8012300548