LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
1 T N S N P 1 3 0 0 - 0 0 0 0 0 - 0 0 0 0 4 1 1 1 1 1 4 5 5 CAT SE
CON'T O 1 SOURCE 60 61 DICKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 Unit in mode 3 with RCS temperature 548 degrees F and pressure 2235 psig. On
[0]3 11-24-80, at 1730 CST 20 containment purge isolation alves were stroked per surveillance
[0]4 requirement 4.6.3.1.3. The valves were not leak rate tested within 24 hours following
o 5 the stroke test as required by surveillance requirement 4.6.3.1.4. There was no
0 6 effect upon public health or safety. Previous Occurrence - none.
07
0 8 1
7 8 9 SYSTEM CAUSE CAUSE CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE
S D 1 A 1 A 1 A 1 A 1 A 1 A 1 A A 1 A
LER/RO EVENT YEAR REPORT NO. 17 REPORT 8 0 1 9 0 2 23 24 26 27 28 29 30 31 31 32 31 32 32 32 32
[1] [(MR) to perform the required leak rate tests. The results section did not receive
the MR within the 24-hour time limit. The valves were satisfactorily tested within
[1[3] 41 hours of the stroke test. Operations personnel have been reinstructed to contact
results personnel directly for tests required within specific time limits.
The factor of the status of th
7 8 9 10 11 44 45 80 PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39) NA NA NA NA NA
PERSONNEL INJURIES NUMBER DESCRIPTION (1)
1 8 0 0 0 0 (40) NA 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
TITI Z 42 NA
7 8 9 10 PUBLICITY ISSUED DESCRIPTION 45 NAC USE ONL *
7 8 9 10 68 69
Name of Preparer: W.T.Cottle/G.B.Kirk Phone: (615) 842-8317