

CONTROL BLOCK: 

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	2	1	9	7	1	2	0	4	8	0	8	1	2	2	3	8	0	9
60	61									68	69						74	75						80
DOCKET NUMBER											EVENT DATE							REPORT DATE						

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During surveillance testing, the Main Steam Line high flow sensors  
0 3 RE-22C and RE-22G tripped at values greater than the limit of 97.5 psig  
0 4 given in the Technical Specifications, Table 3.1.1, item B.2. The trip  
0 5 point values were 98.5 psig for both sensors. The safety significance  
0 6 is considered minimal because the redundant switches RE-22D and RE-22H  
0 7 would have actuated at the desired level to initiate the required main  
0 8 steam isolation functions.

SYSTEM CODE C C (11)		CAUSE CODE X (12)		CAUSE SUBCODE Z (13)		COMPONENT CODE I N S T R U (14)						COMP SUBCODE E (15)		VALVE SUBCODE Z (16)																	
EVENT YEAR 8 0 (17)		SEQUENTIAL REPORT NO. 0 5 6 (18)		OCCURRENCE CODE 0 3 (19)		REPORT TYPE L (20)		REVISION NO. 0 (21)		ACTION TAKEN E (22)		FUTURE ACTION C (23)		EFFECT ON PLANT Z (24)		SHUTDOWN METHOD Z (25)		HOURS 0 0 0 0 (26)				ATTACHMENT SUBMITTED Y (27)		NPRD-4 FORM SUB. Y (28)		PRIME COMP. SUPPLIER L (29)		COMPONENT MANUFACTURER I 2 0 4 (30)			

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the occurrence was due to instrument repeatability. Sensor  
1 1 RE-22C was reset to trip within the desired level, yet sensor RE-22G had  
1 2 to have a microswitch replaced before it would reset to trip at the  
1 3 proper value. The PORC has recommended that these switches be replaced  
1 4 with a suitable qualified model.

8 9  
FACILITY STATUS (28) % POWER (29) OTHER STATUS (30) METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)  
1 5 E 0 9 4 NA B Surveillance Test  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
ACTIVITY CONTENT  
RELEASED OF RELEASE (33) AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)  
1 6 Z Z NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
PERSONNEL EXPOSURES  
NUMBER (37) TYPE (38) DESCRIPTION (39)  
0 0 0 Z NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
PERSONNEL INJURIES  
NUMBER (40) DESCRIPTION (41)  
0 0 0 NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
LOSS OF OR DAMAGE TO FACILITY  
TYPE (42) DESCRIPTION (43)  
Z NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

7 8 9 10  
PUBLICATION  
ISSUED DESCRIPTION (45) 8701050229 NRC USE ONLY  
2 0 Y (44) Weekly News Release  
1 8 9 10  
NAME OF PREPARER Michael J. Fitzgerald  
PHONE: (609) 693-6038