

COPY

PACIFIC GAS AND ELECTRIC COMPANY

LAW DEPARTMENT - 77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

December 30, 1980

Mr. R. H. Engelken, Director
Office of Inspection and Enforcement
Region V
U. S. Nuclear Regulatory Commission
1990 N. California Boulevard
Walnut Creek Plaza, Suite 202
Walnut Creek, California 94596

Re: Docket No. 50-133
License No. DPR-7

Dear Mr. Engelken:

Pursuant to Section X.A.1.g.(1)b. of the Technical Specifications of the Humboldt Bay Unit No. 3 Operating License, enclosed is LER-80-007/03L-0 covering a broken off water pump pulley from the pump shaft of the #2 Fire Pump diesel engine.

Very truly yours,

Philip A. Crane, Jr.

Enclosure
CC w/enc.: Director
Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8101050406

5

A002
5/1