



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMM.
TRAN.

December 11, 1980

U.S. NRC
DISTRIBUTION SERVICES
BRANCH

1980 DEC 15 AM 12 23

DISTRIBUTION
UNIT

MEMORANDUM FOR: Chairman Ahearne
Commissioner Gilinsky
Commissioner Hendrie
Commissioner Bradford

FROM: William J. Dircks, Executive Director for Operations

SUBJECT: DAILY STAFF NOTES, DECEMBER 10, 1980

IE

1. Farley Unit No. 2 (Alabama Power) - Concrete Block Wall Deviations, (PNO-II-80-170).
2. Turkey Point, Units 3 & 4 (FP&L) - Breach of Radioactive Waste Package Integrity, (PNO-II-80-171).
3. Hatch 1 and 2 (Georgia Power) - Offsite Survey of Waste Oil Dealers, (PNO-II-80-172).

NRR

Joseph M. Farley, Unit No. 1

On December 8, 1980, we were advised by Alabama Power Company of preliminary results of the Farley Unit No. 1 turbine disc examination. The turbines have completed two core cycles of operation since plant licensing in June 1977. Test results for low pressure discs revealed keyway and bore cracks in disc number one and keyway cracks in disc number 2. Testing is still under way on the remaining discs.

REGION I PLANT STATUS- 12/10

POOR ORIGINAL

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
BEAVER VALLEY 1	90		SOAKING CORE 1%/HR; WILL BE AT 100% TOMORROW	
CALVERT CLIFFS 1		X	REFUELING	12/15
CALVERT CLIFFS 2	72		COASTING DOWN	
FITZPATRICK	100			
GINNA	100			
HADDAM NECK	100			
INDIAN POINT 2		X	REFUELING AND REPAIR FAN COOLERS	6/81
INDIAN POINT 3		X	MAINTENANCE ON RCP	
MAINE YANKEE		X	REPLACE 2 RCP SEALS	
MILLSTONE 1		X	REFUELING	1/15
MILLSTONE 2	100			
NINE MILE POINT 1	92		COAST DOWN	
OYSTER CREEK	100			
PEACH BOTTOM 2	100			
PEACH BOTTOM 3	100			
PILGRIM 1	100			
SALEM 1		X	REFUELING/CHECKING SEISMIC DESIGN	12/13
SALEM 2		X	AWAITING LICENSE	
THREE MILE ISLAND 1		X	NRC ORDER	
THREE MILE ISLAND 2		X	NRC ORDER	
VERMONT YANKEE		X	REFUELING	12/22
YANKEE ROWE	100			

REGION II PLANT STATUS- 12/10

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
BROWNS FERRY 1	99			
BROWNS FERRY 2	81		PRECONDITIONING AT 10 MW/HR/ROD PATTERN ADJUSTMENT	
BROWNS FERRY 3		X	REFUELING	1/9
BRUNSWICK 1	99			
BRUNSWICK 2		X	FW HEATER OUTAGE/WILL GO TO POWER TODAY	
CRYSTAL RIVER 3	60		FW PUMP REPAIR	
FARLEY 1		X	REFUELING	
HATCH 1	80		LIMIT	
HATCH 2		X	REFUELING	2/1
NORTH ANNA 1	100			
NORTH ANNA 2		X	TRANSFORMER AND BUSS REPAIRS	12/12
OCONEE 1	99			
OCONEE 2	99			
OCONEE 3		X	REFUELING	
ROBINSON 2		X	MAINTENANCE	12/12
SEQUOYAH 1		X	COLD SHUTDOWN - MAINTENANCE	12/13
ST. LUCIE 1	100			
SURRY 1		X	S. G. REPLACEMENT	8/81
SURRY 2	100			
TURKEY POINT 3	75		MONITORING SEPARATOR LEAK REPAIR	
TURKEY POINT 4		X	REFUELING	1/15

REGION III PLANT STATUS- 12/10

POOR ORIGINAL

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
BIG ROCK POINT		X	REFUELING	1/7
COOK 1	100			
COOK 2		X	MAIN GENERATOR REPAIR	12/10
DAVIS-BESSE 1	55		RC PUMP SEAL AND FW SPIKING	
DRESDEN 1		X	CHEMICAL CLEANING	INDEF
DRESDEN 2	47		COASTDOWN	
DRESDEN 3	99			
DUANE ARNOLD	99			
KEWAUNEE	100			
LACROSSE		X	REFUELING	1/31
LASALLE		X	AWAITING LICENSE	
MONTECELLO	100			
PALISADES		X	STARTING UP/CRITICAL TODAY	12/25
POINT BEACH 1		X	REFUELING	12/25
POINT BEACH 2	100			
PRAIRIE ISLAND 1	100			
PRAIRIE ISLAND 2	100			
QUAD CITIES 1		X	REFUELING	12/21
QUAD CITIES 2	80		INCREASING IN POWER/PRECONDITIONING	
#ZION 1		X	TRIP FROM 25% POWER	
ZION 2	91		AT LIMIT WITH FEEDWATER HEATER OUT	

REGION IV PLANT STATUS- 12/10

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
ARKANSAS 1	65		3 PUMP OPERATION	
ARKANSAS 2		X	COLD SHUTDOWN/CVCS LEAK	
COOPER	98			
FORT CALHOUN	75		ADMINISTRATIVE CONTROL (FUEL CONSERVATION)	
FORT ST. VRAIN	68		70% LICENSE LIMIT	

REGION V PLANT STATUS- 12/10.

PLANT NAME	PLANT STATUS		REASON OR COMMENT	RESTART DATE
	% POWER	DOWN		
DIABLO CANYON		X	AWAITING LICENSE	
RANCHO SECO	100			
SAN ONOFRE		X	STEAM GENERATOR TUBE REPAIR	4/16
TROJAN	100			

* - REASON OR COMMENT HAS CHANGED IN PAST 24 HOURS

- REACTOR SCRAM WITHIN PAST 24 HOURS

NOTE - REACTOR STATUS DATA COLLECTED BETWEEN 6 A. M. AND 8 A. M. EACH DAY EXCEPT HOLIDAYS AND WEEKENDS