

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

December 29, 1980

E. A. BORGMANN  
SENIOR VICE PRESIDENT

United States Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attention: Mr. James G. Keppler ✓  
Regional Director

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1  
IE BULLETIN 80-21, VALVE YOKES SUPPLIED BY  
MALCOLM FOUNDRY COMPANY, INC., DOCKET 50-358  
W.O. 57300, JOB E-5590, FILE #3-R

Gentlemen:


This is an interim response to I.E. Bulletin 80-21 which concerns valve parts that were supplied by the Malcolm Foundry Company, Inc. and did not meet specified hardness requirements. The bulletin requested a response by January 2, 1981.

We have contacted all fourteen (14) vendors who have supplied Nuclear grade valves for Zimmer Station to determine if Malcolm Foundry Company, Inc. parts were used in their manufacture.

All fourteen (14) vendors have responded verbally that no Malcolm materials were used in Zimmer Power Station Products. As soon as confirmation of their statements is obtained from all vendors, we will submit our final report on this Bulletin.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By   
E. A. BORGMANN  
Senior Vice President

WDW:dew

cc: W. D. Waymire (pink)  
Attn: General File  
J. D. Flynn  
W. W. Schwiers  
J. R. Schott  
B. K. Culver  
Attn: S. C. Swain  
H. C. Brinkmann  
F. T. Daniels - Site Rep.

NRC Office of Inspection & Enforcement  
Division of Fuel Facility & Materials  
Safety Inspection  
Washington, D.C. 20555

JAN 02 1981

8101150901