



**PUBLIC  
SERVICE  
INDIANA**

S. W. Shields  
Senior Vice President -  
Nuclear Division

0415814015

January 15, 1981

Mr. James G. Keppler, Director  
U. S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Docket Nos.: STN 50-546  
STN 50-547  
Construction Permit Nos.:  
CPPR - 170  
CPPR - 171

Marble Hill Nuclear Generating Station - Units 1 and 2

Dear Mr. Keppler:

On July 17, 1980, Mr. T. D. Geib of Public Service Company of Indiana, Inc. (PSI) notified your office of a potentially reportable item as required by 10 CFR 50.55(e). The support steel supplier for the Nuclear Steam Supply System, Lakeside Bridge and Steel Company, notified PSI that certain radiographs of the steam generator upper lateral support embedments did not meet the density requirements of Section V of the ASME B&PV Code.

In an interim report of October 20, 1980, PSI identified additional embedments and pipe restraints which required reexamination. This reexamination has been performed and all the embedments and pipe restraints appear to meet specification requirements, however, PSI is presently reviewing these reexamination records to ensure they are of acceptable quality. PSI anticipates the results of this examination will be available on or before February 20, 1981. If you have any questions on this matter, please feel free to contact me.

Sincerely,

S. W. Shields

TDG/cg

cc: Director of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

E. R. Schweibinz, P. E.  
J. J. Harrison

B019  
S  
1/0