

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) * (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N I C B E P 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 1 2 3 1 8 0 8 0 1 2 2 8 1 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During unit load changes while moving control rods, No. 38-11 position indication
0 3 | showed a superimposed "3" over the "8" digit when at position "48". All other control
0 4 | rod position indications were normal. This event did not affect the health or safety
0 5 | of the public.
0 6 |
0 7 | Technical Specifications 3.1.3.F, 6.9.1.9b

0 8 | _____ 80

0 9 | SYSTEM CODE [R B] (11) CAUSE CODE [E] (12) CAUSE SUBCODE [A] (13) COMPONENT CODE [I N S T R U] (14) COMP. SUBCODE [S] (15) VALVE SUBCODE [Z] (16)
17 LER/RO REPORT NUMBER [8 0] (21) [] (22) SEQUENTIAL REPORT NO. [1 1 8] (24) [] (25) OCCURRENCE CODE [0 3] (26) REPORT TYPE [L] (27) REVISION NO. [0] (28)
ACTION TAKEN [X] (33) FUTURE ACTION [C] (34) EFFECT ON PLANT [Z] (35) SHUTDOWN METHOD [Z] (36) HOURS [0 0 0 0] (37) ATTACHMENT SUBMITTED [N] (38) NPRO-4 FORM SUB. [Y] (39) PRIME COMP. SUPPLIER [N] (40) COMPONENT MANUFACTURER [G 0 8 0] (41)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A reed switch problem in the rod PIP probe is suspected as the cause of this event.
1 1 | This problem will be corrected during the next outage of sufficient length that allows
1 2 | access to the drywell.
1 3 |
1 4 | _____ 80

1 5 | FACILITY STATUS [F] (28) % POWER [0 5 0] (29) OTHER STATUS [NA] (30) METHOD OF DISCOVERY [A] (31) DISCOVERY DESCRIPTION [Operational Event] (32)

1 6 | ACTIVITY RELEASED [Z] (33) CONTENT OF RELEASE [Z] (34) AMOUNT OF ACTIVITY [NA] (35) LOCATION OF RELEASE [] (36)

1 7 | PERSONNEL EXPOSURES NUMBER [0 0 0] (37) TYPE [Z] (38) DESCRIPTION [] (39)

1 8 | PERSONNEL INJURIES NUMBER [0 0 0] (40) DESCRIPTION [] (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE [Z] (42) DESCRIPTION [] (43)

2 0 | PUBLICITY ISSUED [N] (44) DESCRIPTION [] (45) NRC USE ONLY [] (46-50)

NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521

8101270 794