



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555



JAN 14 1981

MEMORANDUM FOR: Franz P. Schauer, Chief
Structural Engineering Branch, DE

FROM: Don Sells, Project Manager
Licensing Branch No. 2, DL


SUBJECT: COMPRESSIVE STRENGTH TESTS FOR D-MIX CONCRETE AT LIMERICK
GENERATING STATION

On September 24, 1980 Philadelphia Electric Company transmitted Amendment 24 to their Preliminary Safety Analysis Report.

This Amendment is similar to Amendment 22 to the PSAR which requested acceptance testing for 5000 psi concrete (D-Mix) be performed at 90 days. Amendment 22 was not accepted by the staff.

In Amendment 24 the same testing schedule is proposed for 5000 psi concrete, i.e. 90 days. It is my understanding that 90 day testing has been approved for Susquehanna Steam Electric Station.

It is requested that you review Amendment 24 and advise me of its acceptability.


Don Sells, Project Manager
Licensing Branch No. 2
Division of Licensing

8101300144

A