

TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37404

1750 Chestnut Street Tower II

January 26, 1981

POOR ORIGINAL

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SQRO-50-327/80207

The enclosed report provides details concerning the inoperability of
remote shutdown monitoring indicators for pressurizer level. This event
resulted in the plant entering action statement "a" of limiting condition
for operation 3.3.3.5 and is reported under Sequoyah unit 1 Technical
Specification 6.9.1.13.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. J. Green
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Lavalley
Nuclear Safety Analysis Center
Palo Alto, California 94303

NRC Inspector, Sequoyah

A002
S
1/1

8102020465
S