

TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37403

1750 Chestnut Street Tower II

January 26, 1981

POOR ORIGINAL

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SQRO-50-327/80205

The enclosed report provides details concerning the ice condenser inter-
mediate deck doors which were frozen closed. These events resulted
in entering limiting condition for operation 3.6.5.3 and are reportable
under Sequoyah unit 1 Technical Specification 6.9.1.13.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. J. Green
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Levallee
Nuclear Safety Analysis Center
Palo Alto, California 94303

NRC Inspector, Sequoyah

A002
S
/ /

8102020480

S