



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 10, 1981

Docket No. 50-348

Mr. F. L. Clayton, Jr.
Senior Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291



Dear Mr. Clayton:

We are continuing our review of the Inservice Testing Program (IST) for Joseph M. Farley Nuclear Plant Unit No. 1. Alabama Power Company (APCO) is required by 10 CFR 50.55a(g) to have an IST program meeting the 1974 Edition of the ASME code with the 1975 Summer Addenda. The code states that safety-related, locked-open or locked-closed valves shall be categorized as E and must meet the "testing" requirements for Category E valves.

Nearly all operating plants have locked-valve lists which meet the "testing" requirements of the ASME code. These plants have categorized the safety-related, locked valves as Category E and have included these valves in their IST Program. We understand from our discussions with your staff that listing the Category E valves in the IST Program is an additional administrative chore without any safety benefit. We do not agree.

We have determined that Category E valves must be included in the Farley Unit 1 IST Program on the following basis:

1. APCO would be in non-compliance with 10 CFR 50.55a(g) since we have not granted and do not intend to grant relief from this ASME code requirement. Further, APCO has not requested specific relief.
2. We would be inconsistent in the regulatory approach being taken with other licensees.
3. Inspection and Enforcement (IE), in developing the IST inspection requirements, would be mislead in assuming that Category E valves are not part of our program requirements.
4. The 1977 Edition of the ASME Code has eliminated Category E valves from the code. However, our staff is still reviewing this item and have not agreed to elimination at this time.


81022804 00

Mr. F. L. Clayton, Jr.

- 2 -

On this basis, we request that you provide a revision to your proposed IST Program at your earliest convenience.

Sincerely,


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

cc: See attached list

Mr. F. L. Clayton, Jr.
Alabama Power Company

cc: Mr. W. O. Whitt
Executive Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Ruble A. Thomas, Vice President
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Mr. Robert A. Buettner, Esquire
Balch, Bingham, Baker, Hawthorne,
Williams and Ward
Post Office Box 306
Birmingham, Alabama 35201

George S. Houston Memorial Library
212 W. Burdeshaw Street
Dothan, Alabama 36303

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 24-Route 2
Columbia, Alabama 36319