



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELL /N, ILLINOIS 60137

TIC

FEB 5 1981

Docket No. 50-440
Docket No. 50-441

The Cleveland Electric Illuminating
Company
ATTN: Dalwyn R. Davidson
Vice President - System
Engineering and Construction
Post Office Box 5000
Cleveland, OH 44101



Gentlemen:

Thank you for your letter dated January 15, 1981, superseding your original letter of November 19, 1980 in which you informed us of the steps you have taken to correct the items of noncompliance we brought to your attention in Inspection Reports No. 50-440/80-20 and No. 50-441/80-18.

Based on the information provided in your letter and by Mr. M. R. Edelman in a telephone conversation on January 26, 1981 with Mr. D. W. Hayes of this office, we have no further questions in regard to Item I, and will review your corrective actions during a future inspection.

In regard to Item II we understand that you will document the concrete truck agitating revolutions and discharge times either by recording them on the batch plant ticket or by providing a discreet line item on the pour inspection plan. We further understand, concerning Item III, that you will not substitute written examinations for an inordinate portion of the work experience required by ANSI N45.2.6-1973. We will review these items during a subsequent inspection.


The Cleveland Electric
Illuminating Company

- 2 -

FEB 5 1981

Your cooperation with us is appreciated.

Sincerely,



G. Fiorelli, Chief
Reactor Construction and
Engineering Support Branch

cc w/ltr dtd 1/15/81:
Central Files
Reproduction Unit NRC 20b
PDR
Local PDR
NSIC
TIC
Harold W. Kohn, Power
Siting Commission
Daniel D. Wilt, Attorney
Helen W. Evans, State of Ohio