10.00	LICENSEE EVENT REPORT
	CONTROL BLOCK: [ ] [ ] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
7 8	0 H D B S 1 2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
CON'T	REPORT L 6 0 5 0 - 0 3 4 6 7 0 1 2 8 8 1 8 0 2 2 2 7 8 1 9 SOURCE 60 FORT DATE 68 69 EVENT DATE 74 75 REPORT DATE 80
0 2	EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  [(NP-33-81-07) On 1/28/81 at 0330 hours during the performance of the Diesel Generator]
0 3	Monthly Test ST 5081.01, Diesel Generator (DG) 1-2 could not be started with the left ]
0 4	side set of air start motors. It would start with the right side motors. The station
0 5	was in Mode 5 at the time, and the requirements of Technical Specification 3.8.1.2
06	were being met. There was no danger to the health and safety of the public or station
07	personnel. Diesel Generators 1-1 and 1-2 were operable during this time. This event
0 8	Lis being reported to document a component failure.
7 8	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC
0 9	E E (1) E (12) B (13) M O T O R X (14) Z (15) Z (16)  9 10 11 12 12 SEQUENTIAL OCCURRENCE REPORT REVISION
	17 REPORT NUMBER 21 22 23 24 26 27 28 29 30 31 32
	ACTION FUTURE COMPONENT SUPPLIER SUPPLI
[1]	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)    The cause of the occurrence was the failure of one air start motor. The air start motor
	had a broken solenoid drive shaft. The break is considered a random failure. Under
1 2	Maintenance Work Order 81-1406, the air start motor was replaced. The Emergency Diesel
13	Generator 1-2 was successfully tested under ST 5081.01 and declared operable at 1415
114	hours on January 28, 1981.
7 8	FACILITY STATUS SO OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 B 31 Surveillance Test ST 5081.U1 80
	ACTIVITY CONTENT RELEASED OF MELEASE AMOUNT OF ACTIVITY 35  I Z 33 Z 34 NA  NA  NA  B0
1 7 8	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)  9 11 12 13 NA  80
118	PERSONNEL INJURIES NUMBER DESCRIPTION 41    Ø   Ø   Ø   (40) NA
V 8	9 11 12 80  LOSS OF OR DAMAGE TO F CILITY 43  TYPE DESCRIPTION 43
7 8	YA NA BO NRC USE ONLY
20	ISSUED DESLAIPTION 45 B103030 84 S
PVR 81	(419) 259-5000, Ext. 252

## TOLEDO EDISON COMPANY DAVIS-BESSE NUCLEAR POWER STATION UNIT ONE SUPPLEMENTAL INFORMATION FOR LER NP-33-81-07

DATE OF EVENT: January 28, 1981

FACILITY: Davis-Besse Unit 1

IDENTIFICATION OF OCCURRENCE: Failure of one of four air start motors on Emergency Diesel Generator 1-2.

Conditions Prior to Occurrence: The unit was in Mode 5 with Power (MWT) = 0 and Load (Gross MWE) = 0.

Description of Occurrence: On January 28, 1981 at 0330 hours during the performance of the Diesel Generator Monthly Test ST 5081.01, Diesel Generator 1-2 could not be started with the left side set of air start motors. It would start with the right side motors. There are two sets of air start motors on each diesel. Each set has two air start motors. The station was in Mode 5 at the time, and the requirements of Technical Specification 3.8.1.2 were being met by the operability of Diesel Generators 1-1 and 1-2. Therefore, the station did not enter an action statement. This event is being reported to document a component failure of one air start motor.

Designation of Apparent Cause of Occurrence: The cause of the occurrence is the component failure of an air start motor. The motor failed when the solenoid drive shaft broke. The starting sequence actuates the solenoid. The solenoid moves the solenoid drive shaft causing a gear attached to it to engage a planetary gear assembly which is connected to the air start motor. The air supply line then opens to the air motor which starts the shaft turning. The solenoid drive shaft broke between the solenoid and the gear. The break is considered a random failure.

Analysis of Occurrence: There was no danger to the health and safety of the public or to station personnel. Emergency Diesel Generators 1-1 and 1-2 were operable during this time.

Corrective Action: The faulty air start motor was replaced under Maintenance Work Order 81-1406. The engine was tested satisfactorily by the performance of ST 5081.01. Diesel Generator 1-2 was returned to normal at 1415 hours on January 28, 1981.

Failure Data: There have been no other previous occurrences of this nature.

LER #81-009