

### UNITED STATES NUCLEAR REGULATORY COMMISSION REGION I

631 PARK AVENUE KING OF PRUSSIA, PENNSYLVANIA 19406

Docket No. 50-289

FEB 1 2 1981

Metropolitan Edison Company ATTN: Mr. H. D. Hukill

Vice President and Director of TMI-1

P. O. Box 480

Middletown, Pennsylvania 17057

### Gentlemen:

The enclosed IE Information Notice No. 81-03, "Checklist for Licensees Notifications of Significant Events in Accordance with 10 CFR 50.72," is forwarded to you for information. No written response is required. If you desire additional information regarding this matter, please contact this office.

Sincerely,

rector

Enclosures:

1. IE Information Notice No. 81-03, with 2 attachments

CONTACT: D. L. Caphton

(215-337-5266)

cc w/encls:

R. J. Toole, Manager, TMI-1 L. W. Harding, TMI-1 Licensing Supervisor

E. G. Wallace, PWR Licensing Manager

J. B. Liberman, Esquire G. F. Trowbridge, Esquire

Ms. Mary V. Southard, Chairperson, Citizens for a Safe Environment

SSINS No. 6870 Accession No. 8011040260 IN 81-03

# UNITED STATES NUCLEAR REGULATORY COMMISSION OFFICE OF INSPECTION AND ENFORCEMENT

February 12, 1981

IE Information Notice No. 81-03: CHECKLIST FOR LICENSEES MAKING NOTIFICATIONS OF SIGNIFICANT EVENTS IN ACCORDANCE WITH 10 CFR 50.72

### Description of Circumstances:

Significant events reported to the NRC Operations Center receive prompt evaluation by NRC technical staff. To assure that adequate information is obtained for evaluation, in an expedient manner, checklists have been developed for the various types of events and are currently in use by the duty officers manning the NRC Operations Center. In an effort to communicate to licensees the most useful types of information needed depending on the event, a combined checklist has been developed and is attached to this information notice. We recognize that this list is not all inclusive, nor are all of its sections applicable to each event. Rather, it is an attempt to list certain key data elements that, based on past experience, appear to suffice for the vast majority of notifications. Having this type of information available at the time of notification, or shortly thereafter, will serve to expedite the notification and evaluation process and make it more efficient. It is not intended that licensees complete the checklist prior to, or as a condition of, making a notification. Instead, the list is intended to inform licensees of the types of information about events that have been useful to the NRC.

We solicit your cooperation in obtaining any other information that may aid NRC in understanding the event and request that you volunteer such information where appropriate.

## Recommendation to Licensees:

This information notice is provided for general information to licensees. Recipients should review the information for applicability to their facilities. No specific action or response is requested at this time.

If you have any questions regarding this matter, please contact the Director of the appropriate NRC Regional Office.

#### Attachments:

- 1. Checklist
- Recently issued IE Information Notices

## CHECKLIST FOR NOTIFICATION OF SIGNIFICANT EVENTS MADE IN ACCORDANCE WITH 10 CFR 50.72

	f Person Making Reportacility Affected
Description:	72
	74
	Time
	ete depending on type of event)
	Fatalities
	(property)
Safety Hazard (describe - actu	mal/potential)
Offsite Radiation Levels	
	Location
	From (direction)
	r, overcast, temperature)
Equipment/Property Damage	
Cause of Event: .	
icensee Actions:	
aken	
Turney	

sident	Inspector Notified (Yes/No) State Notified (Yes/No)				
ess Rel	lease Planned (Yes/No) News Media Interest (Yes/No)				
	Local/National				
Curr	rent Status: (Complete depending on type of event)				
1.	Reactor Systems Status				
	Power Level Before Event After Event				
	PressureTemp. (thot)(tcold)				
	RCS Flow (Yes/No)Pumps On (Yes/No)				
	Heat Sink: Condenser Steam Atm. Dump				
	OtherSample Taken (Yes/No) Activity Level				
	ECCS Operating (Yes/No)ECCS Operable (Yes/No)				
	ESF Actuation (Yes/No)				
	PZR or RX Level Possible Fuel Damage (Yes/No)				
	S/G Levels Feedwater Source/Flow				
	Containment PressureSafety Relief Valve Actuation (Yes/No)_				
	Containment Water Level Indication				
	Equipment Failures				
	Normal Offsite Power Available (Yes/No)				
	Major Busses/Loads Lost				
	Safeguards Busses Power Source				
	D/G Running (Yes/No) Loaded (Yes/No)				

<sup>1</sup> See Emergency Action Levels, Appendix 1, NUREG-0654, Revision 1, Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants.

Radioactivity Release	
Liquid/Gas	Location/Source
Release Rate	Duration
Stopped (Yes/No)	Release Monitored (Yes/No)
Amount of Release	Tech Spec. Limits
Radiation Levels in Plant	Areas Evacuated
Security/Safeguards 2	
Bomb Threat: Search Conducted	d (Yes/No) Search Results
Site Evacuated (Yes/No)	
Intrusion: Insider	Outsider
Point of Intrusion	Extent of Intrusion
Apparent Purpose	
Strike/Demonstrations: Size of	f Group
Purpose	
Sabotage: Radiological (Yes/No	o) Arson (Yes/No)
Equipment/Property	
Extortion: Source (phone, let	ter, etc.)
Location of Letter	
Demands	
	es/No)Violence (Yes/No)
Control of Facility Compromised	d or Threatened (Yes/No)
	Police, Local Police, etc.)

<sup>2</sup> See 10 CFR 73.71(c), effective April 6, 1981.

IE Information Notice No. 81-03 February 12, 1981

Attachment 2 IN 81-03

## RECENTLY ISSUED IE INFORMATION NOTICES

Information Notice No.	Subject	Date Issued	Issued to
81-02	Transportation of Radiography Devices	1/23/81	All holders of a radiography license
81-01	Possible Failures of General Electric Type HFA Relays	1/16/81	All holders of a power reactor OL or CP
80-45	Potential Failure of BWR Backup Manual Scram Capability	12/17/80	All holders of a power reactor OL or CP
80-44	Actuation of ECCS in the Recirculation Mode While in Hot Shutdown	12/14/80	All holders of a PWR power reactor OL or CP
80-43	Failures of the Continuous Water Level Monitor for the Scram Discharge Volume at Dresden Unit No. 2	12/5/80	All holders of a BWR power reactor GL or CP
80-29 Supplement No. 1	Broken Studs on Terry Turbine Steam Inlet Flange	11/26/80	All holders of a power reactor OL or CP
80-42	Effects of Radiation on Hydraulic Snubber Fluid	11/24/80	All holders of a power reactor OL or CP
80-41	Failure of Swing Check Valve in the Decay Heat Removal System at Davis-Besse Unit No. 1	11/10/80	All holders of a power reactor OL or CP
80-40	Excessive Nitrogen Supply Pressure Activates Safety-Relief Valve Operation to Cause Reactor Depressurization	11/6/80	All holders of a power reactor OL or CP