



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

Docket No. 50-333

30 JAN 1981

Power Authority of the State of New York
James A. FitzPatrick Nuclear Power Plant
ATTN: Mr. R. J. Pasternak
Resident Manager
P. O. Box 41
Lycoming, New York 13093



Gentlemen:

Subject: Inspection 50-333/80-03

This refers to your letter dated January 19, 1981, in response to our letter dated December 22, 1980.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

With regard to Item 2 of Appendix A to our referenced letter, based on a telephone discussion on January 27, 1981 between Mr. R. L. Nimitz of this office and Mr. E. A. Mulcahey of your staff, a procedure is to be established by May 21, 1981 for performing air quality tests of the breathing air supplied by the breathing air system. Additionally, based on this same discussion, the test procedure will specify test frequencies and test methods to be utilized.

Your cooperation with us is appreciated.

Sincerely,

George H. Smith, Chief
Fuel Facility and Materials
Safety Branch

cc:

George T. Berry, Executive Director
J. P. Bayne, Senior Vice President-Nuclear Generation
A. Klausmann, Director, Quality Assurance
M. C. Cosgrove, Site Quality Assurance Engineer
J. F. Davis, Chairman, Safety Review Committee
C. M. Pratt, Assistant General Counsel
G. M. Wilverding, Manager-Nuclear Licensing

8103050 746