POOR ORIGINAL

NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Field	Value
01 Licensee Code (2)	A L J M F 1
License Number (3)	00-00000-00
License Type (4)	4 1 1 1 1
CAT (5)	
CON'T 01 Report Source (6)	L
Docket Number (7)	0 5 0 0 0 3 4 8
Event Date (8)	0 8 1 2 8 0
Report Date (9)	0 9 1 1 8 0

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 1511 on 8-12-80 and 1653 on 8-25-80, the service water (S.W.) building B train
03 battery system was declared inoperable due to low battery cell specific gravity. Tech
04 Spec 3.8.2.5, in part, requires the S.W. building B train battery system to be
05 operable. Tech Spec. 3.8.2.5 action statement requirements were met. The battery
06 was returned to service at 1700 on 8-12-80 and 1919 on 8-25-80 (respectively) follow-
07 ing corrective action and the successful performance of the surveillance test.
08 Health/safety of the public were not affected.

09	System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
	E C	X	Z	B A T T R Y	Z	Z

(17) LER/RO Report Number	Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
	8 0	—	0 4 7	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
X	F	Z	Z	0 0 0 0	N	N	A	E 3 5 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 After the first occurrence the battery was placed on equalize and the specific gravity immediately returned to an acceptable value. Following the second occurrence an
11 inspection again revealed no external cause for the low specific gravity. The corrective action for this occurrence included the implementation of a design change
12 to remove the affected cells (3) from the battery and initiation of an evaluation for
13 the replacement of the entire battery.
14

15	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
	E	1 0 0	NA	B	Performance of surveillance test

16	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
	Z	Z	NA	NA

Personnel Exposures

17	Number (37)	Type (38)	Description (39)
	0 0 0	Z	NA

Personnel Injuries

18	Number (40)	Description (41)
	0 0 0	NA

Loss of or Damage to Facility (43)

19	Type (42)	Description
	Z	NA

Publicity

20	Issued (44)	Description (45)	NRC Use Only
	N	NA	

8009160308

NAME OF PREPARER W. G. Hairston, III. PHONE (205) 899-5156