NRC FORM 366 (7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYJAF1 (2) | 00-0000-000 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000333 (7) | 080580 (8) | 091180 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal shutdown, while conducting Instrument Surveillance Procedure F-ISP-8,
03 Core Spray System pipe break detection switches 14-DPIS-43A and 43B were found set
04 at 1.5 and 2.05 PSID respectively when required to be set at less than or equal to
05 0.5 PSID by TS Table 3.2-2. Instrument 14-DPIS-43B was also found set at 0.93 PSID
06 on August 18, 1980 and at 0.5088 PSID on August 30, 1980.
07
08

09 | SYSTEM CODE SF (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE S (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 — SEQUENTIAL REPORT NO. 066 — OCCURRENCE CODE 03 — REPORT TYPE X — REVISION NO. 1

ACTION TAKEN X (18) | FUTURE ACTION F (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER B080 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Caused by Instrument drift. In each case the instrument was calibrated and returned
11 to service. Surveillance frequency was increased to once each week. New switches
12 of different design are expected to arrive by October 1980 and will be installed
13 as permanent corrective action. Revision 1 is submitted to include the out of
14 specification reading noted on August 30, 1980.

15 | FACILITY STATUS G (28) | % POWER 000 (29) | OTHER STATUS NA (30) | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

8009160476

NRC USE ONLY

W. Verne Childs (315) 342-3840 X207