

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

- - - - -x
:
In the matter of: :
:
METROPOLITAN EDISON COMPANY :
:
(Three Mile Island Unit 1) :
:
- - - - - :
:

Docket No. 50-289
(Restart)

25 North Court Street,
Harrisburg, Pennsylvania

Friday, November 14, 1980

Evidentiary hearing in the above-entitled
matter was resumed, pursuant to adjournment, at 8:46 a.m.

BEFORE:

- IVAN W. SMITH, Esq., Chairman,
Atomic Safety and Licensing Board
- DR. WALTER H. JORDAN, Member
- DR. LINDA W. LITTLE, Member

8011240043

1 APPEARANCES:

2 On behalf of the Licensee, Metropolitan Edison
3 Company:

4 GEORGE F. TROWBRIDGE, Esq.
5 THOMAS A. BAXTER, Esq.
6 DELISSA A. RIDGWAY, Esq.
7 Shaw, Pittman, Potts and Trowbridge,
8 1800 M Street, N.W.,
9 Washington, D. C.

10 On behalf of the Commonwealth of Pennsylvania:

11 ROBERT ADLER, Esq.
12 Assistant Attorney General,
13 505 Executive House,
14 Harrisburg, Pennsylvania
15 WILLIAM DORNSIFE,
16 Nuclear Engineer

17 On behalf of Union of Concerned Scientists:

18 ELLYN WEISS, Esq.,
19 ROBERT D. POLLARD
20 Harmon & Weiss,
21 1725 I Street, N.W.
22 Washington, D. C.

23 On behalf of the Regulatory Staff:

24 JAMES TOURTELLOTTE, Esq.
25 JAMES M. CUTCHIN, IV, Esq.
Office of Executive Legal Director,
United States Nuclear Regulatory Commission,
Washington, D. C.

C O N T E N T S

WITNESSES:

EXAMINATION
BY THE BOARD

CROSS EXAMINATION
BY UCS

Gary R. Capodanno,
Louis C. Lanese, and
Joseph A. Torcivia (Recalled)

By Dr. Jordan	5663	
By Dr. Little	5683	
By Mr. Pollard		5685
By Ms. Weiss		5702
By Mr. Pollard		5706
By Ms. Weiss		5744
By Mr. Pollard		5745

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

P R O C E E D I N G S

1
2 CHAIRMAN SMITH: Before we went on the record this
3 morning, we had a discussion about scheduling, and in
4 particular, the scheduling of November 24. UCS has
5 requested that that be an off day, because they need office
6 time. Licensee has requested that we proceed for efficiency
7 and to expedite the hearings.

8 The Board observed that we believe that UCS has
9 made good use of office time in preparation of the gross
10 examination plans. That has itself resulted in some
11 efficiencies, and it will take this into account in
12 determining whether we meet on the 24th or not.

13 All right. Are you ready?

14 MR. BAXTER: Mr. Chairman, I have a preliminary
15 matter for the record.

16 We have had discussion at various points of the
17 need for written testimony to be filed and timely notice of
18 parties of evidence that is going to be presented, and I
19 would like to call one matter to the Board's attention along
20 that line.

21 I was handed yesterday by Mr. Pollard a letter
22 dated November 13, 1980, from Ms. Weiss to the Board
23 enclosing three documents which UCS proposes to offer as
24 exhibits accompanying Mr. Pollard's testimony, which I
25 expect to be presented next week on UCS Contention Number

1 10. This is Agenda Item Number 4. According to the Board's
2 scheduling memoranda and orders, as I understand it, this
3 evidence should have been filed with the parties on
4 September 25, 1980, pursuant to an extension of time granted
5 to the NRC staff and intervenors on UCS Contention Number 10.

6 The three documents are all dated 1975. They are
7 not being produced as a result of any inquiry by the Board
8 which has been the product of some of the other late
9 evidence that has been presented in the last two weeks.

10 I have already filed my cross examination plan on
11 Mr. Pollard's testimony in this area and consulted with my
12 technical people on the cross examination of Mr. Pollard for
13 next week.

14 I am going to object to the exhibit because
15 of their brevity. Therefore, there is no need for a Board
16 ruling on this matter. I simply wanted to call it to your
17 attention, because I do not want it to be taken as a
18 precedent that exhibits that should have been filed earlier
19 can be accepted at this late date, and giving us so little
20 notice without any justification for it.

21 MR. TOURTELLOTTE: Mr. Chairman?

22 CHAIRMAN SMITH: Mr. Tourtellotte?

23 MR. TOURTELLOTTE: One other matter. This
24 morning, I served the responses by hand to UCS
25 interrogatories of September the 25th. I left a copy with

1 the Board members as well as UCS and the other parties
2 present. It will be mailed today. I note on the cover
3 sheet that I have the date September 30th, but I believe
4 that was September the 25th that those interrogatories were
5 posed.

6 Otherwise, this is the package that will be served
7 today, and I brought it up for UCS, for their convenience.

8 CHAIRMAN SMITH: Anything further?

9 MR. CUTCHIN: Yes, Mr. Chairman.

10 Yesterday, Dr. Jordan asked the staff to take a
11 look at its list of Exhibits 29 through 40 to see if there
12 were any additional ones that should be marked or
13 introduced. The staff has taken a look at the staff
14 believes that the exhibits that were put in by the licensee
15 cover all the bases, and there are none of those that we
16 believe need to be put into the record.

17 CHAIRMAN SMITH: Anything further preliminarily?

18 (No response.)

19 CHAIRMAN SMITH: All right. Ms. Weiss?

20 MS. WEISS: Mr. Pollard is going to do this
21 questioning.

22 DR. JORDAN: I was wondering again if it would be
23 helpful to ask Mr. Capodanno to briefly review the operation
24 of the emergency feedwater system. The diagram and the
25 exhibit he supplied with the testimony is useful and

1 helpful, but I still feel it might be worthwhile to spend a
2 few minutes on the diagram, pointing out the major features
3 of the revised system and how it has changed.

4 Is there any objection?

5 MS. WEISS: That is fine.

6 DR. JORDAN: Do you think it would be helpful?

7 MS. WEISS: Yes.

8 DR. JORDAN: All right.

9 Whereupon,

10 GARY R. CAPODANNO,

11 LOUIS C. LANESE, and

12 JOSEPH A. TORCIVIA

13 were recalled as witnesses by the Board, and having been
14 previously duly sworn by the Chairman, were examined and
15 testified further as follows:

16 EXAMINATION BY THE BOARD

17 BY DR. JORDAN:

18 Q Would you be willing to do that, please?

19 A (WITNESS CAPODANNO) This figure shows the
20 emergency feedwater system as it is configured, and you have
21 made mention of some of the changes. The changes really
22 don't show up in this schematic. I can describe them when
23 we get to specific features, if you wish.

24 Q I see. This is the system prior to the changes
25 that were made for restart.

1 A (WITNESS CAPODANNO) Yes.

2 Q All right. Briefly run us through this, then,
3 pointing out the major components and then the changes so
4 that we will be sensitive to it.

5 A (WITNESS CAPODANNO) Okay. In the emergency
6 feedwater system itself, the major components are located in
7 the middle of the page. They are the three pumps labeled
8 EFP 1, EFP 2A and B. Above Pump P1 is the feed pump turbine
9 that drives Pump Number 1. Above those -- I should say
10 above and to the left and right of those are two boxes
11 labeled SG A and B. Those are the respective A and B steam
12 generators.

13 At the bottom of the page, major components are
14 labeled Condensate Storage Tank B on the left and A on the
15 right, and then slightly above those and in the middle is
16 Condenser Hot Well. So, I will start from the bottom of the
17 page and describe the flow path.

18 When this system is in use, it initially takes
19 suction from these condensate storage tanks.

20 Q From the condensate storage tanks?

21 A (WITNESS CAPODANNO) Yes. Water flow would be to
22 the valves labeled 10A and B adjacent to the condensate
23 storage tanks, and as the diagram is on the page, it would
24 be upward on the page into what is referred to as the pump
25 suction header. It is the line that contains valves labeled

1 EFV 1A and 1B. That provides a common inlet for the water
2 to all three pumps, and then the flow is through those pumps
3 through their discharges into this common discharge line,
4 which again is a horizontal line on this diagram containing
5 valves labeled EFV 2A and B.

6 The flow then goes from the discharge header into
7 the steam generators through valves that are labeled EFV 30A
8 and B.

9 Now, the way the system was originally designed
10 was, the turbine driven pump, that is, Pump Number 1, would
11 be initiated, start to operate on either a loss of all four
12 reactor coolant pumps or loss of both main feedwater pumps,
13 and that pump is turbine driven, so what occurred in that
14 instance was, steam supply valves would open up to supply
15 steam to run the turbine labeled EFP turbine on this drawing
16 and operate Pump Number 1.

17 The steam supply comes from the steam generators
18 through what is termed the steam leads. Those are the lines
19 that go vertically up from the steam generators and
20 eventually terminate in the oblong box labeled Turbine. The
21 steam supply comes from the steam leads and initially goes
22 through the valves labeled NSV 13A and 13B, which are
23 located in the top center of this diagram.

24 Q I see the 15A and the 15B, but I can't find the
25 13A.

1 A (WITNESS CAPODANNO) It is directly above. If you
2 just go up vertically from the turbine symbol, you will see
3 an array of four valves and a rectangular configuration.

4 Q Now I see it. Yes, 13A and 13B, I do see there,
5 showing blank is normally closed?

6 A (WITNESS CAPODANNO) Yes, sir.

7 Q So the source of steam then is from the steam
8 generator through the horizontal line. On the B side is MSV
9 2B?

10 A (WITNESS CAPODANNO) Yes, sir.

11 Q All right, and then through a check valve?

12 A (WITNESS CAPODANNO) That is correct.

13 Q Then, which is the normal path. Is it up at that
14 point to the two-inch line?

15 A (WITNESS CAPODANNO) Yes, it is

16 Q I see. So that either steam generator can be used
17 and one is chosen.

18 A (WITNESS CAPODANNO) Yes. The original design
19 was, there is preferential logic for the A generator. That
20 is, if you've got good steam pressure on the A generator
21 above 100 pounds, the 13A valve would open and the 13B valve
22 would remain closed.

23 Q I see.

24 A (WITNESS CAPODANNO) Then in the logic senses that
25 is not enough pressure in the A generator, then the B would

1 come open to supply steam.

2 Q If the pressure was not adequate in Steam
3 Generator A, then that valve would be closed and the other
4 one would be opened. Is that the way it would work?

5 A (WITNESS CAPODANNO) Yes, sir.

6 Q That is the way the logic would work?

7 A (WITNESS CAPODANNO) Yes.

8 Q By sensing the pressure?

9 A (WITNESS CAPODANNO) Yes.

10 Q All right. Now, you say that has been changed.

11 A (WITNESS CAPODANNO) Yes. If I may, I will go
12 through the rest of the steam flow path.

13 Q I think that is probably wise.

14 A (WITNESS CAPODANNO) Again, describing the
15 original design, assuming that steam generator A had
16 adequate pressure, valve MSV 13A would open. Steam flow
17 would then be vertically down on this diagram through the
18 device labeled MSV 6, and it has a PCV next to it indicating
19 pressure control valve. And then steam is admitted to the
20 turbine. That valve functions to control the steam at the
21 unit to that turbine to regulate throttle pressure.

22 Q I see that PCV is a control valve.

23 A (WITNESS CAPODANNO) Yes, sir.

24 Q And determines the speed of the turbine?

25 A (WITNESS CAPODANNO) No, it does not determine the

1 speed. It just regulates the steam supply pressure. This
2 turbine is designed to run on a nominal 200 pounds pressure
3 of steam. And then it has mounted on the turbine unit
4 itself a speed governor.

5 Q I see. And it exhausts into the atmosphere?

6 A (WITNESS CAPODANNO) Yes, sir.

7 Q Okay.

8 A (WITNESS CAPODANNO) So with the original plant
9 design and the initiation scheme I have described, we would
10 then have the turbine driven pump running, supplying steam
11 to the steam generators, going back to the water flow path I
12 described earlier through the MSV -- excuse me, EFV 30A and
13 B valves. Those valves modulate to control flow into the
14 steam generators, and they worked off a level control signal.

15 There is level instrumentation on the steam
16 generator, and through the integrated control system a
17 signal was sent to these valves to modulate them open or
18 closed, to maintain adequate level, liquid level in the
19 steam generators.

20 Q Now, which valve is that?

21 A (WITNESS CAPODANNO) Again, in vertical lines
22 about midway up the drawing, labeled EFV 30A and B.

23 Q 30A and 30B. I see them. All right. So those are
24 normally operated by the ICS?

25 A (WITNESS CAPODANNO) Yes.

1 Q All right.

2 A (WITNESS CAPODANNO) Now, again, staying with the
3 original design, the two motor driven pumps, those numbered
4 EFP 2A and B were available to pump, but they were not
5 automatically initiated in the original design. The
6 operator in the original design could manually start these
7 motor driven pumps.

8 Again, going back to the bottom of the drawing, I
9 mentioned earlier that the condensate storage tanks served
10 as a source of water, and that is the normal source of water.

11 Q Yes, and there are two separate tanks.

12 A (WITNESS CAPODANNO) Yes.

13 Q One serves one of them, and one the other.

14 A (WITNESS CAPODANNO) In a normal line-up, it can
15 be made that way. There is common piping at the supply to
16 the pumps, so that --

17 Q Either one could.

18 A (WITNESS CAPODANNO) You could cross-feed so you
19 could have them both lined up to feed, and you would have
20 the ability with what is termed the sexualizing valves in
21 the header to isolate parts of the system from other parts
22 of the system.

23 Q Yes. I see. Okay.

24 A (WITNESS CAPODANNO) As I mentioned, the
25 condensate storage tanks are the primary source of water.

1 In addition to that, the hot well, which is the rectangle
2 located midway between the two condensate storage tanks, is
3 also a source of water for the emergency feedwater system.

4 Q I see.

5 A (WITNESS CAPODANNO) That source can be lined up
6 to supply water to the pump section by opening valves
7 labeled on this drawing either COV 8 or COV 12.

8 Q Yes.

9 A (WITNESS CAPODANNO) The reason there are two
10 valves is, one of them is normal flow path with normal power
11 supplies, and the other one, COV 12, is a motor-operated
12 valve with emergency power supplied to it, so that in the
13 event the hot well was to be used, and for any reason the
14 Number 8 valve could not be operated, then the 12 valve is
15 available.

16 Now, turning to Figure 2, this is a schematic that
17 represents another source of water for the emergency
18 feedwater system, and the connection between these two
19 diagrams from Figure 2 to Figure 1 is immediately above the
20 box labeled Condenser Hot Well, and there is a line that
21 says From Emergency River Water Source.

22 Q Yes.

23 A (WITNESS CAPODANNO) So that source is what is
24 depicted on Figure 2. This river water source is the set of
25 emergency river water pumps that serves to supply water to

1 other emergency cooling systems in the plant, namely, the
2 reactor building cooling system. And there is a connection
3 off that water supply into the emergency feedwater system,
4 so that if it is ever required, emergency feedwater can be
5 fed from the river water system.

6 Q Yes. I have forgotten what the source of power
7 for those pumps is.

8 A (WITNESS CAPODANNO) The river water pumps? They
9 are 1E-powered, emergency powered pumps, and again, they
10 start on a safety features actuation signal. So, they could
11 be available and diesel-powered.

12 Q I see. They come straight off the diesel supply,
13 the diesel generators?

14 A (WITNESS CAPODANNO) Yes.

15 Q Okay.

16 A (WITNESS CAPODANNO) In order to get feed of
17 emergency feedwater from the river water source, there are
18 two valves on Figure 2 labeled EFV 4 and 5. These valves
19 have to be opened. They are motor operated valves, but they
20 are locked closed, as indicated by the LC designation next
21 to the valve.

22 Q I see.

23 A (WITNESS CAPODANNO) So this is the situation
24 where somebody has to physically unlock the valve. There is
25 also in the way the plant procedures work that these valves

1 are racked out, which means that the power supply breakers
2 are kept normally open. That means that if you wanted to
3 run these valves on electric power, you would have to close
4 the breakers.

5 However, there are hand wheels on these valves, so
6 at the time the operator is taking the lock off the valve,
7 he is in that area next to the valve. He could also open
8 them manually. The reason they do this is simply, since it
9 is a backup source, it is undesirable to allow any
10 inadvertent actuation and put river water into the steam
11 generators. So this precaution is taken.

12 Now, as far as the changes that are being made to
13 the system, first of all, in the area of actuation, whereas
14 the motor driven pumps were not automatically actuated --

15 Q I couldn't understand.

16 A (WITNESS CAPODANNO) I am sorry. In regard to
17 actuation of the system, the motor-driven pumps, as I
18 mentioned, were not automatically actuated previously.

19 Q Yes.

20 A (WITNESS CAPODANNO) One of the changes being made
21 is to actuate the motor-driven pumps automatically also,
22 so-called auto initiation, so that the same signals, reactor
23 coolant pump loss and main feed pump loss, now start the
24 motor-driven emergency feedwater pumps also.

25 MR. TOURTELLOTTE: So it is loss of the main

1 feedwater pump that starts automatically these? Is that it?

2 WITNESS CAPODANNO: That is right. All three
3 emergency feedwater pumps will now start on loss of main
4 feedwater pumps.

5 BY DR. JORDAN: (Resuming)

6 Q Yes, and how do you detect loss of main feedwater?

7 A (WITNESS CAPODANNO) There is pressure-sensing
8 instrumentation across the main feedwater pumps. That is
9 from the suction side to the discharge side. And if that
10 senses a load differential pressure, it indicates that the
11 emergency feedwater pump is either not operating or it is
12 operating at such a low discharge pressure that it is not
13 able to produce any sufficient flow.

14 Q And then a coincidence --

15 MR. BAXTER: Excuse me, Mr. Capadanno. Did you
16 mean the main feedwater pump is operating at low pressure?
17 You were just talking about the pressure.

18 WITNESS CAPODANNO: Yes. The pressure-sensing
19 instrumentation is across the main feedwater pumps.

20 BY DR. JORDAN: (Resuming)

21 Q I see, and there is a coincidence signal there, so
22 that it takes loss of both.

23 A (WITNESS CAPODANNO) That is correct.

24 Q All right.

25 A (WITNESS CAPODANNO) And again, the other auto

1 initiation signal for emergency feedwater is loss of all
2 reactor coolant pumps, and that signal is now also used to
3 start the motor-driven emergency feedwater pumps.

4 Q I see.

5 A (WITNESS CAPODANNO) So that first change is in
6 the area of auto initiation. Another change that has been
7 made to this system is in terms of the ability to control
8 flow. That is the EFV 30A and B valves.

9 Q Right.

10 A (WITNESS CAPODANNO) As I mentioned earlier, they
11 normally control through the integrated control system.
12 With the changes that have been made to the plant and some
13 other features that have always been in the plant, these
14 valves can be operated under a number of adverse situations,
15 those situations being loss of the ICS signal. If that is
16 completely lost, there is now what is called a manual loader
17 provided in the control room so that the operator can
18 modulate these valves directly from the control room, even
19 if the integrated control room is completely unavailable.

20 A second consideration is that these valves are
21 air operated so that if for some reason the air supply was
22 lost, they could not be further moved. The existing plant
23 design includes a normal air supply from the normal
24 instrument air system in the plant. That system can be
25 powered from emergency diesels. But it is shed from the

1 diesels. It is an engineered safeguards actuation.

2 So, with the original plant design, it would then
3 require that the operator would have to reload the
4 instrument air compressors onto the diesels to continue the
5 air supply. That situation does not represent an immediate
6 loss of air, because there is an air reservoir in the
7 instrument air system, so there is a certain amount of
8 capacity built in.

9 However, you would have to initiate air
10 compressors at some time to maintain that air supply. The
11 change that was made to the plant and installed, completely
12 installed prior to the 2 accident was to put in a backup
13 air supply. This is a separate air compressor that is
14 powered from the diesel buses and remains on the diesel
15 buses regardless of whatever occurs in the plant.

16 That air supply also has a reservoir in it with
17 supplied air, whether off-site power was available or not,
18 and whether or not there was any kind of safeguards
19 actuation.

20 Another feature that has been in the plant is an
21 air receiver also tied into this air supply system to the
22 valves, the 30A and B valves, such that they would fail open
23 on loss of air. That is, this reservoir is normally kept
24 charged, and the air is not withdrawn from it. But if for
25 some reason the entire air supply was lost, there is enough

1 charge in the smaller reservoir to force the 30A and B
2 valves full open.

3 So, with the existing design that is a part of the
4 restart, we had a normal instrument air supply, that is, a
5 normal plant air supply. We had a backup air compressor
6 supply and we had a reservoir that was available to drive
7 the valves open on the loss of those to air supplies.

8 An additional feature that has been added for a
9 restart or as part of the restart effort, however, it what
10 has been termed a two-hour backup air supply.

11 Q The what? The two-hour backup?

12 A (WITNESS CAPODANNO) Yes.

13 Q Thank you.

14 A (WITNESS CAPODANNO) What that consists of is yet
15 another air supply -- actually, it is a gas supply, nitrogen
16 gas provided to the same gas quality as instrument air is,
17 that is, dried gas, very, very little moisture in it, and
18 that supply is maintained in gas bottles and through a
19 valving arrangement will come on to supply motive gas,
20 functioning exactly as instrument air does, to operate the
21 30A and B valves. That is, to allow them to be modulated
22 for a period of at least two hours.

23 Q Is this a single source air supply?

24 A (WITNESS CAPODANNO) The backup?

25 Q Yes.

1 A (WITNESS CAPODANNO) No, it is one per train.

2 Q Two tanks?

3 A (WITNESS CAPODANNO) I am not certain of the
4 number of tanks. That depends on final calculations of
5 quantities. But it is one or more nitrogen cylinders to
6 supply each side.

7 Q I see. So it would be a commercial nitrogen
8 cylinder?

9 A (WITNESS CAPODANNO) Yes.

10 Q I see.

11 A (WITNESS CAPODANNO) Now, those changes allow us
12 to have motive air to the valves and allow operation of the
13 valves, whether or not the normal integrated control system
14 is available. In addition to that, in order to give
15 operator guidance as to what to do when he is controlling
16 these valves 30A and B, additional level instrumentation is
17 being added to each steam generator, two instruments, that
18 is, redundant instruments, emergency power supply to supply
19 to each steam generator.

20 So, again, if there is an ICS or power failure,
21 these instruments are still available and those instruments
22 in conjunction with the controls, additional controls
23 available to the operator would allow him to regulate flow
24 to the steam generators and observe levels in the steam
25 generators.

1 Going back to the condensate storage tanks for a
2 moment, another feature that has been added there -- well,
3 actually, let me back up a step. Existing in this
4 condensate storage tank is level indication. Now, also
5 existing on the condensate storage tanks now is an alarm, a
6 so-called tech spec level alarm.

7 You will note that the diagram shows on the
8 condensate storage tanks and says 150,000 g., tech spec,
9 indicating that the technical specifications require at
10 least 150,000 gallons of water in those tanks. There is an
11 alarm that has always been on the tanks that indicates that
12 at some quantity of liquid above 150,000, that you are
13 encroaching on the 150,000 gallons. That is a so-called
14 tech spec alarm.

15 There is also an existing level indication on the
16 condensate storage tanks. What is being entered for restart
17 is what is termed the 20-minute alarm, and that is when the
18 tank level gets to the point that when all emergency
19 feedwater pumps are running, this alarm will indicate that
20 there is 20 minutes left to the point of exhausting the
21 capacity of the tanks.

22 Going back to the steam supply on the feed pump
23 turbine, in order to assure that we have an adequate supply
24 of steam and to minimize any potential for overspeed on the
25 feed pump turbine due to failure on the pressure feed valve,

1 MS 6, that valve is being changed. It is not physically
2 being altered, but its stroke is being limited, so that it
3 will provide adequate steam and adequate pressure, but that
4 if it should ever fail open, it will not fail open to the
5 point that it will try to supply more steam than the turbine
6 can handle without overspeeding.

7 Part of that protection is provided by these
8 relief valves labeled MSV 22A and B. So, the change to that
9 control valve and the change in the relief valve hardware
10 lowers the set points of those relief valves. So, with the
11 set points lowered, we protect to a lower pressure. We
12 still have adequate capacity to relieve the steam supply
13 that can occur on failure of MSV-6, because that valve is
14 being gagged to open only to a certain point, such that it
15 will pass no more steam than the relief valves can handle.

16 Q I see. You told me that MSV 6 was controlled by
17 the integrated control system.

18 A (WITNESS CAPODANNO) No, that is the pressure
19 control valve for the steam supply, and it is
20 self-regulating. There is a line off the semi-circular
21 indication from the top of the valve back to the steam line
22 that indicates that it senses steam line pressure and
23 regulates off of that direction.

24 Q I see. Okay.

25 A (WITNESS CAPODANNO) Another feature I might

1 mention as long as I am talking about that valve, slightly
2 to the left and down from MSV 6 is a valve labeled ASV 4.
3 That is an auxiliary steam supply that can also be used to
4 run the feed pump turbine from the plant auxiliary boilers.

5 Q I lost that one. I see USV 6, the one I just
6 asked about.

7 A (WITNESS CAPODANNO) Yes. A little bit below MSV
8 6 and to the left.

9 Q And to the left.

10 A (WITNESS CAPODANNO) Yes. It says ASV 4.

11 Q ASV 4. Yes, I see it.

12 A (WITNESS CAPODANNO) And it is labeled Aux Steam
13 Supply.

14 Q Yes.

15 A (WITNESS CAPODANNO) That is a steam supply from
16 the auxiliary boilers.

17 Q I see. Is the auxiliary boiler normally on? It
18 is oil fired, presumably.

19 A (WITNESS CAPODANNO) Yes. There are two of them,
20 oil fired. They are run during startup. They can be run to
21 test equipment. They are not always normally operating,
22 however, so obviously an initiation of this steam source is
23 dependent upon either their being operated or getting them
24 started to supply steam.

25 Q And that is part of the original system, then?

1 A (WITNESS CAPODANNO) Yes.

2 Q Okay. If the operator takes control of the level
3 in the steam generators, how does he do this? Is this
4 something he watches the meter, watches the gauge, the level
5 gauge, and turns a valve?

6 A (WITNESS CAPODANNO) Yes, there is a device called
7 a raise-lower switch. In fact, there are two of them. As I
8 mentioned in the normal ICS supply, there is also the
9 ability to take manual control of the valves via a
10 raise-lower switch.

11 Q I see.

12 A (WITNESS CAPODANNO) Part of the modification,
13 this second control that has been added that is independent
14 of ICS also has a raise-lower device in it.

15 Q So what he does is to set it for a certain rate,
16 and if that matches the steam requirements, then it stays
17 there. If he finds the level creeping up, he lowers the
18 rate?

19 A (WITNESS CAPODANNO) That's right, and the control
20 panel layout has these controls and indication adjacent to
21 one another, so that as he is modulating the control he is
22 also looking at the steam generator levels.

23 Q There is a panel in the control room for doing
24 this?

25 A (WITNESS CAPODANNO) Yes. I might also mention

1 that all of the valves in the system, all power operated
2 valves have control and position indication, so there is
3 steam generator level indication, there is this raise-lower
4 switch in the control, and there is position indication that
5 is open-closed indication, on all the valves, power operated
6 valves in the system.

7 Q I recently heard some concern about possibly
8 overfilling of steam generators. Have you thought about
9 that matter or considered it?

10 A (WITNESS CAPODANNO) Yes. In fact, I believe that
11 was raised at some point by a question on the restart
12 report, and in answer to that question, there was included
13 in the restart report an analysis by B&W on the potential
14 for overfill. I believe it is a conservative analysis, and
15 the results of that analysis show that there is a period of
16 about ten to 17 minutes before overfill would occur, and
17 that given those, at minimum, two level indicators that
18 would be available per steam generator to the operator, and
19 that he has that indication and the control --

20 Q And an alarm?

21 A (WITNESS CAPODANNO) There is also a high level
22 alarm. I believe if there was an ICS failure, I think that
23 alarm is defeated, however.

24 Q When the operator takes control and raises the
25 level to 95 percent, that is not 95 percent of completely

1 filled. Is that right? Am I wrong in saying that the
2 operator does under some circumstances take control and
3 raise the level to 95 percent?

4 A (WITNESS CAPODANNO) I believe he can. I think
5 Mr. Lanese can answer that better than I.

6 A (WITNESS LANESE) That is correct. It is not 95
7 percent of the full level of the steam generator.

8 Q So there is quite a range still to go.

9 A (WITNESS LANESE) That is right.

10 Q All right. Is that --

11 A (WITNESS CAPODANNO) Yes, I think that covers the
12 major features of the system and major changes that are
13 being made to it.

14 BY DR. LITTLE:

15 Q Mr. Capodanno, on Page 10 of your exhibit, you
16 notice that one of the component failures which could
17 contribute to system unavailability would be potential
18 plugging of the emergency feedwater pump suction strainers.
19 Are these the strainers shown in Figure 2?

20 A (WITNESS CAPODANNO) No, the strainers are shown
21 in Figure 1. If you look at each of the pump symbols, just
22 below each pump symbol is a device labeled Strainer. It
23 says Typical on the leftmost one.

24 Q Yes.

25 A (WITNESS CAPODANNO) And then there is one

1 indicated for each of the three pumps. Those strainers have
2 been removed.

3 Q What was their initial function?

4 A (WITNESS CAPODANNO) Their initial purpose is
5 so-called startup strainers, to ensure that the time the
6 fabrication of the piping systems are complete and what
7 systems are started up, and there may be debris such as slag
8 or scale or anything else in the system.

9 Strainers like this are typically installed to
10 catch that debris and protect the pumps. The pumps might be
11 run, the strainers removed and replaced several times to
12 ensure that any debris is collected and removed from the
13 system. Subsequent to that, once you are sure there is
14 nothing left in the system from the construction effort that
15 would be objectionable, the strainers can be removed.

16 Q So their removal is not going to have any adverse
17 effect?

18 A (WITNESS CAPODANNO) That is correct. It will not
19 have an adverse effect once they are removed.

20 Q They are removed because they are no longer
21 necessary.

22 A (WITNESS CAPODANNO) That is correct.

23 Q All right.

24 DR. JORDAN: One more thing. You do refer in your
25 reference to a report, Auxiliary Feedwater Systems

1 Reliability Analysis, BAW 1584. Has this been made into an
2 exhibit? I would like to see a copy of that report.

3 MR. BAXTER: Fine. We will provide you with one.

4 DR. JORDAN: Mr. Pollard or Ms. Weiss, do you have
5 questions now on explaining the operation of the system? If
6 you have, now would be a good time, and then go to your
7 regular cross.

8 CROSS EXAMINATION BY UCS

9 BY MR. POLLARD:

10 Q The only question I have, is it correct that
11 Figure 1 on your exhibit is equivalent -- the equivalent
12 information is shown on Figures 302-081 and 302-011 in
13 Section 9 of the restart report?

14 A (WITNESS CAPODANNO) The information regarding
15 steam supply to the feed pump turbine is shown on Drawing
16 302-011. I am sorry. What was the other reference?

17 Q 302-081.

18 A (WITNESS CAPODANNO) Again, yes, that is correct.
19 For the emergency feedwater portion, information is shown on
20 Drawing 081.

21 MR. POLLARD: Dr. Jordan, the other thing I would
22 like to have them explain before we start is, on 302-081 is
23 a portion of the system that is used for cooling of the
24 pumps or cooling of the bearings and so on. I think that
25 would also be helpful if he could explain how the pumps are

1 cooled.

2 DR. JORDAN: Very well. Let us get that drawing.

3 (Pause.)

4 MR. POLLARD: Also, for the record, could we note
5 that the drawing we are referring to is 302-011, and it is
6 labeled Revision 22, and 302-081 is labeled Revision 17.

7 WITNESS CAPODANNO: Did you want me to describe
8 the cooling system now?

9 MS. WEISS: Yes.

10 WITNESS CAPODANNO: On the Drawing 081, in the top
11 right corner, there is a schematic labeled Emergency
12 Feedwater Pump Bearing Cooling. These pumps are
13 self-cooled. That means that the discharge water from the
14 pump itself is used to cool the pump bearings, and what this
15 diagram is indicating is, from the three pump symbols, those
16 circular symbols at the bottom coming off of there indicated
17 from the discharge of the pump a water supply that is fed to
18 the pump bearings, and the same applies to each of the three
19 pumps.

20 After passing through the bearing housing to cool
21 the bearings, this water is returned ultimately to the
22 condensate storage tanks.

23 BY MR. POLLARD: (Resuming)

24 Q On your Figure 1 in your exhibit, coming out the
25 discharge on each pump is shown what appears to be a small

1 open and a half inch or two inch recirculation line. Is
2 this also for cooling the pumps, and is that different from
3 what you just explained on 302-081?

4 A (WITNESS CAPODANNO) Yes. This schematic in the
5 upper right of Drawing 081 shows a particular water supply
6 to pump bearings. The thing shown in our figure which also
7 appears on the lower left of Drawing 081 is the pump
8 recirculation or minimum flow line, and it is correct, that
9 is provided to assure minimum flow through the main body of
10 the pump to provide cooling, so that you would not have an
11 isolated flow and result in overheating.

12 MR. POLLARD: I have no further questions on
13 general explanation of the system.

14 CHAIRMAN SMITH: Okay. You can proceed with your
15 cross examination then.

16 BY MR. POLLARD: (Resuming)

17 Q As we have done with other witnesses where we had
18 joint testimony, if we could have the author of the
19 testimony answer first, and then if someone else cares to
20 add, that would be fine.

21 Of course, the first section is a dual
22 authorship. I don't know who the principal author is.

23 A (WITNESS CAPODANNO) I am sorry. Are you
24 referring to one of the responses to a particular question?

25 Q Yes. I am sorry. I am going to go through your

1 testimony in order. The first question, Board Question 6A,
2 has two authors identified.

3 I think the first thing I would like to start with
4 concerns pursuing our discussion of last evening. I would
5 like to know what your definition is of safety grade.

6 A (WITNESS LANESE) I think in the most general
7 terms a safety grade is one that is designed to
8 reliably function for a particular safety function that it
9 has to perform. And that would include qualification with
10 respect to the environmental consequences of an event. It
11 would include reliable power source. It would include
12 appropriate quality assurance and quality control and the
13 manufacture, installation of the system.

14 If appropriate, separation of the system, physical
15 and electrical separation, would be included in that as
16 well, and perhaps a more general answer is that it has to
17 meet the appropriate general design criteria that would
18 apply for the event in which it needs to function.

19 Q Then as a basis for judging whether or not the
20 system can reliably perform its function, the test would be
21 whether or not it meets the appropriate general design
22 criteria. Is that correct?

23 A (WITNESS LANESE) Yes, that is correct.

24 Q And it would also perhaps involve meeting 50.55A,
25 which incorporates the requirements of IEEE Standard 279?

1 A (WITNESS LANESE) I would have to see 50.55A again
2 to answer that question.

3 Q Well, you can read it if you wish. All it says is
4 that protection systems must meet IEEE 279. I know Mr.
5 Baxter doesn't like -- The question is not that complicated.

6 MR. BAXTER: The regulation has an implementation
7 section to it.

8 WITNESS LANESE: That is what I was referring to,
9 the implementation.

10 BY MR. POLLARD: (Resuming)

11 Q It is specifically 50.55A, Codes and Standards (H).

12 A (WITNESS CAPODANNO) Are you looking at the same
13 page we are? Can you reference the page where it appears?

14 Q Not when you have my book, I can't.

15 MR. BAXTER: It is around Page 350.

16 CHAIRMAN SMITH: Don't confuse 55A and 55(A).

17 Page 345.

18 MR. BAXTER: 351.

19 MS. WEISS: It is Page 351.

20 WITNESS LANESE: I think I have it.

21 CHAIRMAN SMITH: What is it on 351 that we are
22 going to be talking about?

23 MR. POLLARD: In the righthand column there is a
24 paragraph labeled (Protection Systems).

25 WITNESS LANESE: I guess I would have two comments

1 about that. The first is that the definition of a
2 protection function is fairly specific, and in my
3 understanding represents reactor protection system and
4 engineered safeguards.

5 So, from that point of view it may not apply. As
6 far as the implementation, it says the applicable version of
7 279 in effect at the time of the docketing of the
8 construction permit, so it may not also apply for TMI 1
9 under those conditions.

10 On the other hand, we generally compare ourselves
11 to the requirements of 279. I think when I talked about
12 redundancy and diversity and separation I was referencing
13 the general type guidance that you would expect a safety
14 related system to be.

15 BY MR. POLLARD: (Resuming)

16 Q We, of course, have another contention which is
17 going to get into this applicability or not. All I am
18 asking for the time being is, within your written direct
19 testimony, on Board Question 6, when you use the phrase
20 "safety grade," and if the equipment you are talking about
21 when you use the phrase "safety grade" includes equipment
22 within your definition of "protection system," does that
23 then mean in your direct testimony that it also meets the
24 requirements of IEEE 279?

25 A (WITNESS LANESE) I still have the problem of

1 "protection system" in that I think it implies engineered
2 safeguards. Putting that aside, I would expect that we meet
3 279 with respect to redundancy sources of power supply,
4 diversity, timeliness of initiation.

5 Q Are there some requirements of 279 then that you
6 may not meet when you use the term "safety grade?"

7 A (WITNESS LANESE) I cannot remember all the
8 requirements of 279, which is why I just wouldn't say on a
9 blanket basis we meet it. I think we meet the intent.

10 Q I guess we will just have to wait until we get to
11 something specific.

12 A (WITNESS LANESE) Fine.

13 Q Within your definition of the phrase "safety
14 grade," will the emergency feedwater be safety grade prior
15 to restart?

16 A (WITNESS LANESE) With respect to loss of
17 feedwater transients, with respect to small break LOCA
18 mitigation, yes.

19 Q Does that mean, then, there are some accidents for
20 which emergency feedwater would not be safety grade?

21 A (WITNESS LANESE) Prior to restart, I think that
22 is correct. I think that is what we have identified in the
23 attachment to Exhibit 15 when we addressed the general
24 design criteria.

25 Q Now, for the loss of feedwater transient in the

1 small break LOCA accidents, when you say, "Emergency
2 feedwater will be safety grade prior to restart," do you
3 include in that statement the instrumentation and controls
4 for emergency feedwater meet IEEE Standard 279?

5 A (WITNESS LANESE) I think the answer is yes, with
6 the understanding that for small break LOCA, the operator
7 may take manual control, recognizing that there is ICS
8 control of the feedwater regulating valves. Should there be
9 a failure of that signal, he would take control.

10 A (WITNESS CAPODANNO) I might add that the
11 components are being supplied for the modifications I
12 described earlier for restart, that is, to provide
13 independence from the integrated control system, are
14 basically safety grade components.

15 Q When you say "basically safety grade" --

16 A (WITNESS CAPODANNO) There are some transmitters
17 which to my understanding of the qualification requirements
18 to industry codes and standards may not at this time be
19 met. I think I am referring particularly to IEEE 323, where
20 my understanding is to date no equipment manufacturer has
21 been able to fully meet that standard, and GPU and other
22 utilities are engaged in a qualification program on
23 equipment right now.

24 The equipment being supplied is otherwise
25 qualified, and as a result of that qualification program,

1 the hardware we are procuring will either be qualified or we
2 will know in conjunction with the manufacturers how to
3 modify it to make it qualified in all respects.

4 Q When you mention IEEE Standard 323, which version
5 are you referring to?

6 A (WITNESS CAPODANNO) I am really not certain. I
7 am referring, however, in particular to the aging
8 requirements, the actual date or the addition date. I am
9 not certain of that.

10 Q All right. Then in your testimony, in your
11 written testimony, there is a sentence that states, "The
12 emergency feedwater system will not be fully safety grade
13 before the restart of TMI 1."

14 A (WITNESS LANESE) Again, that is not fully safety
15 grade with respect to other events as identified in the
16 attachment to the Exhibit 15.

17 A (WITNESS CAPODANNO) I think the point here that
18 is identified in the attachment is that there was an I&E
19 Bulletin 79-01B regarding qualification of electrical
20 equipment. That has been and is being addressed, and all
21 the results are not in on that. Consequently, in our
22 attachment to our exhibit, we have identified that condition.

23 Q Mr. Lanese, when you say it will not be fully
24 safety grade for the events identified in the exhibit, could
25 you please tell me which events you are referring to in the

1 exhibit?

2 I am referring to licensee Exhibit 15, if that is
3 what you are referring to.

4 A (WITNESS LANESE) In general, it would be high
5 energy line breaks in the intermediate building.

6 DR. JORDAN: High energy line breaks where?

7 WITNESS LANESE: In the intermediate building.

8 And I think also if you look at the note on GDC 2, it
9 indicates that a seismic event still has to be investigated
10 further for the system.

11 BY MR. POLLARD: (Resuming)

12 Q Just to save time, could you tell me what section
13 that is in the exhibit?

14 A (WITNESS CAPODANNO) It is Table 1, which is
15 attached to Exhibit 15. It is Page 1 of 5 of that table.

16 A (WITNESS LANESE) It is right after the Figure 2.

17 Q Thank you.

18 Are there any other events other than those listed
19 in that table for which the system will not be safety grade
20 prior to restart?

21 A (WITNESS LANESE) No.

22 DR. JORDAN: For my information, is there a
23 general design criteria that is applied specifically to
24 emergency feedwater systems? I notice GDC 34 applies to
25 residual heat removal. But is that only the low pressure

1 heat removal system? Is that your understanding?

2 WITNESS CAPODANNO: I don't believe any of the
3 GDC's, at least for fluid systems, are written with specific
4 identification of systems in mind. The term "residual heat
5 removal" is referring to removing post-shutdown heat.

6 Because the criteria have to be expansive enough
7 to cover those PWR and BWR designs, I think the idea of
8 establishing criteria rather than specific systems
9 identification is what is intended.

10 DR. JORDAN: I see. Well, of course, immediately
11 after shutdown, the only means of removing residual heat is
12 through the heat exchangers and the emergency feedwater
13 system, normally. So, I guess I concluded that therefore
14 the GDC 24 applied.

15 WITNESS CAPODANNO: Well again, since it is
16 establishing a broad-based criteria for nuclear power
17 plants, in the case of B&W systems residual heat removal is
18 done by what they term the decay heat removal system. That
19 is a long-term cooling system that is distinct from
20 emergency feedwater.

21 DR. JORDAN: Well, I guess the main thing in GDC
22 34 that catches my eye is, assuming a single failure
23 criteria, and I gather from your saying the system meets
24 IEEE 279 that it meets the single failure criteria also.

25 WITNESS CAPODANNO: Yes, it does meet single

1 failure criteria.

2 WITNESS LANESE: Two comments, please, Dr.
3 Jordan. I don't think we said we met 279. I think we said
4 that we normally compared ourselves to it. I don't think we
5 are prepared to make the statement without having reviewed
6 it again.

7 DR. JORDAN: Yes, I remember, now. That is fine.
8 Thank you.

9 WITNESS LANESE: The other comment is that
10 normally after reactor trip you do not depend on emergency
11 feedwater to remove heat.

12 DR. JORDAN: How is that? I didn't hear.

13 WITNESS LANESE: After reactor trip, the emergency
14 feedwater system is not the normal source of removing heat
15 from the reactor. It is main feedwater through the startup
16 control valves. And that is a differentiation between an
17 auxiliary feedwater system and an emergency feedwater system.

18 DR. JORDAN: Yes. Oh --

19 WITNESS LANESE: An auxiliary feedwater system
20 would be used under normal conditions to remove heat either
21 during startup or possibly after reactor trip. Ours is
22 indeed an emergency feedwater system, in that it would only
23 be used if the normal sources of feedwater were not
24 available.

25 DR. JORDAN: All right. I guess there has been a

1 fair amount of confusion to this point in the hearing, and I
2 thought the only difference was, the staff used one set of
3 terms and licensee another. But by auxiliary feedwater
4 system, then, in your case, you are referring to the main
5 feedwater system --

6 WITNESS CAPODANNO: Dr. Jordan, if I may, there
7 is, I think --possibly historically there was a very
8 definite distinction made. As an example, combustion
9 engineering PWR plants make use of a feedwater system which
10 we call emergency and they have termed auxiliary.

11 DR. JORDAN: I see.

12 WITNESS CAPODANNO: In those plants, that system
13 is used to supply feedwater for startup and shutdown.

14 DR. JORDAN: Yes.

15 WITNESS CAPODANNO: And I believe historically the
16 term "auxiliary feedwater" was used. B&W designs, our
17 emergency feedwater system functions only when the normal
18 feedwater system is unavailable.

19 DR. JORDAN: I see. Startup and shutdown, you use
20 the main feedwater system.

21 WITNESS CAPODANNO: That is correct, and over a
22 period of time the terms "auxiliary" and "emergency" have
23 been mixed. As an example, in the reliability report that
24 you made reference to earlier, one of the very early
25 introductory comments in that report says that the term

1 "auxiliary feedwater" will be used for B&W plants where
2 traditionally that has been referred to as emergency
3 feedwater.

4 At this point, the terms are used interchangeably.

5 MR. BAXTER: Dr. Jordan, I think we established
6 that with Mr. Jones in his testimony introducing the B&W
7 analysis. He used the two terms interchangeably.

8 DR. JORDAN: Yes, I remember that he did, but this
9 triggered my interest, that in this case there might be or
10 have been at one time a difference. That is fine. Thank
11 you. Go ahead.

12 BY MR. POLLARD: (Resuming)

13 Q Prior to the changes that you made to the
14 emergency feedwater system which you described to Dr. Jordan
15 earlier, was the emergency feedwater system safety grade, or
16 has it become safety grade as a result of the changes?

17 A (WITNESS LANESE) I believe previously it would be
18 considered important to safety, and as a result of lessons
19 learned, I suppose, in other B&W LOCA analysis, it would be
20 considered safety grade in the future.

21 Q I will have to ask the question again, having read
22 that. Prior to making the changes, was the emergency
23 feedwater system safety grade?

24 A (WITNESS LANESE) Our interpretation of the system
25 was that it was important to safety.

1 Q It was not therefore safety in the present sense?

2 A (WITNESS LANESE) That is correct.

3 Q Would you agree that if there were an accident
4 with loss of main feedwater, and total loss of emergency
5 feedwater, that you would be unable to meet the requirements
6 of 50.46 without using bleed and feed?

7 A (WITNESS LANESE) I don't think 50.46 is
8 applicable. As a criterion, because we are talking about a
9 multiple failure situation. 50.46 does not address that
10 situation.

11 Q Let's assume that we have lost main feedwater, and
12 assume that we have no emergency feedwater. Can the reactor
13 core be adequately cooled following an accident such as a
14 small break LOCA without using bleed and feed?

15 A (WITNESS LANESE) I think the answer that we gave
16 in response to 6A still stands, that you would require feed
17 and bleed to cool the reactor core, again, with the
18 understanding that that total loss of main and emergency
19 feedwater isn't a design basis.

20 Q Would you agree that it would be a design basis
21 accident if emergency feedwater was not safety grade?

22 A (WITNESS LANESE) No, I think I would not
23 necessarily.

24 Q Can you explain why not, please?

25 A (WITNESS LANESE) I think if it were not important

1 to safety and not classified as important to safety, I would
2 agree, but not safety grade. Safety grade is a more narrow
3 description of the function of the clearance of the system.

4 Q I think it is going to be important, then, for you
5 to explain to me the difference between the phrases which
6 you used, "safety grade" and "important to safety," that is,
7 to explain very specifically which requirements are not met
8 if a system in your words is classed as important to safety,
9 which would have to be met if the system were classified
10 safety grade.

11 A (WITNESS LANESE) I think current regulations,
12 current Reg. Guides, applicable versions of IEEE 279 would
13 apply to the safety grade system. Important to safety
14 implies the more general applicability of the general design
15 criteria, and I think there is more latitude interpretation
16 of what they mean.

17 Q What I would like you to do is to tell me
18 specifically which regulations, which regulatory guides,
19 which provisions of IEEE 279 would not have to be met if a
20 system was important to safety, but would have to be met if
21 it was going to have to be safety grade.

22 DR. JORDAN: I am a little puzzled by the
23 question, in that the witness has not said, if I remember
24 right, that the system was one that was important to
25 safety. I think he said that the emergency feedwater system

1 was safety grade. So, what is the import of the question?

2 MS. WEISS: Maybe we need to clarify that. The
3 original question which started this line was, would you
4 agree prior to the accident that emergency feedwater was not
5 safety grade? And he finally agreed.

6 The next question was -- assuming -- and then we
7 talked about bleed and feed -- would a loss of all feedwater
8 be a design basis accident if emergency feedwater were not
9 safety grade? And that is the question which I think -- and
10 the response was, the witness came back and made a
11 distinction between "important to safety" and "safety grade"
12 with respect to the answer to that question.

13 Maybe we should ask him to repeat that, and start
14 the line of questioning again.

15 WITNESS LANESE: If the system did not have a
16 Class 1E power source, if it did not have the safety grade
17 initiating signals that it now has, if it did not have the
18 quality assurance and quality control that it has had, if it
19 did not have the surveillance requirements on the system,
20 then I would say that you would have to consider it not
21 being available, and that it would be a design basis event.

22 I think the bottom line is that it is designed to
23 be suitably reliable and to have enough safety designed into
24 the system that it does not require the postulation of a
25 different design basis event.

1 BY MS. WEISS:

2 Q Let me ask you a couple of questions. You came in
3 yesterday and at the beginning of your testimony you
4 expressed your agreement with the staff's definition of
5 safety grade as defined in Mr. Conran's testimony in UCS
6 Contention 4 -- 14, excuse me. Was that the definition of
7 safety grade that you used at the time you wrote your direct
8 testimony?

9 A (WITNESS CAPODANNO) If I may, first of all, I
10 don't think we said we agreed with it in its entirety. We
11 used it as a basis. Secondly, we did not have that
12 available to us at the time we wrote the testimony. But we
13 felt that it provides documentation of some of the bases
14 that we had come to independently.

15 Q Okay. Now, let me ask you this. What was your
16 definition of the term "safety grade" which you used in your
17 testimony at the time you wrote that testimony? What
18 definition were you using?

19 A (WITNESS LANESE) I would like to clarify one
20 thing first. I was not aware of Mr. Conran's definition of
21 "safety grade" prior to writing the testimony.

22 Q We understand that. I want to know what your
23 definition was at the time you wrote your testimony.

24 MR. BAXTER: I believe Mr. Lanese testified
25 earlier this morning what his definition of "safety grade"

1 is. I heard him go through a description of the features of
2 such a system. He didn't quote Mr. Conran's testimony. He
3 referenced it. I think the question is repetitive.

4 MS. WEISS: If so, I did not understand the
5 distinction. I think it needs to be very clear.

6 DR. JORDAN: I thought also that he had answered.

7 CHAIRMAN SMITH: Well, as a courtesy to Ms. Weiss,
8 it can be done again.

9 WITNESS LANESE: I think "important to safety" is
10 a general term that describes the requirement of a system --

11 BY MS. WEISS: (Resuming)

12 Q Mr. Lanese, I asked you the definition of the term
13 "safety grade" at the time you wrote your testimony.

14 A (WITNESS LANESE) That is right. That is what I
15 am getting at.

16 Q Okay.

17 A (WITNESS LANESE) So, "important to safety" is the
18 more general term. I would interpret a safety-grade system
19 as one that meets the current regulatory requirements for a
20 safety grade system, applicable Reg. Guides, applicable IEEE
21 standards.

22 Q And that is the definition you used in your
23 testimony?

24 A (WITNESS LANESE) When I said it was not fully
25 safety grade for some events, that is right. I think I

1 really mean that we have a system that is important to
2 safety.

3 Q Do you use the term "system important to safety"
4 in your direct testimony?

5 A (WITNESS LANESE) No, I use "safety related."

6 Q That is a distinction that does not appear in your
7 direct testimony. Is that correct?

8 A (WITNESS LANESE) That is correct.

9 Q Did you talk to your lawyers after your testimony
10 was written and after you saw Mr. Conran's testimony and
11 arrived at this distinction between "important to safety"
12 and "safety grade" equipment?

13 A (WITNESS CAPODANNO) No. In fact, in early August
14 there was an in-house GPU document that was authored by our
15 engineering department and QA departments that gave very
16 much the definition that Mr. Lanese has described regarding
17 "important to safety" and what we are calling "safety
18 grade," and that was the basis which we started from in
19 preparing this testimony.

20 Q Let me ask you then why that distinction doesn't
21 appear in this testimony.

22 A (WITNESS CAPODANNO) The distinction between
23 "important to safety" and the subset of it?

24 Q The distinction between "important to safety" and
25 "safety grade."

1 A (WITNESS LANESE) At the time we were writing the
2 testimony, I don't think we thought the distinction was
3 important.

4 Q But you now do think the distinction is important?

5 A (WITNESS LANESE) Since you have raised the issue
6 in this context, yes, in defining the difference.

7 Q What made you think the distinction was
8 important? Was that from discussions with your attorneys?

9 A (WITNESS LANESE) No.

10 MR. BAXTER: I object to the questioning, Mr.
11 Chairman. I think the witness raised the question of
12 "important to safety" as an aid in answering the questions
13 on what "safety grade" means. He evidently feels it is
14 helpful to explain what he means by that term. So, I don't
15 know what mysterious --

16 CHAIRMAN SMITH: Well, this is for the witnesses
17 and not for counsel to explain. It is traditional cross
18 examination, and she has a right to it.

19 MR. BAXTER: She has a right to probe
20 conversations between counsel the witness?

21 CHAIRMAN SMITH: Absolutley. Well, that is not a
22 blank check, but if she is going to try to establish that a
23 definition was changed for the convenience of the
24 litigation, that is appropriate.

25 WITNESS LANESE: Counsel made me aware that Mr.

1 Conran had written a definition of "safety related" and
2 "important to safety," and "safety grade." I read it for
3 the first time last night. It verifies my understanding of
4 what I had always considered a system that was safety grade,
5 a system that was important to safety.

6 MR. POLLARD: Let's try and go back to where we
7 were, and let me see if I understand where we were.

8 BY MR. POLLARD: (Resuming)

9 Q Is it correct that your testimony is, before you
10 made the changes that you just described this morning which
11 will be in place prior to restart, that the emergency
12 feedwater system was not safety grade?

13 A (WITNESS LANESE) Yes.

14 Q And did I also understand you correctly that
15 assuming the emergency feedwater system is not a safety
16 grade system, the total loss of feedwater would be a design
17 basis accident for the plant?

18 A (WITNESS LANESE) No, that is still not what I was
19 trying to say. While I agree that it was in certain
20 respects not safety grade, it meets those applicable general
21 design criteria for the loss of feedwater events and for the
22 small break LOCA events in which the systems would
23 potentially be required.

24 DR. JORDAN: You are speaking now of the systems
25 redesigned for restart?

1 WITNESS LANESE: That is correct.

2 DR. JORDAN: That wasn't quite your question, was
3 it?

4 MR. POLLARD: No, that was not my question.

5 BY MR. POLLARD: (Resuming)

6 Q Prior to the changes, you have just testified the
7 system was not safety grade.

8 A (WITNESS LANESE) Correct.

9 Q My next question is, before the changes with
10 emergency feedwater system not safety grade, wasn't it true
11 that a design basis accident under those circumstances would
12 be total loss of main feedwater and emergency feedwater?

13 A (WITNESS LANESE) No. Again, because it was
14 always considered a system important to safety, it had a
15 suitable degree of reliability, and while I agree that you
16 might have to consider a temporary loss of emergency
17 feedwater, there would not be a sustained loss of emergency
18 feedwater.

19 Therefore, it would not be a design basis for the
20 plant.

21 DR. JORDAN: In that connection, I believe you do
22 say later in your testimony that the changes made have not
23 greatly influenced or increased the reliability of the
24 system. Am I correct in my memory?

25 WITNESS CAPODANNO: That is correct. What we have

1 addressed in that response, since you have raised it, is the
2 fact that we are looking at, among other things, the
3 requirements of the restart order with the specific
4 statement to the effect of the increased timelines of the
5 system.

6 We feel that the changes we have made to in fact
7 increase the timeliness of the response of the system do
8 increase the ability of the system to withstand certain
9 failures. When you get into reliability issues themselves,
10 I think that is something that would take a bit longer
11 discussion, and you might care to address that later, or now.

12 But our feeling was --

13 DR. JORDAN: I don't want to go into the
14 reliability now, but I do want to mention, I presume counsel
15 did tell you -- you weren't here some couple of weeks ago,
16 when I said that partly with respect to my Question 6, I was
17 concerned whether loss of feedwater should be a design basis
18 event, and in that respect, I was concerned as to whether
19 the reliability, even though it met the general design
20 criteria and met the single failure criteria, whether that
21 was adequate to still classify it as a design basis event.

22 So you see that the questions are aimed very much
23 at what is on my mind, and I don't know whether you knew
24 that or not. But I thought you had not really addressed 6K
25 -- misunderstood what I had in mind.

1 WITNESS CAPODANNO: Your concerns were
2 subsequently relayed to us.

3 DR. JORDAN: Fine.

4 BY MR. POLLARD: (Resuming)

5 Q I would like to try one more question if I could.
6 We will make it hypothetical, so I can make it very
7 specific, and if you could just give me a yes or no and then
8 explain, let me assume we have a plant in which the main
9 feedwater system and the emergency feedwater system are not
10 capable of withstanding even an operating basis earthquake,
11 much less a safe shutdown earthquake.

12 Would you agree that in such a plant, total loss
13 of main feedwater and emergency feedwater would be a design
14 basis event or design basis accident?

15 A (WITNESS LANESE) Yes, I would.

16 (Pause.)

17 Q I am reading now the first paragraph on Page 2 of
18 your testimony. I am sorry. That is a continuation of the
19 paragraph on Page 1. Could you clarify that paragraph a
20 little bit for me, to distinguish between what the operator
21 has to do versus what is automatic? It appears to be, you
22 first say he might have to do it manually, but then you say
23 it will be done automatically. It is somewhat confusing.

24 A (WITNESS LANESE) There are two automatic
25 initiation signals for emergency feedwater. One is the loss

1 of all four reactor coolant pumps. The second is a complete
2 loss of main feedwater. What I was trying to say is that
3 there could be two situations, assuming reactor coolant
4 pumps continue to run through this event, then the only
5 automatic initiation signal would be from the loss of main
6 feedwater.

7 So, really, there were several conditions. If
8 main feedwater was running, we would expect to be putting in
9 water to the steam generators, anyway. And if it was not,
10 then you would expect auto initiation of emergency
11 feedwater.

12 Even if that were not to occur, the operator would
13 still be able to take manual action to initiate emergency
14 feedwater.

15 BY MR. POLLARD: (Resuming)

16 Q You would agree that in order for the emergency
17 feedwater system to perform its safety function, more is
18 needed than just initiation, that you also have to have
19 proper control of the regulator valves. Is that correct?

20 A (WITNESS LANESE) Ultimately, you need to be able
21 to control flow to the steam generators.

22 Q And at present those regulator valves in their
23 normal mode are controlled by the ICS.

24 A (WITNESS LANESE) That is right, with the
25 capability to independently manually control flow.

1 Q And the ICS is not safety grade. Is that correct?

2 A (WITNESS LANESE) That is correct.

3 Q Is it important to safety within your meaning?

4 A (WITNESS LANESE) No, it is not.

5 Q So, then, in a sense, the emergency feedwater
6 system is only safety grade when you disconnect the normal
7 control from it and substitute the operator?

8 A (WITNESS LANESE) Safety grade. That is correct.

9 Q Maybe I had better ask the other question then.
10 What about, it is only important to safety within your
11 meaning if you also disconnect the normal control and
12 substitute the operator?

13 A (WITNESS LANESE) Yes, that is correct also.

14 Q In the next paragraph of your testimony, you talk
15 about an event which occurred at Oconee. Please describe
16 briefly for me what happened at Oconee?

17 A (WITNESS CAPODANNO) My understanding is that
18 there was an ICS failure at Oconee which resulted from the
19 failure of a device called a static transfer switch to make
20 a transfer from the normal ICS power supply to a regulated
21 power supply. And that as a consequence of that there was
22 some interruption of power to the ICS system.

23 Q What happened as a result of that?

24 A (WITNESS CAPODANNO) I am only generally aware of
25 what consequences might occur. I don't believe I could give

1 you a detailed description of the results. As I understand
2 it, however, some operator action was taken to restore the
3 power. The exact conditions and changes in condition that
4 the plant went through, I could not recite those to you.

5 Q The Board question was, is loss of emergency
6 feedwater following a main feedwater transient accident, an
7 accident which must be protected against with safety grade
8 equipment, would such accident be caused or aggravated by a
9 loss of non-nuclear instrumentation such as occurred at
10 Oconee?

11 Now, if you have not gone back and examined what
12 the consequences were of the power supply failure at Oconee,
13 how can you answer the Board's question?

14 A (WITNESS LANESE) We have looked at our ICS, and
15 there is no failure mechanism in our ICS that will cause a
16 loss of normal and emergency feedwater. In the same
17 context, with respect to LOCA, the ICS failure would not
18 prevent additional water to at least one steam generator,
19 that is, partially as a result of the change in the failure
20 modes to the 30 valves.

21 Q Did you examine the integrated control system for
22 these type failure modes before the Oconee incident occurred
23 or after?

24 A (WITNESS CAPODANNO) I think there was an overlap
25 in time frame, since the restart effort engineering-wise has

1 been going on since the second quarter of 1979 to the
2 present, and I am not certain of the date of the Oconee
3 incident, but I believe it fell within that time frame.

4 Consequently, we were looking at the emergency
5 feedwater system and postulated failures. We didn't
6 specifically address the type of component failure that
7 occurred at Oconee for initial evaluation. What we did was
8 make the assumption that ICS failed. That is to say,
9 whether a relay or a switch or some other device might have
10 caused that failure, we didn't consider that, because we
11 felt the more logical thing to do was to look at the end
12 result, which would be a failure of ICS, and we addressed
13 failures of ICS.

14 Q When did the Oconee incident occur?

15 A (WITNESS CAPODANNO) As I said, I am really not
16 certain of the date. My recollection is, it fell in that
17 time frame I just described.

18 Q Well, if it wasn't the Oconee incident that caused
19 you go to back and examine ICS, what was the motivation?

20 A (WITNESS CAPODANNO) Well, going back even prior
21 to the TMI 2 accident, GPU Met Ed had been investigating and
22 making changes, some of which I described earlier, which
23 were installed in the plant for the emergency feedwater
24 system.

25 Subsequently, in response to the TMI 2 accident,

1 and in response to the restart order, both the NRC and
2 ourselves raised issues regarding emergency feedwater. We
3 made some proposals to the NRC for changes. They raised
4 others. That collective effort resulted in a list of
5 modifications to be made.

6 So, in addition to the earlier efforts which
7 preceded the TMI 2 accident, we also were investigating
8 other changes to the system subsequent to the accident. As
9 I mentioned earlier, part of that overall effort was to
10 investigate the results of ICS failures.

11 Q Now, in your testimony, you say this review of the
12 integrated control system is a preliminary review. Is that
13 still your testimony?

14 A (WITNESS CAPODANNO) I think the correct way to
15 characterize it at this point is, it is an ongoing review.
16 There has been some review done by others, that is to say,
17 not myself, other engineering sections.

18 Q At this point --

19 MR. BAXTER: Were you finished with your answer,
20 Mr. Capadanno?

21 WITNESS CAPODANNO: No, I was not.

22 So that from the time we wrote the testimony until
23 now, further work has been done, and still further work is
24 planned.

25 BY MR. POLLARD: (Resuming)

1 Q If further work is still planned in this review,
2 do you have any basis now for believing that the ongoing
3 review will not discover any other adverse interactions?



4 A (WITNESS CAPODANNO) My understanding is, to date,
5 depending upon the situation that you postulated occurring
6 as a failure within ICS, the failure will either have no
7 impact at all or will have a relative impact in that it
8 won't suddenly result in a loss of feedwater or loss of
9 emergency feedwater.

10 It does cause some devices to change position,
11 such as valves. Valves under some conditions fail half-open.


12 DR. JORDAN: I don't want to shut off any
13 questions on this, but I do believe there is a portion of
14 the hearing that will be involved with the failure mode and
15 analysis of the ICS system, which will include, presumably,
16 its effect on the emergency feedwater. Am I right in this?

17 MR. BAXTER: There is a particular contention,
18 from Mr. Sholly on this submission required by the
19 Commission's order on the failure modes and the effect of
20 ICS analysis.



21 DR. JORDAN: All right. I guess while we are at
22 that point, however, in the questioning by Mr. Pollard, a
23 failure of the non-nuclear instrumentation system results in
24 a failure of the integrated control system. Is that correct
25 or not? And I am asking for information entirely.





**IMAGE EVALUATION
TEST TARGET (MT-3)**




MICROCOPY RESOLUTION TEST CHART







**IMAGE EVALUATION
TEST TARGET (MT-3)**



MICROCOPY RESOLUTION TEST CHART



1 WITNESS CAPODANNO: My understanding is this, that
2 at least from the standpoint of power supply, ICS/NNI
3 receives the same power supply. So, I am aware to that
4 extent that if that is the failure postulated, you lose
5 power to both ICS and NNI.

6 DR. JORDAN: The ICS is powered by the non-nuclear
7 instrumentation?

8 WITNESS CAPODANNO: Well, they are distinct
9 systems in the sense that ICS is an integrated control for
10 flow of feedwater reactor power. Non-nuclear
11 instrumentation is controlling other plant systems. I
12 cannot give you a real detailed definition of the
13 distinction. My comment was in reference to the electrical
14 power supplied to that control system.

15 DR. JORDAN: Where does the ICS get its power? Is
16 that off the Class 1E system?

17 WITNESS CAPODANNO: No, not directly. It is
18 through a network that is battery-backed. That is, it cuts
19 a DC power supply that is converted to AC, and as I
20 mentioned a little bit earlier, there is also a transfer,
21 an automatic transfer that occurs if there is any loss of
22 that battery power to a regulated AC power supply.

23 DR. JORDAN: Similar to some of the
24 instrumentation that must be safety grade in the control
25 room, isn't some of that instrumentation also powered from

1 the DC batteries by means of converters?

2 WITNESS CAPODANNO: Yes. I believe it is, yes.

3 BY MR. POLLARD: (Resuming)

4 Q Is it correct the way the system is presently --
5 Let me try again.

6 Is it true the way the system will be designed at
7 the time of restart that a failure either in or affecting
8 the integrated control system could result in total loss of
9 feedwater for some period of time?

10 A (WITNESS CAPODANNO) No, that is not correct.

11 Q Can a failure in the integrated control system
12 result in a failure of flow to at least one steam generator?

13 A (WITNESS CAPODANNO) No.

14 Q If you would look, please, at your Figure 1 in the
15 exhibit, as I understood your testimony, Valves EFV 30A and
16 30B were controlled by the integrated control systems. Is
17 that correct?

18 A (WITNESS CAPODANNO) Yes. Under normal operation,
19 that is correct.

20 Q Now, with a failure in the integrated control
21 system, isn't it possible that that failure could close EFV
22 30-A?

23 A No, my understanding is that either the failure
24 leave the valve alone, that is, it doesn't cause it to
25 change position, or will result in the valve failing to a

1 half-open position.

2 Q Loss of electrical power, as I understand it,
3 causes the valve to fail to the half-open position. In
4 evaluating electrical circuits, though, you must also not
5 only consider loss of power; is it not correct that you also
6 need to consider short-circuit failure of individual
7 electronic components?

8 A (WITNESS CAPODANNO) I think that would be
9 accurate.

10 Q Are you familiar enough with the design and the
11 electronics in the integrated control system to be able to
12 say that you are sure that no electrical failure of any type
13 within the ICS could not result in the ICS sending a signal
14 to close EFV 30A?

15 A (WITNESS CAPODANNO) No, I am not. I don't
16 believe I intended to say that.

17 Q All right. Let me try my original question again
18 then. Is it possible for a single failure in the integrated
19 control system to result in closure of EFV 30A?

20 A (WITNESS CAPODANNO) My response, and I will
21 repeat it again, is, to my knowledge I was addressing, first
22 of all, power failures. That is the thing I am aware of.
23 Beyond that, in the context of the additional components in
24 the system that you described, I really do not know the
25 answer.

1 Q Does anybody on the panel know the answer?

2 A (WITNESS LANESE) No.

3 A (WITNESS TORCIVIA) (Nods negatively.)

4 Q It would seem to me that surely there must be some
5 false signals getting crossed up that would result in the
6 integrated control system thinking there is too much water
7 going into the steam generator, and taking the wrong
8 action. I can't conceive of a piece of equipment that
9 doesn't do that.

10 A (WITNESS CAPODANNO) I don't exclude the
11 possibility. I just simply can't testify that I have
12 accurate knowledge if that would occur or through what
13 mechanism it would occur.

14 DR. JORDAN: Wouldn't it be a reasonable
15 assumption for the moment to assume that it might occur?

16 MR. POLLARD: That is how I was going to phrase my
17 question next.

18 DR. JORDAN: Could you give him that?

19 MR. POLLARD: Well, I am really surprised actually
20 that --

21 DR. JORDAN: I think it would be reasonable for
22 you to make that assumption. If it is wrong, it will be
23 corrected, but let's assume for the moment that is the case.

24 MR. POLLARD: As you pointed out, we are going to
25 have other panels here later to talk about this.

1 DR. JORDAN: Yes, there will be a session on the
2 failure of the integrated control system and the possible
3 effects of that, and I believe there has been a review of
4 that system by the Oak Ridge National Laboratory, and this
5 is one of the exhibits that we have received from staff or
6 licensee. Is that correct?

7 MR. BAXTER: Yes. The staff has provided as a
8 reference both the B&W -- the integrated control system
9 modes as it affects analysis and the Oak Ridge National Lab
10 review, and this comes under one of Mr. Sholly's contentions.

11 DR. JORDAN: Good.

12 MR. POLLARD: What I would like to do is, if we
13 could take a break now, we were going to try and find some
14 of this information.

15 MS. WEISS: See if we can find the diagrams so we
16 can nail down the answer to this question one way or another.

17 MR. POLLARD: If we could have a break now, it
18 would be convenient.

19 CHAIRMAN SMITH: All right. Let's take our
20 midmorning break of 15 minutes.

21 However, before Mr. Toutellotte and Mr. Trowbridge
22 leave, when we were discussing the emergency planning
23 meeting this morning, I neglected to inquire as to whether
24 you recommend that the Board issue an order requiring the
25 intervenors in the emergency planning contentions to

1 participate, or if you feel it is unnecessary, having been
2 in touch with each of those people.

3 We would also like to know if a representative of
4 FEMA is planning to attend.

5 MR. TOURTELLOTTE: Yes, a representative from FEMA
6 will be here, and I think it is a good idea to have the
7 order simply because if someone changes their mind between
8 now and then and decides not to show up, I think it would be
9 detrimental to the overall hearing. I think it would be
10 good for the parties to all understand the importance of
11 being there and participating

12 So, I would recommend the issuance of the order.
13 Also, we didn't arrive at any particular time, so whatever
14 the Board could do in suggesting a time --

15 CHAIRMAN SMITH: How about 1:00 p.m., the 24th?

16 MR. TOURTELLOTTE: Yes, that is fine.

17 CHAIRMAN SMITH: This is the time selected by the
18 Board to be a time that normally would be occupied by any
19 intervenor in hearing time in any event.

20 Would it be possible -- I will try to get that
21 order out this afternoon when I return to the office in
22 Bethesda, but it would be possible for somebody on you staff
23 to advise those affected intervenors that the Board will be
24 issuing an order for participation at that time?

25 MR. TOURTELLOTTE: Yes, Mr. Chairman. If you will

1 notify -- if you could notify Mr. Gray as to the exact time
2 when that order issues, he will take it from there and
3 notify the other intervenors.

4 CHAIRMAN SMITH: Okay.

5 All right, we will break until 20 minutes to 11:00.

6 (Whereupon, a brief recess was taken.)

7 MS. WEISS: We were not able to find a diagram of
8 the integrated control system in the time available, and I
9 don't think that one is in the restart report. If it is
10 still necessary to ask these specific questions, we will try
11 to find one over the weekend.

12 BY MR. POLLARD: (Resuming)

13 A Mr. Capadanno, referring to your testimony in
14 response to Board Question Number 6-B, on Page 3, you state
15 that "The extent to which other safety grade and non-safety
16 grade systems' failures can affect this function has been
17 evaluated." Then you say, "Included within this evaluation
18 have been the electrical power supplies, non-nuclear
19 instrumentation."

20 Then, on Page 4, in the middle paragraph, you
21 state that "As indicated in the accompanying exhibit, TMI 1
22 Emergency Feedwater System, the emergency feedwater system
23 can operate and meet its design function with loss of
24 instrument air, loss of AC power, and loss of non-nuclear
25 instrumentation."

1 Do I understand those parts of your testimony to
2 mean that in evaluating the failure modes of particularly
3 the ICS, the only failure mode you really looked at was loss
4 of power?

5 A (WITNESS CAPODANNO) I think not entirely. We
6 took the approach that ICS and its ability therefore to
7 control had been lost for whatever reason. The comment then
8 addresses the fact that there is additional control, i.e.,
9 the manual loaders that I mentioned earlier, that will allow
10 us to continue to operate the emergency feedwater system so
11 that we are indeed independent of the effects of an ICS
12 failure.

13 If the ICS did not stroke a valve, the operator
14 has the ability through the modification, that is, the
15 addition of this manual loader, to operate that valve.

16 Q You did not specifically try to determine, then,
17 whether the integrated control system in a failure could
18 cause the regulator valves to go full open or to go full
19 closed?

20 A (WITNESS CAPODANNO) Again, in looking at ICS as a
21 system that fails, we did not -- I did not go through and
22 try and determine whether the valve would fail full open,
23 partially open, or partially closed.

24 My understanding, as I mentioned earlier, is,
25 certain ICS failures have no effect on valve position.

1 Others result in valves failing half open, and in the
2 context of this written testimony we therefore say that
3 either given the inability of ICS to do anything, that is,
4 to either cause a valve to open or close, or in the
5 situation where the ICS failure might result in a valve
6 going partially open, we have independent control available
7 to allow the operator to drive that valve further open or
8 further closed as required.

9 Q So I understand the answer to my question to be,
10 you did not look at the ICS to determine whether failures in
11 its circuitry could cause the control valve to go closed or
12 to go full open?

13 A (WITNESS CAPODANNO) That is correct. We, as I
14 said, took a specific condition, ICS failure, without
15 getting into specific subsets of that condition.

16 DR. JORDAN: Can you say that there is manual
17 override of the ICS signal?

18 A (WITNESS CAPODANNO) Yes. In fact, from my
19 particular familiarity with power failures on ICS, you can
20 have a normal power failure. The system will transfer to a
21 backup power supply. The operator has the ability to
22 control from that.

23 If for any reason you choose to postulate that
24 that fails, then you are into the modification that I
25 described, the so-called manual loaders, which is the

1 restart modification, so that again in the context of what
2 we read here, what we intended to say was that ICS was
3 assumed to fail without getting into whether a wire or a
4 relay or some other device caused that failure, and that
5 given that failure occurring in any of its possible modes, we
6 have the ability to still maintain control of the system.

7 Q During the break, I re-reviewed the panel's
8 qualifications, and I notice that Mr. Torcivia has a
9 bachelor of science degree in electrical engineering. I
10 would like to ask you, Mr. Torcivia, did you in preparing
11 this testimony evaluate the design of the integrated control
12 system at all?

13 A (WITNESS TORCIVIA) No, sir.

14 Q Have you ever evaluated the integrated control
15 system?

16 A (WITNESS TORCIVIA) No, sir. My expertise
17 involves the power involved in controlling -- the power
18 involved in controlling the equipment and not necessarily
19 the instrumentation or the integrated control circuits
20 themselves.

21 CHAIRMAN SMITH: I am sorry. What was your
22 expertise, sir?

23 WITNESS TORCIVIA: That involved in the power
24 which feeds various devices and controls, but not
25 necessarily the control itself, such as integrated control

1 circuits or instrumentation.

2 CHAIRMAN SMITH: Were you here on that loss of
3 power question, that last question?

4 WITNESS TORCIVIA: That is correct.

5 BY MR. POLLARD: (Resuming)

6 Q I notice from your qualifications you say you have
7 extensive experience in process control and instrumentation
8 for industrial plants. On the basis of your experience, in
9 the types of instruments and controls used for processes
10 where we are measuring things such as steam flow and feed
11 flow and steam generator level and trying to have an
12 instrument which then controls the position of a regulator
13 valve, in your experience, would you consider it a usual
14 situation that a failure in such a control system could in
15 fact signal such a regulatory valve to go full-closed or
16 full open, depending on the failure?

17 A (WITNESS TORCIVIA) Let me first preface that by
18 indicating that within my position at General Public
19 Utilities, I do not involve myself in process controlled
20 equipment or anything of that nature, although my expertise
21 in the past has been somewhat involved in process controlled
22 equipment.

23 Therefore, in answering this question, it does not
24 imply that it does apply to this particular ICS system or to
25 this particular circuitry.

1 If I understand your question correctly, you are
2 indicating that a failure of the ICS system or any control
3 which is associated with a motor operated valve, that the
4 valve can fall in place wherever the failure happens to
5 develop.

6 Is that correct?

7 Q Yes, I think so.

8 A (WITNESS TORCIVIA) There is one possible
9 exception in that at times there are sealing circuits
10 developed which will, once the circuitry is initiated, it
11 will continue to operate it so long as the power is there,
12 regardless of what external effect other control circuits
13 may have on it. And that may be possible.

14 CHAIRMAN SMITH: Before you go on, Mr. Torcivia,
15 apparently, your expertise is a power supply engineer,
16 basically.

17 WITNESS TORCIVIA: The power which is involved in
18 supplying electrical equipment such as motors, transformers,
19 lighting, and things of that nature.

20 CHAIRMAN SMITH: And we have already observed that
21 the Board's reference to the St. Lucy decision, which was a
22 station blackout question, was misunderstood. I think it
23 may be possible, and we will open it for discussion, to
24 excuse Mr. Torcivia from appearing if he is not on any other
25 question, which it doesn't appear that he is, because this

1 testimony does not in the slightest address the Board's
2 concern.

3 So, we would be open to suggestions that he not be
4 required to appear here next week. Of course, he is quite
5 welcome, but he probably would not have been here if the
6 Board's question had been understood the way we intended it.

7 MR. BAXTER: I appreciate the suggestion, Mr.
8 Chairman. I do think, even if it is not directly
9 responsive, that the information Mr. Torcivia has supplied
10 on Pages 13 and 14 of the testimony on the reliability of
11 off-site power supplies is at least indirectly helpful and
12 relevant to other issues before the Board.

13 I would appreciate it, and it would be very much
14 appreciated, I am sure, by Mr. Torcivia, if to the extent
15 that UCS or the Board has questions on that limited section
16 of the testimony, if it wouldn't be too disruptive, to ask
17 those this morning, and Mr. Torcivia would not have to come
18 back next week. That would be very much appreciated.

19 MR. POLLARD: We have no questions on Mr.
20 Torcivia's testimony at all.

21 CHAIRMAN SMITH: We would not have required
22 anybody to produce this information in response to Board 6K.

23

24

25

1 MR. BAXTER: All I am indicating is that I would
2 like to keep the testimony in the record, and if the Board
3 has questions, we would welcome them today.

4 DR. JORDAN: I don't see, a quick glance, and I
5 didn't mark any previously -- so that I think it would be,
6 so far as I am concerned, he could be excused, and if he is
7 not needed by the panel for any of the other questions, I
8 think we could do that, and UCS -- well, let's see, how
9 about the other, either the staff or the state?

10 CHAIRMAN SMITH: Do you have any questions?

11 MR. ROBERT ADLER: No, we had no questions for Mr.
12 Torcivia.

13 CHAIRMAN SMITH: Mr. Cutchin, would you object to
14 excusing Mr. Torcivia, or do you have any questions?

15 MR. CUTCHIN: I have no questions of him, sir, and
16 would have no objection to his being excused.

17 MR. BAXTER: Thank you, Mr. Torcivia. You are
18 excused.

19 MS. WEISS: I wonder if he could just sit here
20 until we get finished with this line, and then leave. Mr.
21 Pollard is about to hypothesize a situation. He might be
22 able to help.

23 CHAIRMAN SMITH: Well, the understanding is that
24 he doesn't have to return next week, so whatever he can
25 contribute today.

1 DR. JORDAN: Let's keep him here today.

2 WITNESS TORCIVIA: Thank you.

3 BY MR. POLLARD: (Resuming)

4 Q I have forgotten whether it was Mr. Caopdanno or
5 Mr. Lanese, but am I correct that at least one of you said
6 that the emergency feedwater system will be safety grade at
7 the time of restart for loss of feedwater transients and
8 small break LOCAs, is that correct?

9 A (WITNESS LANESE) That is correct.

10 Q And as I understand your exhibit, although I am
11 not sure it is yet covered this morning, is it correct that
12 if there is a leak in one steam generator, that the way the
13 emergency feedwater system is designed, it will
14 automatically terminate flow. emergency feedwater flow to
15 that steam generator?

16 A (WITNESS LANESE) That is correct. That is the
17 steam line rupture detection system, and pressure would have
18 to go below 600 pounds in the generator.

19 DR. JORDAN: It is not a leak necessarily. It is
20 a loss in pressure, is that right? If the leak produced a
21 loss in pressure with sufficient magnitude to result in a
22 loss of pressure, then the feedwater would be switched.

23 WITNESS LANESE: That's right.

24 DR. JORDAN: All right.

25 BY MR. POLLARD: (Resuming)

1 Q And that type of an accident is within design
2 basis for the plant, is that correct?

3 A (WITNESS LANESE) That is correct.

4 Q Under such a situation, then, if the emergency
5 feedwater system was automatically actuated, it would either
6 right away or sometime later be attempting to deliver
7 feedwater only to one steam generator.

8 A (WITNESS LANESE) That is true.

9 Q In this situation, assuming that there is an
10 electrical fault within the integrated control system which
11 could cause the feed regulator valve for that steam
12 generator which is still receiving water to go closed, would
13 you agree, then, that a single failure in the ICS would
14 result in no feedwater being delivered to either steam
15 generator?

16 A (WITNESS LANESE) I cannot address the single
17 failure of the ICS.

18 Q That was my assumption, that a failure in the ICS
19 would cause feed regulator valves to go closed.

20 A (WITNESS LANESE) There would at least be an
21 interruption of emergency feedwater. The steam line rupture
22 detection signal resets when steam generator pressure goes
23 back above 600 pounds, so you do not necessarily lose
24 emergency feedwater to the initially depressurized generator
25 continuously.

1 Q But for some time period.

2 A (WITNESS LANESE) Yes, for some time period you
3 could.

4 Q Turning now, Mr. Capodanno, to your testimony on
5 Question 6B, in the first paragraph, the sentence I have
6 already read, you refer to an evaluation which was done to
7 determine what other safety grade and non-safety grade
8 systems failures could affect emergency feedwater.

9 Who did this evaluation?

10 A (WITNESS CAPODANNO) It was a joint effort on the
11 part of several engineering sections to review different
12 systems.

13 Q Several engineering sections of what?

14 A (WITNESS CAPODANNO) I am going to make sure I
15 understand you.

16 Are you referring to the paragraph on page 4 with
17 regard to other systems that support or could affect
18 emergency feedwater?

19 Q No, I'm sorry, I should have directed you to the
20 first paragraph in your answer on page 3.

21 A (WITNESS CAPODANNO) The first paragraph on page 3.

22 Q In response to Question 6B.

23 A (WITNESS CAPODANNO) Yes.

24 Q The sentence states, the extent to which other
25 safety grade and non-safety grade systems failures can

1 affect this function has been evaluated.

2 My question is, who did this evaluation?

3 A (WITNESS CAPODANNO) Again, the same answer.

4 Q Well, I didn't understand you. Can you be more
5 specific as to who did the evaluation?

6 A (WITNESS CAPODANNO) Well, within our engineering
7 section, as is I think typical --

8 DR. JORDAN: This is GPU.

9 WITNESS CAPODANNO: Yes, sir. There are
10 engineering groups for mechanical engineering, electrical
11 engineering, instrumentation and control engineering, where
12 systems that we looked at can be involved. Those sections
13 were consulted.

14 BY MR. POLLARD: (Resuming)

15 Q Were you personally involved in this evaluation?

16 A (WITNESS CAPODANNO) To some extent, yes.

17 Q To what extent?

18 A (WITNESS CAPODANNO) Well, as we mention later on
19 on page 5, there was review of certain mechanical systems
20 for --

21 Q Excuse me. Did you say page 5?

22 A (WITNESS CAPODANNO) I'm sorry, page 4.

23 MS. WEISS: Please keep your voice up. It is hard
24 to hear you.

25 WITNESS CAPODANNO: In the second paragraph on

1 page 4, we make mention of systems such as instrument air,
2 we talk about the ability of the pumps to be cooled. I
3 believe -- yes, those, reference to cooling, lubricant and
4 instrument air, those are the ones I had some direct
5 involvement in.

6 BY MR. POLLARD: (Resuming)

7 Q And when was this evaluation done?

8 A (WITNESS CAPODANNO) In preparing the testimony,
9 my part was -- I looked at what existed in the plant
10 systems, and that was my evaluation, to see what the other
11 systems that are referred to there would or would not do.
12 So this was done in September, I believe, of this year.

13 Q With respect to the second paragraph on page 3 in
14 your answer to Board Question 6B, you list electrical power
15 supplies, non-nuclear instrumentation, instrument air
16 supply, and heating and ventilation systems.

17 A (WITNESS CAPODANNO) Uh-huh.

18 Q Which of those listed components are non-safety
19 grade?

20 A (WITNESS CAPODANNO) The instrument air supply
21 itself is nonsafety grade, and we have established in the
22 context of non-nuclear instrumentation, ICS NNI was what we
23 were referring to there.

24 Q I'm sorry, again I couldn't hear your answer.

25 A (WITNESS CAPODANNO) In regard to the term

1 non-nuclear instrumentation, that encompasses what we have
2 discussed previously, the integrated control system, NNI.

3 Q And that is non-safety grade?

4 A (WITNESS CAPODANNO) I'm sorry?

5 Q That's non-safety grade?

6 A (WITNESS CAPODANNO) Yes.

7 And secondly I mentioned the instrument air supply
8 as being a non-safety grade system.

9 Q What about electrical power supplies?

10 A (WITNESS CAPODANNO) In regard to the emergency
11 feedwater system, those are Class 1E systems.

12 Q What about heating and ventilation systems for the
13 areas within the plant where emergency feedwater components
14 are located?

15 A (WITNESS CAPODANNO) Those are also safety systems.

16 Q At the top of page 4 of your testimony, the
17 sentence starts, "Single active failures."

18 Could you please define for me what you mean by
19 the term "active failure"?

20 A (WITNESS CAPODANNO) This statement addresses the
21 HVAC system, and I was addressing active failures of
22 components such as pumps, valves, things that have to change
23 position in order to achieve whatever the function should
24 be, open or closed, start or stop.

25 Q Are the heating and ventilation systems powered

1 from a diesel generator?

2 A (WITNESS CAPODANNO) Yes, I believe they are.

3 Q Are they redundant?

4 A (WITNESS CAPODANNO) Yes, the cooling in that area
5 has separate coils and is redundant.

6 Q By in that area you mean all plant locations where
7 equipment from the emergency feedwater system is located?

8 A (WITNESS CAPODANNO) Yes, that is in the
9 intermediate building.

10 DR. JORDAN: Which building?

11 WITNESS CAPODANNO: Intermediate building.

12 BY MR. POLLARD: (Resuming)

13 Q And continuing in that paragraph you have a
14 sentence which states, "Under conditions of loss of all AC
15 power, the environmental temperature limits for the turbine
16 driven emergency feedwater components will not be exceeded
17 for a period of eight hours.

18 Is the eight hours a design requirement, or does
19 that just happen to be what they can withstand?

20 A (WITNESS CAPODANNO) Well, the statement is a
21 periods of over eight hours.

22 Q Excuse me.

23 A (WITNESS CAPODANNO) And it is based on an
24 evaluation of the heat input to the building on the
25 assumption that there is no heat removal from the building.

1 Q Let me ask the question a different way. Was it
2 necessary to demonstrate that the components' temperature
3 limits would not be exceeded for a period of over eight
4 hours?

5 A (WITNESS CAPODANNO) No. The eight hours is not
6 of significance from that standpoint. What it represents
7 simply is that if you add a certain number of Btus to a
8 given volume, you will achieve some temperature after a
9 certain time. In this case it happens to be eight hours.

10 Q And then the next sentence states, "Under these
11 same conditions, the motor driven pumps could not be
12 operated."

13 Why not?

14 A (WITNESS CAPODANNO) The assumption is there is no
15 AC power available, that is, no diesel power, no off-site
16 power. That is the context in which we understood that we
17 should be addressing the question.

18 DR. JORDAN: I see. The second sentence under
19 conditions of loss of all AC power, you included onsite as
20 well as off-site, so it is a station blackout.

21 WITNESS CAPODANNO: That is correct.

22 DR. JORDAN: I had not appreciated that.

23 BY MR. POLLARD: (Resuming)

24 Q Referring to the last paragraph on page 4 of your
25 testimony, where you talk about operational errors, the

1 Board had asked in what respect is the emergency feedwater
2 system vulnerable to operator errors? I would like you to
3 tell me, please, what are all the operator errors that would
4 disable the system?

5 A (WITNESS CAPODANNO) Is that question what are all
6 the errors?

7 Q What are all the operator errors that could
8 disable the emergency feedwater system?

9 A (WITNESS CAPODANNO) The errors that we are
10 referring to here include valves that could be closed, that
11 is, manual valves that might have been closed by an operator
12 that should be open for operation of the system. It could
13 include controls in the control room that might be in a
14 defeat position that should be in an operable position.

15 Q Are those all of the operator errors that could
16 disable the system?

17 A (WITNESS CAPODANNO) Yes. Again, we took this in
18 the context of things an operator could do such as having
19 valves closed, manually closed that should be open. This
20 addresses human manipulation rather than some kind of
21 automatic actuation.

22 Q Is it possible for an operator error to result in
23 disabling the circuit breakers for the motor driven pumps?

24 A (WITNESS CAPODANNO) A breaker could be racked out
25 by an operator.

1 Q And as I understood your explanation earlier, the
2 only valves which have position indication in the control
3 room are those that are power operated. Is that correct?

4 A (WITNESS CAPODANNO) Yes, I believe that is
5 correct.

6 Q So, for example, if we refer to Figure 1 in your
7 exhibit, that if the suction valves for all three emergency
8 feedwater pumps were closed, the operator would not have
9 indication of that in the control room. Is that correct?

10 A (WITNESS CAPODANNO) Are you referring to the
11 valves labeled EFV 16A?

12 Q 16B and --

13 A (WITNESS CAPODANNO) And EFV 6, I believe.

14 Q 6, yes.

15 A (WITNESS CAPODANNO) Okay. Again, are you asking
16 if they were closed, whether there would or would not be
17 control room indication?

18 Q That is correct.

19 A (WITNESS CAPODANNO) It is correct that there
20 would not be control room indication. However, as I
21 indicated, there either is completed or is in the process of
22 being completed -- I am not sure which in every instance --
23 procedures to assure proper valve line-ups, and some of that
24 information has been identified in response to NRC questions
25 in some of the supplements to the Restart Report where valve

1 sets that have to have specific positions are identified,
2 and in addition, draft technical specifications have also
3 been submitted. The intent of each of these is to assure
4 that valves such as these are maintained in their proper
5 positions.

6 Q That last paragraph on page 4 of your testimony,
7 when you say "See Licensee testimony in response to UCS
8 Contention 10 and Sholly Contention No. 3 on safety system
9 bypass and override," can you please specifically tell me
10 what part of that testimony, or page, or question?

11 A (WITNESS CAPODANNO) I would have to take a look
12 at it.

13 Q Well, please do, and please, for the next sentence
14 as well.

15 (Pause)

16 A (WITNESS CAPODANNO) I have surveyed this response
17 to UCS Contention 10 and Sholly Contention No. 3. What we
18 were responding to, or identifying, I should say, on page 4
19 is simply that there is additional information here that
20 also has bearing on operation of valves. We didn't intend
21 to imply that this particular set of testimony was a
22 detailed presentation of specific procedures or specific
23 operator actions, merely that we saw some relation between
24 what is contended and the response to it, and the emergency
25 feedwater system itself. There are some statements in here

1 about operators taking certain actions to operate valves,
2 and this particular set of testimony further addresses some
3 issues about automatic versus operator action.

4 So our point was that there is a relation between
5 the two, and I think your question was addressing perhaps
6 specifically procedures. I am not certain. But if that is
7 the intent, that is not really what we were trying to say by
8 this parenthetical reference.

9 Q So the parenthetical reference merely means there
10 is some information that is related to operator errors in
11 general and the procedures that are going to be used to
12 hopefully improve the situation.

13 A (WITNESS CAPODANNO) Yes. The Contention is
14 addressing -- I am referring now to UCS Contention 10 and
15 Sholly Contention 3 -- seems to be addressing the need for a
16 greater or lesser extent of operator actions versus
17 automatic actions.

18 Q Well, am I correct, then, with respect to the
19 Board Question 6B, which asks in what respect is the
20 emergency feedwater system vulnerable to operator errors,
21 your sole response to that consists of one sentence on page
22 4 which states, "Operational errors that might affect the
23 functioning of the emergency feedwater system have been
24 evaluated, and procedural changes have been instituted to
25 assure proper surveillance and operation of the system to

1 preclude loss of function."

2 A (WITNESS CAPODANNO) I think as a direct statement
3 in response to the question, yes. The additional
4 information given in response to the question also
5 identifies either that certain conditions that might be
6 postulated can be overcome, or refers you to the exhibit to
7 understand what conditions that could be postulated can be
8 overcome.

9 Q Well, the sentence I read to you does not refer to
10 the exhibit. Is that correct?

11 A (WITNESS CAPODANNO) That is correct.

12 Q In reviewing your professional qualifications, Mr.
13 Capodanno, could you point me to any portion of that which
14 relates to you personally having in the past been involved
15 with developing operator procedures or judging the adequacy
16 of those procedures?

17 A (WITNESS CAPODANNO) In the past I have not been
18 specifically involved in developing procedures.

19 Q What about judging the effectiveness of procedures?

20 A (WITNESS CAPODANNO) Again are we referring to
21 past employment?

22 Q Any time.

23 A (WITNESS CAPODANNO) In the past, prior to working
24 with GPU, I had no direct involvement with procedures.

25 Q Did you have any direct involvement since you

1 worked with GPU?

2 A (WITNESS CAPODANNO) Some, review of procedures to
3 provide comments.

4 Q Could you give me some estimate of what percentage
5 of your professional working time for GPU has been spent
6 reviewing operator procedures?

7 A (WITNESS CAPODANNO) The current configuration
8 function of the GPU Nuclear Group, which is the encompassing
9 organization of which I am a part, has responsibility for
10 development of procedures as well as other engineering
11 tasks. What is occurring is a transition in absorbing
12 various engineering departments from within the GPU Service
13 Corporation as well as what was formerly in Metropolitan
14 Edison Company. There is a transition going on to have
15 engineering personnel in what was the Service Company, now
16 the GPU Nuclear Group, be involved with review of
17 procedures. That has not been fully formalized, and by and
18 large, procedures are generated by others. There has been
19 one instance in regard to a special operating procedure
20 where I was involved in review of it to provide some
21 comments.

22 MS. WEISS: Mr. Chairman, would you please direct
23 the witness in the future to try to confine himself to
24 answering the question. He never did get around to
25 answering that one, and we will repeat it. If he feels he

1 needs to explain, he can explain afterwards.

2 BY MS. WEISS:

3 Q The question was, what percentage of your
4 professional working time while at GPU has been spent in
5 reviewing operator procedures?

6 A (WITNESS CAPODANNO) It is small. It would be
7 less than 1 percent.

8 BY MR. POLLARD: (Resuming)

9 Q Now, it is correct that at Unit 2 prior to the
10 accident they had procedures for operators as well, is that
11 correct?

12 A (WITNESS CAPODANNO) Yes.

13 Q And now, in preparing for restart, you have
14 developed new procedures, is that correct?

15 A (WITNESS CAPODANNO) The company has. I don't
16 think you mean me personally.

17 Q Excuse me, yes. New procedures have been
18 developed to support restart.

19 A (WITNESS CAPODANNO) Yes, or modifications of
20 existing procedures.

21 Q Was the reason new procedures were developed
22 because you found that the old procedures were inadequate?

23 A (WITNESS CAPODANNO) Again, as I said earlier, I
24 have not had enough involvement in these procedures to
25 really answer that question. I think that, however, if you

1 want an opinion, that the procedures have been expanded,
2 perhaps, in some areas to be more explicit. I don't know
3 that I can characterize them as inadequate.

4 Q But it is correct tha GPU has always had
5 procedures. This is nothing new in terms of having
6 procedures for operators.

7 A (WITNESS CAPODANNO) That is true.

8 DR. JORDAN: I don't understand. Does GPU have
9 procedures or do they have guidelines for procedures for the
10 operating companies?

11 WITNESS CAPODANNO: I am using GPU as an
12 all-encompassing term. The operating companies have
13 procedures.

14 DR. JORDAN: Okay.

15 MR. POLLARD: I'm sorry. I also, Mr. Chairman,
16 was referring to Mr. Ed, and I think I got into using GPU.

17 DR. JORDAN: I misunderstood. Good.

18 BY MR. POLLARD: (Resuming)

19 Q Moving on to your answer to the Board Question 6C,
20 Mr. Capodanno, the Board asked what has been the experience
21 in other power plants with failures of safety grade
22 emergency feedwater systems if they have such systems in
23 other power plants.

24 Am I correct that in preparing your testimony you
25 looked only at B&W plants?

1 A (WITNESS CAPODANNO) That is correct.

2 Q And do any of those B&W plants that you looked at
3 have safety grade emergency feedwater systems?

4 A (WITNESS CAPODANNO) My understanding is that the
5 Davis-Besse plant identified on page 6 of the testimony has
6 a safety grade emergency feedwater system.

7 Q You examined feedwater failures, as I understand
8 in your testimony, only up to March 28th of 1979, is that
9 correct?

10 A (WITNESS CAPODANNO) Yes.

11 Q Why didn't you go beyond that date?

12 A (WITNESS CAPODANNO) The amount of data involved
13 here, as we said in the introductory sentence, is
14 exhaustive, and in order to get some significant amount of
15 that data, we made use of the NRC's LER output. What was
16 available to us was through that date. My understanding is
17 not clear as to whether or not the remainder from March 28,
18 '79 to the present is also available, but we requested that
19 through our licensing group, and that is what was provided
20 to us.

21 Q So you didn't really ask for anything beyond March
22 28 of '79.

23 A (WITNESS CAPODANNO) We asked for the available
24 information on this computer summary. It came back
25 terminating at March 28, 1979. And as I said, I am not

1 clear as to why it does not go beyond that point.

2 Q Do you think that is just a coincidence, then,
3 that that happened to end on the day of the TMI 2 accident?

4 A (WITNESS CAPODANNO) I really don't know.

5 Q In tabulating the failures that you have in your
6 testimony, you apparently have tabulated, as I understand,
7 those failures which no emergency flow could be or could
8 have been instantaneously delivered to the steam generators.

9 Dids you discover any failures which may have
10 disabled only half of the emergency feedwater system, or one
11 train?

12 A (WITNESS CAPODANNO) I don't recall at this
13 point. I would have to re-review that computer listing to
14 answer your question.

15 Q In other words, you interpreted the Board question
16 to be only asking you about total loss of feedwater?

17 A (WITNESS CAPODANNO) We were unclear as to the
18 intent of the question. We tried to explain that you could
19 do an exhaustive review, considering the number of plants,
20 and the different designs in plants, and we really were not
21 sure how to answer the question. And so we did what we
22 thought was an answer to what was being asked.

23 A (WITNESS LANESE) Could I just add to that? These
24 were all not necessarily losses of feedwater. Some of them
25 were corrected before the system was demanded to function.

1 Q Yes, I understood that.

2 When you got your LER output in accordance with
3 your request from the NRC, did you have more LERs than you
4 have listed in your testimony?

5 A (WITNESS CAPODANNO) Yes. There are more than.

6 Q How many operating B&W plants are there?

7 A (WITNESS CAPODANNO) I believe it is on the order
8 of six.

9 Q And how many plant years of operation do those six
10 plants represent?

11 A (WITNESS CAPODANNO) I cannot answer that question.

12 Q Do you have some idea of what is the total number
13 of reactor years of experience in the United States with
14 nuclear power plants?

15 A (WITNESS CAPODANNO) Again I --

16 Q A ballpark figure. Would it be about 500 reactor
17 years of experience?

18 A (WITNESS CAPODANNO) Well, some plants have been
19 operating since the '60s. Some have come on line in the
20 '70s. You know, I really don't know if I play with the
21 arithmetic what that would come out. It might be on the
22 order of 60 plants times 10 years, it might be on a number
23 like you have suggested.

24 CHAIRMAN SMITH: You are talking interchangeably,
25 plants and reactors.

1 MR. POLLARD: Yes. I also have the tendency to
2 use plants and reactors interchangeably. I will try to be
3 more specific.

4 BY MR. POLLARD: (Resuming)

5 Q Do you think that in finding five events where no
6 emergency feedwater flow could have been instantaneously
7 delivered to the steam generators might be significant if
8 the number of reactor years of experience represented by
9 those B&W plants is relatively small, and by that I mean
10 perhaps 100 reactor years?

11 A (WITNESS CAPODANNO) I think in order to answer
12 that you have to look at when some of these events occurred,
13 and my understanding is that some of these events occurred
14 before the plants actually were operational. It occurred up
15 in the startup and test phase.

16 Q Do you have any idea of the statistical
17 significance of the number of emergency feedwater failures
18 which you reported in your testimony?

19 A (WITNESS CAPODANNO) No.

20 Q Do you agree that four out of the five which you
21 report in your testimony were due to operator error?

22 A (WITNESS CAPODANNO) Yes.

23 Q And so would you agree that with respect to those
24 failure modes that you reported in your testimony, operator
25 error was the dominant failure mode?

1 A (WITNESS CAPODANNO) For those identified, yes.

2 Q Do you have an opinion as to whether changing a
3 system from non-safety grade to safety grade would have a
4 significant impact on the rate of operator errors?

5 A (WITNESS CAPODANNO) I believe it may very well
6 decrease the number of operator errors. I think one of the
7 instances cited here concerns a design that has a single
8 bearing cooling water system to the pumps. By contrast, the
9 TMI 1 system has independent cooling. So if you were to
10 postulate an error of, say, an operator misaligning cooling
11 valves on a system that was designed as either important to
12 safety or even safety grade if it were being built today --

13 Q Which event are you referring to?

14 A (WITNESS CAPODANNO) Pardon me?

15 Q Which event are you referring to?

16 A (WITNESS CAPODANNO) It is the second one under
17 Davis-Besse. It says personnel error in line-up of bearing
18 cooling water.

19 Q What from that event description leads you to
20 conclude that the bearing cooling water system was not
21 redundant?

22 A (WITNESS CAPODANNO) I have seen other
23 documentation which I cannot recall specifically which said
24 that was not the case.

25 Q I thought you told me earlier that Davis-Besse was

1 the only plant that had an emergency feedwater system.

2 A (WITNESS CAPODANNO) That is my understanding, but
3 by the same token, I am not the designer, nor do I have
4 detailed knowledge of it. Consequently, from other
5 documentation I have read, it has been identified as a
6 safety grade emergency feedwater system.

7 Q Would you agree that if it had only a single
8 bearing cooling water system, that it could not possibly
9 have been safety grade?

10 A (WITNESS CAPODANNO) I think under the definition
11 we have given for redundancy, separation, etc., yes.

12 MR. POLLARD: The Board will note that we have a
13 typing error in our cross examination plan referring to the
14 staff's testimony.

15 BY MR. POLLARD: (Resuming)

16 Q In response to the Board's Question 6I of the
17 staff -- you didn't look for it, 6I, the question was "Will
18 the reliability of the emergency feedwater system be greatly
19 improved upon conversion to safety grade, and is it the
20 Licensee's and staff's position that the improvement is
21 enough such that the feed and bleed backup is not required?"

22 MR. BAXTER: Do you have a copy of that testimony,
23 Mr. Capodanno?

24 WITNESS CAPODANNO: The NRC Staff testimony?

25 MR. BAXTER: Yes.

1 WITNESS CAPODANNO: Yes, I found it.

2 BY MR. POLLARD: (Resuming)

3 Q I'm sorry, I have already directed you to the
4 wrong place. Let me direct you to the right place.

5 If you have the staff's testimony, you can turn to
6 page 11, and the paragraph labeled F reads, "Based on the
7 emergency feedwater system design and the modifications to
8 be implemented as described in the TMI 1 Restart SER,
9 NUREG-0680, we believe that further additional hardware
10 changes will not significantly improve emergency feedwater
11 reliability. The common cause failure mode, as a result of
12 operator error, still remains as the dominant source of
13 system unreliability. This failure mode is being further
14 minimized with improvements in the human factors aspects of
15 the plant, i.e., improved operating and emergency
16 procedures, improvements in instrumentation, and continuous
17 operator training."

18 My question is do you agree with the staff that
19 the common cause failure mode as a result of operator error
20 still remains as the dominant source of system unreliability?

21 A (WITNESS CAPODANNO) No, I don't.

22 Q What do you think the dominant failure mode is?

23 A (WITNESS CAPODANNO) I am not quite sure what you
24 mean by dominant. Since reliability is introduced, are you
25 talking about a specific type of reliability with numerical

1 values generated and so on?

2 Q Are you generally familiar with reliability
3 analyses?

4 (WITNESS CAPODANNO) No, but the term gets used in
5 several contexts. If it is being used specifically as a
6 reliability analysis, I understand what a reliability
7 analysis is. In a more general sense, the word can also be
8 used, and I am not quite sure how you are phrasing your
9 question.

10 Q Could you please read that sentence in the staff's
11 testimony, and as that sentence reads, are you saying you
12 don't understand what they mean by the dominant source of
13 system unreliability?

14 A (WITNESS CAPODANNO) My interpretation would be
15 that they have evaluated that against some other condition
16 that might affect system operation. What I am trying to get
17 straight is whether or not this context of your question
18 implies that the staff ran a reliability analysis and from
19 that they have made this statement.

20 Q Well, then, we will define what we mean by
21 reliability. Let's assume that reliability means the
22 probability that the emergency feedwater system will be
23 unable to carry out its function for loss of feedwater
24 transients and small break loss of coolant accidents, that
25 is, the probability that it will fail to do those functions.

1 What do you think will be the principal
2 contributor to the probability that the system will be
3 unable to perform that function?

4 A (WITNESS CAPODANNO) At this point it would more
5 likely be the case of a component problem of some type.

6 CHAIRMAN SMITH: Would you repeat that, please?

7 WITNESS CAPODANNO: I said I believe it would be a
8 component problem of some type.

9 BY MR. POLLARD: (Resuming)

10 Q Can you give me some examples?

11 A (WITNESS CAPODANNO) Some information I have
12 reviewed in the past makes reference to such things as
13 valves that didn't operate or valves that were improperly
14 manufactured. I believe that at this point, with the
15 changes in the system design and changes in the system
16 procedures, that it may be a more likely occurrence of a
17 component giving some problem with the emergency feedwater
18 system.

19 Q Can I refer just briefly, please, to Figure 1 of
20 your exhibit?

21 Am I correct that in the long term, after restart,
22 that you intend to modify further the emergency feedwater
23 system such that there will be parallel valves installed
24 where it is now shown to be EFV 30A and EFV 30B?

25 A (WITNESS CAPODANNO) That is the intent, yes.

1 Q Would that be a type of component failure that
2 would be present at restart that would not be present in the
3 eventual long term that is concerning you about this
4 reliability or that you identify as the principal
5 contributor to its unreliability?

6 A (WITNESS CAPODANNO) Yes. In the long term, the
7 addition of those valves is to provide further ability of
8 the system to withstand a component failure.

9 CHAIRMAN SMITH: I don't believe that he answered
10 the question, nor do I believe that the question was an
11 appropriate one to begin with. However, because the
12 question assumed the premise that he had a concern about
13 component failure, but that is not what has been his
14 testimony.

15 MR. POLLARD: That is why I tried to rephrase it,
16 that the component failure was the principal contributor.

17 CHAIRMAN SMITH: Right, but your ultimate question
18 premised a concern of this witness of component failure.

19 MR. POLLARD: That is the part I think the
20 transcript will show that I rephrased.

21 CHAIRMAN SMITH: I understand. All right, I did
22 not quite pick up the second clause as rephrasing the first
23 clause.

24 DR. JORDAN: I have a question on the answer.
25 Is the modification going to be to add another

1 valve in parallel with the present EFV 30 A and EFV 30B, or
2 will it be to have a different operator on the valve?

3 WITNESS CAPODANNO: The valves will be added in
4 parallel to the existing valves.

5 DR. JORDAN: That means that if those valves were
6 to fail open, the operator would have no control.

7 WITNESS CAPODANNO: No. In addition to the valve
8 in parallel with the 30 valves, there would be a set of
9 block valves also in parallel. There is a figure in the
10 supplement to the Restart Report that shows that in more
11 detail.

12 DR. JORDAN: Very well.

13 WITNESS LANESE: I think we may need some
14 additional clarification on the reasons for putting the
15 valves in also, and what we mean by improving the
16 reliability of the system by making it safety grade. I
17 think the predominant deficiencies in the system now with
18 respect to high energy line breaks in the intermediate
19 building, and the primary purpose for putting those valves
20 in is for these other events. It is again not primarily
21 because of LOCA, because of feedwater events.

22 In addition, the use of cavitating venturis in the
23 system in the long term puts some different requirements on
24 the system. So I think when we are talking about improving
25 the availability of the system after an event, we are

1 talking about the improvement of the availability primarily
2 because of the high energy line breaks.

3 DR. JORDAN: Because of what?

4 WITNESS LANESE: The high energy line breaks, a
5 feed line break accident specifically. And also we need to
6 qualify that equipment for the steam line break environment
7 in the intermediate building.

8 DR. JORDAN: Okay, I'll come back to that. I
9 guess I didn't quite understand it, but go ahead. I don't
10 want to take your time now.

11 BY MR. POLLARD: (Resuming)

12 Q On page 6 of your testimony, the paragraph
13 immediately preceding Board Question 6G states that the
14 Licensee has committed to perform functional testing of the
15 emergency feedwater system at TMI 1 prior to restart, and to
16 demonstrate the adequate operability of the system to meet
17 its design function.

18 Could you please describe for me this functional
19 testing?

20 A (WITNESS CAPODANNC) There are identified in the
21 Restart Report commitments to do a flow test on the
22 emergency feedwater pumps, to establish flow to the steam
23 generators. I believe there are also commitments to test
24 the initiation logic, that is, the automatic actuation for
25 emergency feedwater, and to test valving.

1 Q When you say test the valving, what does that
2 involve?

3 A (WITNESS CAPODANNO) On the EFV 30A and B valves.

4 Q And specifically what kind of test?

5 A (WITNESS CAPODANNO) I believe there is a
6 commitment for testing those valves as to operability.

7 Q In what respect operability, just simply to see if
8 they will open or close?

9 A (WITNESS CAPODANNO) Yes, and they are also going
10 to be used during the flow test to regulate the flow to the
11 steam generators.

12 A (WITNESS LANESE) That system will also have a
13 start-up test that will include initiation of emergency
14 feedwater, introduction of emergency feedwater into the
15 generator, and a test to show that it will control level at
16 the required set point for a loss of offsite power, and a
17 demonstration that natural circulation will be maintained in
18 the system. So it is really a -- it should be a mock-up of,
19 say, a loss of offsite power, possibly a reactor trip and
20 then a loss of offsite power. We are still working on the
21 details of that test. But ultimately we will take the
22 system through its full requirements to establish natural
23 circulation flow by means of emergency feedwater.

24 Q These tests that you described, Mr. Lanese, did
25 you call those startup tests?

1 A (WITNESS LANESE) Yes.

2 Q Well, either the functional testing that Mr.
3 Capodanno talks about in his testimony or the startup tests,
4 are they going to test the loss of non-nuclear
5 instrumentation power supplies and the operator transferring
6 to the manual control?

7 A (WITNESS LANESE) Not as a part of these tests,
8 but I cannot address if that is going to be performed in
9 another startup test. I am only aware of the startup test
10 with respect to emergency feedwater at this point.

11 Q Isn't that part of the emergency feedwater?

12 A (WITNESS LANESE) This test will not assume
13 failures of the NNI ICS. Whether other tests will be
14 initiated by losing NNI ICS I'm not sure at this point.

15 Q Well, let me just ask a general point. Is it Met
16 Ed's intention prior to restart to test every aspect of the
17 emergency feedwater system which is talked about in your
18 testimony in this proceeding as necessary for a restart?

19 A (WITNESS LANESE) I think we are going to test
20 those aspects of the system that we feel requires a
21 demonstrated availability or operability.

22 Q So you think you would, even though you don't know
23 the exact test, as a matter of position by Met Ed, you would
24 in fact have a test that would involve loss of power to the
25 non-nuclear instrumentation and see if the operator can

1 transfer control and still control the valve?

2 A (WITNESS LANESE) I can only answer in general
3 terms. Anything that we feel would need to be demonstrated
4 to show the availability of the system would be tested.
5 Since I am not involved in the NNI ICS, I cannot make a
6 judgment on whether that requires an in-plant test.

7 Q Is this transfer by the operator upon loss of
8 non-nuclear instrumentation in your view an important
9 provision?

10 A (WITNESS LANESE) Yes, it is.

11 Q So then you personally at least would recommend
12 that such a test be done.

13 A (WITNESS LANESE) In some manner. We have to
14 demonstrate to ourselves that that capability is indeed
15 installed properly in the plant.

16 MR. POLLARD: Mr. Chairman, we are, as you can see
17 on our cross examination plan, at a break point, if this is
18 convenient.

19 CHAIRMAN SMITH: Okay. This seems to be a good
20 place.

21 But before we adjourn -- all right, then, we will
22 adjourn and what is our schedule for next week? It is the
23 routine schedule. Right, we meet --

24 MR. POLLARD: We were going to ask, of course, to
25 do the same, 10:00 o'clock.

1 CHAIRMAN SMITH: Well, you see, this is not a
2 simple request. It has ripples all over the place. When
3 you at the last minute make that request, it changes the
4 travel plans of everybody involved, and if you want to make
5 that the regular practice, then we will address it, but
6 don't make these changes casually because they make a big
7 difference in the travel plans, we have to change flight
8 reservations, and everything else has to be changed.

9 MS. WEISS: I thought that I had asked last week
10 that at least every week that we are here that it be 10:00
11 o'clock.

12 CHAIRMAN SMITH: I did not understand that to be
13 the case.

14 MS. WEISS: I thought that is what I said.

15 CHAIRMAN SMITH: That one hour may not seem like a
16 big deal, but it does back up all the way to when the hotel
17 reservations have to be changed, the airline reservations
18 are changed, and it is very late to do that.

19 So, your request now is that on the days with UCS
20 that we begin at 10:00 on Tuesdays instead of 9:00.

21 MR. BAXTER: And run until 6:00 o'clock?

22 CHAIRMAN SMITH: And run until 6:00.

23 Does anybody object to that?

24 I would like that we could keep our regular
25 schedule and come in late.

1 All right, we will meet at 10:00 then.

2 MS. WEISS: And I understood -- did I understand
3 the Board to have ruled that the 24th of November will be a
4 day for meeting on emergency plans and not a hearing day?

5 CHAIRMAN SMITH: No, we have not ruled on that.

6 well, we have ruled that the 24th will be a day
7 for meeting on emergency plans, but we have not ruled that
8 it will not be a hearing day. I think perhaps we should
9 rule, if possible, now, so that parties can make as much
10 notice. Just give us a moment.

11 We'll do it off the record so that we can adjourn
12 now and meet at 10:00, and then we will come back and
13 announce it.

14 MS. WEISS: Thank you.

15 (Whereupon, at 11:59 o'clock a.m., the hearing in
16 the above-entitled matter recessed, to reconvene at 10:00
17 o'clock a.m., Tuesday, November 18, 1980.)

18

- - -

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: Metropolitan Edison Company (Three Mile Island Unit 1)

Date of Proceeding: November 14, 1980

Docket Number: 50-289 (Restart)

Place of Proceeding: Harrisburg, Pennsylvania

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Alfred H. Ward

Official Reporter (Typed)

Alfred H. Ward

Official Reporter (Signature)