



**Commonwealth Edison**  
 One First National Plaza, Chicago, Illinois  
 Address Reply to: Post Office Box 767  
 Chicago, Illinois 60690

November 17, 1980

Mr. B. J. Youngblood, Chief  
 Licensing Branch No. 1  
 Division of Licensing  
 U.S. Nuclear Regulatory Commission  
 Washington, DC 20555

Subject: LaSalle County Station Units 1 and 2  
 Control Room Habitability System  
NRC Docket Nos. 50-373/374

References (a): L. O. DelGeorge letter to A. Bournia dated  
 May 6, 1980.

(b): O. D. Parr letter to L. O. DelGeorge dated  
 January 22, 1980

Dear Mr. Youngblood:


In response to an inquiry made by Mr. Bournia of your Staff Commonwealth has reviewed the design of the LaSalle County Unit 1 and 2 Control Room Habitability System in accordance with Standard Review Plan Sections 2.2.1, 2.2.2, 2.2.3, and 6.4 and Regulatory Guide 1.78 and 1.95. Based on this review it is judged that the LaSalle control room habitability design satisfies the guidance for design in the named NRC positions.

Furthermore, as you are aware Commonwealth Edison resolved previously outstanding questions proposed by your staff on this system, by the commitment to implement the system design improvements described in Reference (a). It is our present understanding that those commitments resolved the concern expressed by the Staff in open item 25 of Reference (b) and provided sufficient bases for closure of the review of this issue. Further documentation of this assessment will be provided in Appendix L of the FSAR in response to NUREG 0694 item II.D.3.4.

For the reasons previously stated, no further modifications to the LaSalle County design are required. If you have any further questions in this regard, please direct them to this office.

Three (3) signed originals and thirty-seven (37) copies of this letter are submitted for your use.

Very truly yours,



J. S. Abel  
 Director of Nuclear Licensing

SUBSCRIBED and SWORN to  
 before me this 17th day  
 of November, 1980  
[Signature]  
 Notary Public