

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 T N I S N P 1 2 00-00000-00 3 41111 4 5

CON'T  
01 REPORT SOURCE L 6 050003277 121280 8 122480 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 At 0700 (c) on 12/12/80, mode 5, notification was received that the solenoid valves  
03 for the valve operators on six (6) containment isolation valves were not qualified  
04 for the accident environment. The affected valves are three (3) control air supply  
05 containment isolation valves and three (3) containment vacuum relief isolation  
06 valves. There was no effect on public health or safety. Previous occurrences - none.  
07  
08

09 SYSTEM CODE PA 11 CAUSE CODE B 12 CAUSE SUBCODE A 13 COMPONENT CODE VALVOP 14 COMP. SUBCODE E 15 VALVE SUBCODE Z 16  
LER/RO REPORT NUMBER 80 21 EVENT YEAR 80 22 SEQUENTIAL REPORT NO. 197 24 OCCURRENCE CODE 01 28 REPORT TYPE T 30 REVISION NO. 0 32  
ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT C 20 SHUTDOWN METHOD Z 21 HOURS 0024 37 ATTACHMENT SUBMITTED N 23 NPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER L 25 COMPONENT MANUFACTURER A499 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Equipment was not qualified for radiation dose under assumed accident environment of  
11  $7 \times 10^7$  rad. The affected solenoid valves (ASCO Models HB 8300C58RU, HB 8262C22, and  
12 HT 8316C15) were replaced by solenoid valves qualified for the accident environments.  
13  
14

15 FACILITY STATUS B 28 % POWER 000 29 OTHER STATUS NA 30 METHOD OF DISCOVERY D 31 DISCOVERY DESCRIPTION Engineering Design Review 32  
16 ACTIVITY RELEASED OF RELEASE Z 33 CONTENT Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
17 PERSONNEL EXPOSURES NUMBER 000 17 TYPE Z 38 DESCRIPTION NA 39  
18 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION NA 41  
19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

8012300444  
Name of Preparer W. T. Cottle/A. H. Gelston  
Phone 615-842-8261