

Central Mail



**Consumers  
Power  
Company**

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

COPY

February 13, 1978

Mr James G Keppler  
Office of Inspection and Enforcement  
Region III  
US Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

DOCKET 50-155 - LICENSE DPR-6 -  
BIG ROCK POINT PLANT - RESPONSE TO IE BULLETIN 78-02

As required by IE Bulletin 78-02, Consumers Power Company has surveyed electrical terminal block installations in systems inside containment required to operate under LOCA conditions and outside containment required to operate in the high-energy pipe break environment. The results of this survey indicate that there are no "unprotected" (ie, not encased in splashproof metal boxes) terminal blocks of any type, utilized at Big Rock Point in the specified systems and areas.

William S Skibitsky (Signed)

William S Skibitsky  
Senior Licensing Engineer

CC: DKDavis, USNRC

FEB 16 1978

aoz  
T

8103040360