

NPDES NOTIFICATION
Apparent Difference From Daily Average/Maximum Limitation

March 16, 1981

Plant: Palisades Plant Permit No: MI-0001457

Outfall Description: Turbine Sump Oil Separator Waste (OOG) Outfall No: 800218

Parameter: Oil and Grease (Freeon) Parameter No: 00556

1. Date of Incident: February 28, 1981
2. Identification of specific effluent limitation or monitoring requirement affected:

Daily average oil and grease limitation of 15 mg/l.
3. Description of Incident:

For February the daily average oil and grease concentration was 62.4 mg/l
4. Apparent Cause:

High values recorded on 2/3/81, 2/23/81 and 2/24/81 as previously explained in the Company's reports dated 2/13/81 and 3/3/81.
5. If not immediately corrected, the anticipated time the condition is expected to continue:

NA
6. Corrective Action - The following corrective action was taken or will be taken to reduce, eliminate and prevent recurrence:

Each case was handled separately. The cause was identified and corrective action was taken as previously reported.
7. Additional Comments:

NA
8. Signed: Ronald L Fobes

Revised 1/19/81

rp0381-0195a-57

8108240 418