

APPENDIX A

NOTICE OF VIOLATION

Virginia Electric and Power Company
North Anna 1 and 2

Docket Nos. 50-338 & 50-339
License Nos. NPF-4 & NPF-7

As a result of the inspection conducted on December 1, 1980 through January 10, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violations were identified.

- A. Technical Specification 3.3.1.1 Action Statement #7 requires that the inoperable channel be placed in a tripped condition within one (1) hour.

Contrary to the above, on November 14, 1980, Channel 1 of Steam Generator A Level was placed in a tripped condition 9½ hours after the level indicator reading was logged as being greater than the allowed tolerance from the average of the three level channels and was therefore inoperable.

This is a Severity Level IV Violation (Supplement I.D.3.) and applicable to Unit 1. A similar item was brought to your attention in our letter dated August 20, 1980.

- B. Technical Specification 6.8.1.a requires that procedures be developed, implemented and maintained for the procedures recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978. Section 3 of Appendix A discusses procedures for Startup, Operations and Shutdown of Safety Related Systems.

Contrary to the above, during the startup conducted from November 24 through November 30, 1980 the verification of service operability of Engineered Safeguards and Reactor Protection instrument transmitters was not performed as required by 1-OP-1A, Pre Startup Checkoff List. This item reflects incomplete corrective action to a previous violation.

This is a Severity Level V Violation (Supplement I.E.) and applicable to Unit 2. A similar item was brought to your attention in our letter dated August 20, 1980.

Pursuant to the provisions of 10 CFR 2.201, Virginia Electric and Power Company is hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date: MAR 10 1981

8108240793