

APPENDIX A

NOTICE OF VIOLATION

Georgia Power Company
Hatch 2

Docket No. 50-366
License No. NPF-5

As a result of the inspection conducted on January 10 - February 20, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violations were identified.

- A. Technical Specification 3.5.3.1.b.2 requires that in condition 4, two independent Core Spray System subsystems shall be operable taking suction from the condensate storage tank when the suppression pool is drained.

Contrary to the above, the operability of the core spray system was not met in that on January 26, 1981, the manual injection isolation valves for both subsystems were inadvertently shut for approximately 7 hours.

This is a Severity Level IV Violation (Supplement I.D.2.).

- B. Technical Specification 6.8.2 requires that written procedures be reviewed by the Plant Review Board (PRB) and approved by the Plant Manager.

Contrary to the above, adequate review and approval requirements were not met in that the PRB reviewed and the Plant Manager approved an inservice inspection hydro procedure (HNP-2-1230) on January 9, 1981, which, resulted in violation of technical specification 3.5.3.1.b.2 when implemented.

This is a Severity Level IV Violation (Supplement I.D.2.).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date: MAR 10 1981

8103240 839