

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 T N S N P 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE JO 37 CAT 50

CONT

01 REPORT SOURCE L 6 0 5 0 0 0 3 2 7 7 0 3 0 3 8 1 8 0 3 2 0 8 1 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 Unit 1 in mode 5. A design review pursuant to I&E Bulletin 79-14 discovered four sleeves
03 (mark #'s 525, 529, 533, and 537 on TVA 47W470-5) are identified as 8", 8", 6", and
04 8" nominal diameter, respectively, while the as-built sleeve size is 4" for all four.
05 This condition is unacceptable from a pipe qualification viewpoint since the four seal
06 water injection lines passing through the sleeves have movement in excess of the available
07 clearance. LCO 3.4.10.a was entered. There was no effect upon public health or safety.
08 Previous occurrences - none.

09 SYSTEM CODE C B 11 CAUSE CODE B 12 CAUSE SUBCODE C 13 COMPONENT CODE P E N E T R 14 COMP. SUBCODE F 15 VALVE SUBCODE Z 16
9 10 11 12 13 14 15 16
17 LER/RO REPORT NUMBER 8 1 EVENT YEAR 3 1 21 22 SEQUENTIAL REPORT NO. 0 2 3 24 25 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 REVISION NO. 0 32
21 22 23 24 25 26 27 28 29 30 31 32
ACTION FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRC-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
F 18 F 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 L 25 X 9 9 9 47
33 34 35 36 37 38 39 40 41 42 43 44 45
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The apparent cause is incorrect installation during construction. Modifications are
11 complete to provide clearance for the piping through three sleeves. One sleeve (mark
12 #533, 6" nominal diameter) has been determined to be acceptable for temporary operation
13 and will be modified at the earliest opportunity.

14
15 FACILITY STATUS G 28 % POWER 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY D 31 DISCOVERY DESCRIPTION Design modification 32
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
6 RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
10 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
NRC USE ONLY

Name of Preparer J. M. McGriff/G. B. Kirk

Phone (615) 842-8317

8108250507