



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

APR 24 1981



Docket No.: 50-358

The Cincinnati Gas & Electric Company
ATTN: Mr. Earl A. Borgmann
Vice President, Engineering
Post Office Box 960
Cincinnati, Ohio 45201

Dear Mr. Borgmann:

Subject: Safety Concerns Associated with Pipe Breaks in the BWR Scram System

On April 9, 1981, we discussed with your representatives the NRC's Office of Analysis and Evaluation of Operational Data (AEOD) report entitled, "Safety Concerns Associated with Pipe Break in the BWR Scram System." The Report describes a potential sequence of events which could result from a break in the BWR scram discharge piping during a scram condition concurrent with an inability to reclose the scram outlet valves. Concerns identified include the quality of the scram discharge volume piping, the ability to detect and isolate such a break, and potential water and steam degradation of available ECCS equipment as a result of the break. A number of recommendations were made in the report to remedy the potential concerns.

We are presently studying these issues and recommendations to determine whether the BWR design basis accidents should be modified and as a consequence whether appropriate actions should be taken for operating BWR plants. The purpose of this letter is to provide to you the AEOD report so that you can evaluate its applicability to your plant and determine appropriate remedial measures, and to request information from you concerning your evaluation in order to assist in determining an appropriate course of action for the NRC.

Therefore, please provide us within 45 days of your receipt of this letter, the following information:

1. A generic evaluation of the applicability of the indicated sequences of events in the REPORT to the BWR plant design, your estimate of the probability of occurrence of such sequences, and the bases for these conclusions,
2. A generic evaluation of the applicability of the indicated safety concerns and findings in the REPORT relative to BWR plant construction, design, and operation and the bases for these conclusions, and

8105040042

A

Mr. E. A. Borgmann


- 2 -

3. A generic evaluation of the recommendations listed in the REPORT discussing the degree to which the recommendations are being or have been implemented with bases why the recommendations should or should not be completely implemented on BWRs.

In addition, provide the following information within 120 days of your receipt of this letter:

1. Provide an evaluation of the applicability of the 45 day generic evaluation to your plant. This evaluation should contain plant specific considerations related to system design, instrumentation, construction, operation, operator training, and emergency procedures for your plant.
2. In light of the AEOD report and the 45 day generic evaluation, provide a plant specific evaluation of your facility's Scram Discharge Volume System conformance to GDC 14, GDC 35, GDC 55, §50.2(v), 50.55a (including footnote 2), and §50.46 of the Commission's regulations. This evaluation should address which portions of the Scram Discharge Volume System are considered to be part of the reactor coolant pressure boundary, the quality group and safety class of the Scram Discharge Volume System, the codes and standards used for the design, fabrication and inservice inspection of this system, and your bases for the above classifications or groupings.
3. Provide by analysis or reference a demonstration that a break in the Scram Discharge Volume System meets the requirements of §50.46 of the Commission's regulations, taking into account the environmental and flooding aspects of such a break.

Sincerely,



Robert L. Tedesco, Assistant Director
for Licensing

Enclosure:
As stated

cc: See next page w/enclosure

Mr. Earl A. Borgmann
Vice President - Engineering
Cincinnati Gas & Electric Company
P. O. Box 960
Cincinnati, Ohio 45201

cc: Troy B. Conner, Jr., Esq.
Conner, Moore & Corber
1747 Pennsylvania Avenue, N.W.
Washington, D.C. 20006

Mr. William J. Moran
General Counsel
Cincinnati Gas & Electric Company
P. O. Box 960
Cincinnati, Ohio 45201

Mr. William G. Porter, Jr.
Porter, Stanley, Arthur
and Platt
37 West Broad Street
Columbus, Ohio 43215

Mr. James D. Flynn, Manager
Licensing Environmental Affairs
Cincinnati Gas & Electric Company
P. O. Box 960
Cincinnati, Ohio 45201

David Martin, Esq.
Office of the Attorney General
209 St. Clair Street
First Floor
Frankfort, Kentucky 40601

Dr. Frank F. Hooper
School of Natural Resources
University of Michigan
Ann Arbor, Michigan 48109

Charles Bechhoefer, Esq., Chairman
Atomic Safety & Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Glenn O. Bright
Atomic Safety & Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Leah S. Kosik, Esq.
3454 Cornell Place
Cincinnati, Ohio 45220

W. Peter Heile, Esq.
Assistant City Solicitor
Room 214, City Hall
Cincinnati, Ohio 45220

John D. Woliver, Esq.
Clermont County Community Council
Box 181
Batavia, Ohio 45103

Mrs. Mary Reder
Box 270, Rt. 2
California, Kentucky 41007

Andrew B. Dennison, Esq.
200 Main Street
Batavia, Ohio 45103

Robert A. Jones, Esq.
Prosecuting Attorney of Clermont
County, Ohio
154 Main Street
Batavia, Ohio 45103

Resident Inspector/Zimmer
RFD 1, P. O. Box 2021
U. S. Route 52
Moscow, Ohio 45153

Mr. John Youkilis
Office of The Honorable William Gradison
United States House of Representatives
Washington, D. C. 20515