

THE CINCINNATI GAS & ELECTRIC COMPANY



Docket No. 50-358

April 29, 1981

Mr. Harold Denton, Director  
Office on Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

RE: WM. H. Zimmer Nuclear Power Station -  
Unit 1 - NUREG-0737 Submittal



Dear Mr. Denton:

This letter will confirm phone conversations between your Mr. Hinson and Messers, Brinkmann and Erickson of CG&E. CG&E will be supplementing the Zimmer NUREG-0737 submittal as follows:

1. Reference Item II.B.2 - A chart will be provided showing post accident dose rates in key locations. Drawings will also be provided to show the pathways to be followed by persons moving to and from vital areas. These items are intended to assist NRC reviewer in confirming expected dose rates.
2. Reference Item IID.3.3 - Silver Zeolite sample cartridges will be used in post accident situations involving mobile gases.
3. II.F.1 Containment Monitors - The following additional information will be provided:
  1. Drawings showing penetration location
  2. An explanation of why these locations were selected
  3. A drawing of an actual penetration.

CG&E will also prepare a pre-established radiation level chart to enable easy conversion of monitor readings to actual doses. This is to account for low energies which might not be detected.

It is our understanding from the above phone conversation that this letter will enable the above items to be shown as resolved in the Zimmer SSER, pending receipt of promised information.

cc: Service List

Very truly yours,

The Cincinnati Gas & Electric Company

*James D. Flynn*  
By: James D. Flynn

8105040356

A