

## REFUELING OPERATIONS

### CRANE TRAVEL - SPENT FUEL PIT

#### LIMITING CONDITION FOR OPERATION

---

3.9.7 Loads in excess of 900 pounds shall be prohibited from travel over the spent fuel pit except for the:

- a. Spent fuel pit building roof hatches,
- b. Spent fuel inspection stand,
- c. Fuel handling equipment,
- d. Spent fuel racks,
- e. Temporary gate, and
- f. Shielding panels.

APPLICABILITY: With fuel assemblies in the spent fuel pit.

#### ACTION:

With the requirements of the above specification not satisfied, place the crane load in a safe condition. The provisions of Specification 3.0.3 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.9.7 Loads in excess of 900 pounds shall be prevented from traveling over the spent fuel pit by administrative control except that the:

- a. Spent fuel pit building roof hatches, the spent fuel inspection stand, the fuel handling equipment, spent fuel racks, the temporary gate and the shielding panels may travel over the spent fuel pit in accordance with approved written procedures.
- b. Spent fuel storage racks, the spent fuel inspection stand, the temporary gate and the shielding panels shall be prevented from traveling over fuel assemblies in the spent fuel pit by administrative control; and
- c. Fuel handling equipment when moved for maintenance shall be prevented from traveling over fuel assemblies in the spent fuel pit by administrative control.