

Y1003J01A02
July 1980

SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR
VERMONT YANKEE NUCLEAR POWER STATION
RELOAD NO. 7

8009250693

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT
PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Vermont Yankee Nuclear Power Corporation for VY's use with the U.S. Nuclear Regulatory Commission (USNRC) for amending VY's operating license of the Vermont Yankee Nuclear Power Station. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained or provided to General Electric at the time this report was prepared.

The only undertaking of the General Electric Company respecting information in this document are contained in the contract between Vermont Yankee Nuclear Power Corporation and General Electric Company for nuclear fuel and related services for the nuclear system for Vermont Yankee Nuclear Power Station, dated July 11, 1975, and nothing contained in this document shall be construed as changing said contract. The use of this information except as defined by said contract, or for any purpose other than that for which it is intended is not authorized; and with respect to any such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy or usefulness of the information contained in this document or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.

CONTENTS

	<u>Page</u>
1. PLANT-UNIQUE ITEMS	1
2. RELOAD FUEL BUNDLES	1
3. REFERENCE CORE LOADING PATTERN	1
4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM WORTH - NO VOIDS, 20°C	1
5. STANDBY LIQUID CONTROL SYSTEM SHUTDOWN CAPABILITY	2
6. RELOAD UNIQUE TRANSIENT ANALYSIS INPUTS	2
7. RELOAD UNIQUE GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS	2
8. SELECTED MARGIN IMPROVEMENT OPTIONS	2
9. CORE-WIDE TRANSIENT ANALYSIS RESULTS	3
10. LOCAL ROD WITHDRAWAL ERROR (WITH LIMITING INSTRUMENT FAILURE) TRANSIENT SUMMARY	3
11. OPERATING MCPR LIMIT	3
12. OVERPRESSURIZATION ANALYSIS SUMMARY	4
13. STABILITY ANALYSIS RESULTS	4
14. LOSS-OF-COOLANT ACCIDENT RESULTS	4
15. LOADING ERROR RESULTS	4
16. CONTROL ROD DROP ANALYSIS RESULTS	4
APPENDICES	
A.	A-1
B. MARGIN-TO-SPRING SAFETY VALVES	B-1

ILLUSTRATIONS

Figure	Title	Page
1	Core Loading Pattern	1
2a	Scram Reactivity and CRD Specifications, EOC8	6
2b	Scram Reactivity and CRD Specifications, EOC8-1	7
2c	Scram Reactivity and CRD Specifications, EOC8-2	8
3a	Generator Load Rejection, EOC8	9
3b	Generator Load Rejection, Without Bypass, EOC8-1 GWd/t	10
3c	Generator Load Rejection, Without Bypass, EOC8-2 GWd/t	11
4	Loss of 100°F Feedwater Heating	12
5	Feedwater Controller Failure	13
6	Limiting Rod Pattern	14
7	MSIV Closure, Flux Scram	15
8	Reactor Core Decay Ratio vs Power	16

1. PLANT-UNIQUE ITEMS (1.0)*

Appendix A: Operating MCPR Limit

Exposure-dependent limits (EOC-2 GWd/t and EOC-1 GWd/t).

Appendix B: New Bundle Loading Error Event Analysis Procedures

Appendix C: Margin to Opening of Unpipied Safety Valves

2. RELOAD FUEL BUNDLES (1.0, 2.0, 3.3.1, and 4.0)¹

	<u>Fuel Type</u>	<u>Number</u>	<u>Number Drilled</u>
Irradiated	8DB274L	24	24
Irradiated	8DB274H	96	96
Irradiated	8DB219L	12	12
Irradiated	8DPB289	60	60
Irradiated	P8DPB289	96	96
New	P8DPB289	80	80
Total		368	368

3. REFERENCE CORE LOADING PATTERN (3.3.1)

Nominal previous cycle exposure: 15.75 GWd/t. Assumed reload cycle exposure: 16.80 GWd/t. Core loading pattern: Figure 1.

4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM WORTH - NO VOIDS, 20°C (3.3.2.1.1 AND 3.3.2.1.2)

BOC k_{eff}	
Uncontrolled	1.105
Fully Controlled	0.948
Strongest Control Rod Out	0.981
R, Maximum Increase in Cold Core Reactivity with Exposure Into Cycle, Δk	0.005

* () refers to areas of discussion in Reference 1.

Reference 1: "General Electric Boiling Water Reactor Generic Reload Fuel Application", NEDE-24011-P-A, August 1979.

5. STANDBY LIQUID CONTROL SYSTEM SHUTDOWN CAPABILITY (3.3.2.1.3)

	Shutdown Margin (Δk) (20°C, Xenon Free)
ppm	
800	0.057

6. RELOAD UNIQUE TRANSIENT ANALYSIS INPUTS (3.3.2.1.5 AND 5.2)

	<u>EOC8</u>	<u>EOC8-1</u>	<u>EOC8-2</u>
Void Coefficient N/A* (-c/% Rg)	8.03/10.03	8.58/10.73	8.52/10.65
Void Fraction (%)	40.13	40.13	40.13
Doppler Coefficient N/A (-c/°F)	0.728/0.217	0.224/0.213	0.218/0.207
Average Fuel Temperature (°F)	1342	1342	1342
Scram Worth N/A (-\$)	36.27/29.02	35.49/28.40	34.27/27.42
Scram Reactivity versus Time	Figure 2a	Figure 2b	Figure 2c

7. RELOAD UNIQUE GETAB TRANSIENT ANALYSIS INITIAL CONDITION
PARAMETERS (5.2)

<u>Exposure</u>	<u>EOC8</u>			<u>EOC8-1 GWd/t</u>			<u>EOC8-2 GWd/t</u>		
	<u>8x8</u>	<u>8x8R</u>	<u>P8x8R</u>	<u>8x8</u>	<u>8x8R</u>	<u>P8x8R</u>	<u>8x8</u>	<u>8x8R</u>	<u>P8x8R</u>
Peaking factors (local, radial axial)	1.22 1.36 1.40	1.20 1.50 1.40	1.20 1.48 1.40	1.22 1.40 1.40	1.20 1.54 1.40	1.20 1.52 1.40	1.22 1.44 1.40	1.20 1.58 1.40	1.20 1.58 1.40
R-Factor	1.098	1.052	1.052	1.098	1.052	1.052	1.098	1.052	1.052
Bundle Power (MWt)	5.763	6.346	6.275	5.911	6.495	6.426	6.105	6.680	6.688
Bundle Flow (10 ³ lb/hr)	109.3	110.0	110.9	108.2	109.0	110.0	106.9	107.8	108.2
Initial MCPR	1.29	1.29	1.31	1.26	1.26	1.28	1.21	1.21	1.21

8. SELECTED MARGIN IMPROVEMENT OPTIONS (5.2.2)

Exposure-dependent limits: EOC8-1 GWd/t to EOC8
EOC8-2 GWd/t to EOC8-1 GWd/t
BOC8 to EOC8-? GWd/t

*N = Nuclear Input Data
A = Used in Transient Analysis

9. CORE-WIDE TRANSIENT ANALYSIS RESULTS (5.2.1)

<u>Transient</u>	<u>Exposure</u>	<u>Power (%)</u>	<u>Core Flow (%)</u>	<u>$\bar{\phi}$ (% NBR)</u>	<u>O/A (% NBR)</u>	<u>P_{SL} (psig)</u>	<u>P_v (psig)</u>	<u>ΔCPR 8x8/8x8R/P8x8R</u>	<u>Plant Response</u>
Load Rejection without Bypass	EOC8	104.5	100	295	119	1242	1261	0.22/0.22/0.24	Figure 3a
	EOC8-1 Gwd/t	104.5	100	265	116	1237	1254	0.19/0.19/0.21	Figure 3b
	EOC8-2 Gwd/t	104.5	100	172	109	1210	1228	0.09/0.09/0.09	Figure 3c
Loss of 100°F FW Heater	BOC8 to EOC8	104.5	100	123	122	-	-	0.14/0.14/0.14	Figure 4
Feedwater Controller Failure	BOC8 to EOC8	104.5	100	113	110	1022	1065	0.05/0.05/0.05	Figure 5

10. LOCAL ROD WITHDRAWAL ERROR (WITH LIMITING INSTRUMENT FAILURE) TRANSIENT SUMMARY (5.2.1)

<u>Rod Block Reading (%)</u>	<u>Rod Position (Feet Withdrawn)</u>	<u>ΔCPR</u>		<u>LHGR</u>		<u>Limiting Rod Pattern</u>
		<u>8x8/8x8R/P8x8R</u>	<u>8x8/8x8R and P8x8R</u>	<u>8x8/8x8R</u>	<u>and P8x8R</u>	
104	4.0	0.09/0.12/0.13	12.0/14.0			Figure 6 ↓
105*	4.0	0.09/0.12/0.13	12.0/14.0			
106	4.5	0.10/0.14/0.15	12.4/14.5			
107	5.0	0.11/0.15/0.16	12.8/15.1			
108	6.0	0.14/0.19/0.20	13.3/16.1			
109	7.0	0.18/0.22/0.23	13.6/16.7			

11. OPERATING MCPR LIMIT (5.2)

See Appendix A.

*Indicates setpoint selected.

12. OVERPRESSURIZATION ANALYSIS SUMMARY (5.3)

<u>Transient</u>	<u>Power (%)</u>	<u>Core Flow (%)</u>	<u>P_{sl} (psig)</u>	<u>P_v (psig)</u>	<u>Plant Response</u>
MSIV Closure (Flux Scram)	104.5	100	1267	1290	Figure 7

13. STABILITY ANALYSIS RESULTS (5.3)

Decay Ratio: Figure 8

Reactor Core Stability:

Decay Ratio, x_2/x_0 0.84

(Natural Circulation - 105%
Rod Line)

Channel Hydrodynamic Performance

Decay Ratio
(Natural Circulation -
105% Rod Line)

8x8 channel	0.39
8x8R channel	0.29
P8x3R channel	0.29

14. LOSS-OF-COOLANT ACCIDENT RESULTS (5.5.2)


Fuel type P8DPB289 was introduced in Reload 6.

15. LOADING ERROR RESULTS (5.5.4)

See Appendix A.

16. CONTROL ROD DROP ANALYSIS RESULTS (5.5.1)

Maximum incremental rod worth 0.76% Δk .



FUEL TYPE	
A = 8DB274L	C = 90PB289
B = 8DB274H	E = P8DPB289, R6
C = 8DB219L	F = P8DPB289, R7

Figure 1. Core Loading Pattern




Figure 2a. Scram Reactivity and CRD Specifications, EOC8




Figure 2b. Scram Reactivity and CRD Specifications, EOC8-1




Figure 2c. Scram Reactivity and CRD Specifications, EOC8-2







Figure 3a. Generator Load Rejection, EOC8




Figure 3b. Generator Load Rejection, Without Bypass, EOC8-1 GWd/t







Figure 3c. Generator Load Rejection, Without Bypass, EOC8-2 GwD/t







Figure 4. Loss of 100°F Feedwater Heating







Figure 5. Feedwater Controller Failure

	02	06	10	14	18	22
43						12
39			16		32	
35		40		30		0
31			32		44	
27		12		0		0
23	16		32		44	

- Notes: 1. Rod pattern is 1/4 core mirror symmetric. Upper left quadrant shown on map.
2. Numbers indicate number of notches withdrawn out of 48. Blank is a withdrawn rod.
3. Error rod is at 22,27 (reactor coordinates).

Figure 6. Limiting Rod Pattern







Figure 7. MSIV Closure, Flux Scram




Figure 8. Reactor Core Decay Ratio vs Power

APPENDIX A

OPERATING MCPR LIMIT

If, during steady-state operation, the offgas activity as measured at the SJAE's exceeds 236,000 μ Ci/sec for fifteen (15) minutes of 1.18 Ci/sec for one (1) minute, the operating MCPR limit shall be as follows:

<u>Exposure Range</u>	MCPR Operating Limit		
	<u>8x8</u>	<u>8x8R</u>	<u>P8x8R</u>
EO8-1 GWd/t to EOC8	1.29	1.29	1.31
EOC8-2 GWd/t to EOC8-1 GWd/t	1.26	1.26	1.28
BOC8 to EOC8-2 GWd/t	1.21	1.26	1.26

If, during steady-state operation, the offgas activity as measured at the SJAE's is less than specified above, the operating limit shall be as follows:

<u>Exposure Range</u>	MCPR Operating Limit		
	<u>8x8</u>	<u>8x8R</u>	<u>P8x8R</u>
EOC8-1 GWd/t to EOC8	1.29	1.29	1.31
EOC8-2 GWd/t to EOC8-1 GWd/t	1.26	1.26	1.23
BOC8 to EOC8-2 GWd/t	1.21	1.21	1.21

APPENDIX B
LOADING ERROR RESULTS
(NEW BUNDLE LOADING ERROR EVENT ANALYSES PROCEDURES)

The bundle loading error analyses results presented in Section 15 in this supplement are based on new analyses procedures for both the rotated bundle and the mislocated bundle loading error events. The use of these new analyses procedures is discussed below.

B.1 NEW ANALYSIS PROCEDURE FOR THE ROTATED BUNDLE LOADING ERROR EVENT

The rotated bundle loading error event analysis results presented in this supplement are based on the new analysis procedure described and approved in **Reference B-1**. This new method of performing the analysis is based on a more accurate detailed analytical model.

The principle difference between the previous analysis procedure and the new analysis procedure is the modeling of the water gap along the axial length of the bundle. The previous analysis used a uniform water gap, whereas the new analysis utilizes a variable water gap which is more representative of the actual condition, since the interfacing between the top guide and the fuel spacer buttons, caused by misorientation, causes the bundle to lean. The effect of the variable water gap is to reduce the power peaking and the R-factor in the upper regions of the limiting fuel rod. This results in the calculation of a reduced CPR for the rotated bundle. The calculation was performed using the same analytical models as were previously used. The only change is in the simulation of the water gap, which more accurately represents the actual geometry.

The results of the analysis indicate the P8DPB289 bundle a 17.7 kW/ft LHGR (includes densification spiking penalty of 2.2%) and 0.19 Δ CPR (includes a 0.02 penalty due to variable water gap R-factor uncertainty) with a minimum CPR of 1.07.

B.2 NEW ANALYSIS PROCEDURE FOR THE MISLOCATED BUNDLE LOADING ERROR EVENT

The mislocated bundle loading error event analyses results presented in this supplement are based on the new analysis procedure described in Reference A-1. This new method of performing the analysis employs a statistically corrected Haling procedure and analyzes every bundle in the core.

The use of the statistically corrected Haling analyses procedure indicates that the LHGR is 16.6 and that minimum CPR for mislocated bundles (e.g., P8x8R into P8x8R) is greater than the safety limit (1.07) for all exposures throughout Cycle 8.

Y1003J01A02

REFERENCES

- B-1 Safety Evaluation Report (letter), D. G. Eisenhut (NRC) to R. E. Engel (GE), MFN-200-78, dated May 8, 1978.

APPENDIX C

MARGIN-TO-SPRING SAFETY VALVES

The rationale for changing the basis for providing pressure margin to the spring safety valves is presented in Reference C-1. This change has been accepted by the NRC (Reference C-2).

On this basis the plant can operate at full power throughout the cycle.

The core response to the limiting anticipated event is given in Table C-1 and Figure C-1

Table C-1
CORE-WIDE TRANSIENT ANALYSIS RESULTS

<u>Transient</u>	<u>Exposure</u>	<u>Power (%)</u>	<u>Flow (%)</u>	<u>P_{sl} (psig)</u>	<u>P_v (psig)</u>	<u>Plant Response</u>
MSIV Closure Trip Scram	BOC-EOC	104	100	1162	1183	Figure B-1

REFERENCES

- C-1. J. F. Quirk (GE) letter to Olan D. Parr (NRC), "General Electric Licensing Topical Report NEDE-24011-P-A, 'Generic Reload Fuel Application', Appendix D, Second Submittal," dated February 28, 1979.
- C-2. Letter, T. A. Ippolito (NRC) to D. L. Peoples (Commonwealth Edison Co.), enclosing Safety Evaluation Supporting Amendment No. 42 to Operating License No. DPR-25, Dresden Nuclear Power Station, Unit 3, April 16, 1980.







Figure C-1. MSIV Closure, Position Scram