

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 250-1000

F. L. CLAYTON, JR.
Senior Vice President



Alabama Power
the southern electric system

October 15, 1980

Docket No. 50-348

Director
Office of Management Information and
Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Sir:

RE: Joseph M. Farley Nuclear Plant
Unit No. 1
Monthly Operating Data Report

Attached are two (2) copies of the September, 1980 monthly operating report for Joseph M. Farley Nuclear Plant, Unit 1, as required by Section 6.9.1.6 of the Appendix A Technical Specifications. As requested by letter from Mr. John F. Stolz to Mr. Alan R. Barton, dated October 21, 1977, a "Narrative Summary of Operating Experience" is included in the attached report.

If you have any questions, please advise.

Yours very truly,

William O. Whitt
for F. L. Clayton, Jr.

FLCJr/JRC:bjh

Attachments

cc: Mr. Ted Cintula (1 copy)
Director, IE (10 copies)
Director, RII (1 copy)

*Proos
5/11*

8010210 402

R

JOSEPH M. FARLEY NUCLEAR PLANT
UNIT 1

NARRATIVE SUMMARY OF OPERATIONS
SEPTEMBER, 1980

There were five unit shutdowns and seven power reductions in the month of September.

The following safety-related maintenance was performed in September:

1. Replaced cells 19, 20 and 21 on the B train Service Water battery and cells 27, 28 and 29 on the A train Service Water battery.
2. Replaced 1B Diesel A train air compressor relief valve.
3. Repacked and set the lift on #10 River Water pump.
4. Repacked air reservoir discharge valves on 1B Diesel train A and B air start systems.