



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MARCH 25 1980

Docket No: 50-334

LICENSEE: Duquesne Light Company

FACILITY: Beaver Valley Power Station, Unit No. 1

SUBJECT: MEETING SUMMARY - LESSONS LEARNED

The licensee met with the staff on March 7, 1980 to discuss the implementation plan requirements for Lessons Learned and specifically to request approval of the site location for the long term technical support center. The list of attendees is attached as Enclosure 1.

All of the areas of the short term lessons learned were discussed with the licensee with particular attention to those areas where recent clarifications of positions have occurred and where other licensees misinterpreted our positions. Beaver Valley is scheduled to restart in July 1980 and their Lessons Learned implementation plan is due to be reviewed prior to that time. The licensee is beginning to purchase some of the equipment required and those corresponding lessons learned areas will be better defined in the coming months. The lessons learned task force is not expected to review the Beaver Valley plan any time soon because of priority considerations being given to the operating plants.


The licensee had requested the meeting to discuss the location of the long term technical support center. Due to the crowded site at Beaver Valley, the licensee has chosen an area just east of the Unit 2 construction but on the other side of the Shippingport-Midland highway. The licensee has a tunnel access beneath the road. The proposed one story building will be located 1100-1200 feet from the control room. It will house the technical support center, emergency response center, and near site operations center, as well as other offices and rooms to support an emergency situation. The building will normally be used as an office building and training center. Direct communication with the control room will be established with 8 or more closed circuit TV cameras that can scan, tilt, and zoom to all portions of the control boards. Senior licensee management will be located in both the technical support center and control room for effective management of operations. There may also be some consideration to installing picture-telephones between the two points. Details of the proposed building with a site plot and building plan are attached as Enclosure 2.

The staff was unable to respond to the licensee on the location of the technical support center. Discussion are to be held by NRC management on the Arkansas Nuclear Power Plant location of their technical support center and the results of that discussion may help with the Beaver Valley decision. The licensee

8004240087

MARCH 25 1980

will be notified of the outcome of the Arkansas decision as it affects the Beaver Valley proposed site.



D. Wigginton
Senior Project Manager
DOR-ORB-1

Enclosures: As Stated

Meeting Summary for
Beaver Valley 1

MARCH 25 1980

Docket Files

- NRC PDR
- Local PDR
- OR&I Reading
- NRR Reading
- H. Denton
- E. Case
- D. Eisenhut
- R. Tedesco
- G. Zech
- B. Grimes
- W. Gammill
- L. Shao
- J. Miller
- R. Vollmer
- T. J. Carter
- A. Schwencer
- D. Ziemann
- P. Check
- G. Lainas
- D. Crutchfield
- B. Grimes
- T. Ippolito
- R. Reid
- V. Noonan
- G. Knighton
- D. Brinkman
- Project Manager
- OELD
- UI&E (3)
- C. Parrish/P. Kreutzer
- ACRS (16)
- NRC Participants
- NSIC
- TERA
- Licensee

Mr. James A. Werling
Plant Superintendent
Beaver Valley Power Station
P. C. Box 4
Shippingport, Pennsylvania 15077

Mr. John A. Levin
Public Utility Commission
P. O. Box 3265
Harrisburg, Pennsylvania 17120

Mr. J. D. Sieber, Superintendent
of Licensing and Compliance
Duquesne Light Company
Post Office Box 4
Shippingport, Pennsylvania 15077

Gerald Charnoff, Esquire
Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Karin Carter, Esquire
Special Assistant Attorney General
Bureau of Administrative Enforcement
5th Floor, Executive House
Harrisburg, Pennsylvania 17120

Mr. Roger Tapan
Stone and Webster Engineering
Corporation
P. O. Box 2325
Boston, Massachusetts 02107

Mr. F. Noon
R & D Center
Westinghouse Electric Corporation
Building 7-303
Pittsburgh, Pennsylvania 15230

B. F. Jones Memorial Library
663 Franklin Avenue
Aliquippa, Pennsylvania 15001

Mr. John Carey, Director
Nuclear Operations
Duquesne Light Company
435 Sixth Avenue
Pittsburgh, Pennsylvania 15219

Mr. R. E. Martin
Duquesne Light Company
435 Sixth Avenue
Pittsburgh, Pennsylvania 15219

Marvin Fein
Utility Counsel
City of Pittsburgh
313 City-County Building
Pittsburgh, Pennsylvania 15219

Lessons Learned Implementation

March 7, 1980 Meeting With Beaver Valley Unit No. 1

D. Wiggington	NRC-ORB
N. Anderson	NRC-ORB
J. Kerrigan	NRC-ORB
C. Willis	NRC-ORB
Turdoin	NRC-ORB
M. rields	NRC-DSS
J. Sieber	DLC
J. Carey	DLC
T. Telford	NRC-DOR
J. Kane	TEK NECTRON
J. L. Koepfinger	DLC
M. Seigel	DLC
J. Campbell	DLC