

WCAP-8587-
SUPP 2-E18A

WESTINGHOUSE CLASS 3


EQUIPMENT QUALIFICATION
TEST REPORT
INSTRUMENT BUS POWER SUPPLY
(STATIC INVERTER)
(NORMAL AND ABNORMAL TEMPERATURE AND HUMIDITY TESTING)

BY
M. YALICH


EDITED BY
C. E. FAUST III

July 1980

APPROVED:



T. M. Anderson
Manager, Nuclear Safety



S. Ramchandran
Manager, Electrical Systems Application

Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, PA 15230

5169A

8008260 453

TABLE OF CONTENTS

| <u>Section</u> | <u>Title</u> | <u>Page</u> |
|----------------|----------------------------------|-------------|
| 1.0 | OBJECTIVE | 1 |
| 2.0 | EQUIPMENT TESTED | 2 |
| 3.0 | PERFORMANCE SPECIFICATIONS | 3 |
| 4.0 | DESCRIPTION OF THE TEST FACILITY | 4 |
| 5.0 | TEST PROCEDURE | 5 |
| 6.0 | TEST DATA | 6 |
| 7.0 | SUMMARY | 7 |

TABLES

| <u>Table</u> | <u>Title</u> | <u>Page</u> |
|--------------|------------------------------|-------------|
| TABLE I | Specified Service Conditions | 8 |
| TABLE II | Test Equipment | 9 |
| TABLE III | Test Data | 10 |

LIST OF FIGURES

| <u>Figure</u> | <u>Title</u> | <u>Page</u> |
|---------------|--|-------------|
| Figure 1 | Temperature versus Humidity - Enclosed Environments Outside Containment | 11 |
| Figure 2 | Test Set-Up for Static Inverter Environment Test | 12 |
| Figure 3 | Environmental Chamber in Background, Load Rack and Instruments in Foreground | 13 |
| Figure 4 | Three Phase Static Inverter Which Supplied Source Power to the Inverter Under Test | 14 |
| Figure 5 | Inverter Under Test at Left. (Unit to the Right is a MOD 80 Undergoing Life Test, Not Included in this Report) | 15 |
| Figure 6 | Instruments Used to Monitor Temperature and Humidity | 16 |
| Figure 7 | Temperature and Humidity Recorder as Seen Through a Porthole, Inverter is in the Background | 17 |
| Figure 8 | Breaker Panel Located in Environmental Chamber. Door was Closed During Test. | 18 |
| Figure 9 | Breaker Panel With Door Open to Show Breakers. | 19 |

1.0 OBJECTIVE

The objective of this qualification program is to demonstrate that the Static Inverter meets or exceeds its safety-related performance requirements while subjected to the normal and simulated abnormal service conditions specified in Figure 1. A qualification test was performed on one typical Static Inverter.

2.0 EQUIPMENT TESTED

The equipment tested was a production model Static Inverter manufactured by Westinghouse PED, Buffalo, N.Y. which is a static type model 7.5 KVA Instrument Bus Power Supply, [] a.c.

3.0 PERFORMANCE SPECIFICATION

The Static Inverter was tested to verify its functional operability as defined below:

3.1 Twelve hours continuous operation at the extreme temperature and humidity conditions of Figure 1 (condition 3 - loss of ventilation or Non-Class 1E air conditioning).

3.2 The following output characteristics.

3.2.1 Voltage: 118 VAC \pm 2%

3.2.2 Frequency: 60 Hz \pm 1.0 Hz

3.2.3 Distortion: Less than 5% total harmonic distortion

3.2.4 Power factor of 0.8

4.0 DESCRIPTION OF THE TEST FACILITY

The environmental qualification of the Static Inverter was performed at Westinghouse Power Electric & Drive Systems (PEDS), Buffalo, N. Y., which is also the manufacturer of the equipment.

4.1 Test Equipment

4.1.1 The environmental test chamber with a temperature capability of []^{a,b,c} and reaching a relative humidity of []^{a,b,c} with integral controlling thermocouple and temperature recorders.

4.1.2 Other associated test equipment are listed in Table II. Calibrations are traceable to National Bureau of Standards.

4.2 Mounting

4.2.1 With this being a temperature and humidity test, the equipment was free standing. No bolting or fastening to the floor was specified since this was not germane to this test sequence.

4.3 Connections

4.3.1 Connectors were used for all connections requiring them. Terminal board connections were made using ring tongue terminals. Interconnecting cabling between various assemblies were typical prefabricated cables (with connectors) as indicated in Figure 3.

5.0 TEST PROCEDURES

5.1 Normal Environmental Testing

A number of performance checks (i.e. burn-in, systems calibration, etc.) are carried out by Westinghouse to verify capability to meet performance requirements under ambient conditions. These normal environmental tests are performed on all production units prior to release and, as a consequence, are not reported in this generic test report, which is limited to reporting the results of abnormal environmental testing of a representative unit. However, the results of these normal environmental production unit tests are maintained by Westinghouse and are available for audit for any particular project. The generic abnormal environmental testing described in this report do, furthermore, cover a range of temperature and humidity parameters that encompass the specified range of these parameters for the normal environment (Figure 1).

5.2 Abnormal Environmental Testing

5.2.1 Service Conditions

The safety-related functions of the Static Inverter were tested while subject to simulated service conditions specified in Table I. During the same testing period, the input voltage and frequency were varied above and below the normal values as also shown in Table I.

5.2.2 Monitored Functions

The Inverter output performance of AC voltage, current, frequency and total harmonic distortion were monitored during each abnormal service condition cycle.

6.0 TEST DATA

The test data summarized below demonstrates that the equipment under test met or exceeded the specifications of Section 3.2 (See Table III for detailed results).

6.1 Output voltage remained within specified limits, maximum deviations ranged between []^{b,c,e} volts at the worst, and usually staying between []^{b,c,e} volts.

6.2 Output frequency varied between []^{b,c,e} Hz.

6.3 Total harmonic distortion varied from []^{b,c,e} meeting the 5% requirement.

6.4 Output current was a nominal []^{b,c,e} Amps (ranging between []^{b,c,e} Amps) with power factor held to []^{b,c,e}.

7.0 SUMMARY

- 7.1 The Static Inverter was tested under normal and simulated abnormal service conditions (environmental, input voltage, and frequency) to demonstrate its capability to perform its safety-related function under these conditions. The test results show the equipment remained within the output specification of Section 3.2 while subjected to the environmental and supply extremes shown in Table I.
- 7.2 The specified performance requirements for functions are 12 hours at abnormal conditions. EQDP-ESE-18, Section 2.6, requires a test of four (two for margin) 12 hour cycles of temperature, humidity, voltage and frequency extremes. The conditions for all four cycles are presented in Table III.
- 7.3 Figures 3 through 9 are included to show the test configuration.

TABLE I

SPECIFIED SERVICE CONDITIONS

| <u>Cycle</u> | <u>Time Hrs.</u> | <u>Temp</u> <u>(°F)</u> | <u>Humid.</u> <u>(% RH)</u> | <u>Line VAC</u> | <u>Line Freq. (Hz)</u> |
|--------------|------------------|----------------------------|--------------------------------|-----------------|------------------------|
| 1 | 12 | [| | |] b,c,e |
| 2 | 12 | | | | |
| 3 | 12 | | | | |
| 4 | 12 | | | | |

TABLE II

TEST EQUIPMENT

| Parameter | Instrument | Serial Number |
|-------------------------------------|--|---------------|
| Temperature | Fisher Mercury | None |
| | Fisher Thermometer | None |
| Input Voltage | Westinghouse Voltmeter PY5 | 1431220 |
| | Westinghouse Voltmeter PY5 | 23230 |
| | Westinghouse Voltmeter PA5 | 2485271 |
| Input Frequency | Weschler Freq. Meter QA5 & | None |
| | Westinghouse Transducer | |
| Output Voltage | Westinghouse Voltmeter PA5 | 274848 |
| Output Current | Westinghouse Ammeter Style 682166-A | 3718 |
| Output Watts | Westinghouse Wattmeter PY5 | 6982 |
| Current Transformer | Westinghouse Current Transformer Type GCI-101 100/5 Ratio | 00757 |
| Output Total Harmonic Distortion | Hewlett Packard Distortion Analyzer Model 330D | 246-09943 |
| Output Frequency | Hewlett Packard Interval/ Frequency Counter Model 522B | 125-05464 |

TABLE 111

TEST DATA

| Cycle | Ambient | | Supply | | Supply | | Output | | Output | | Power | | Output | | Total | |
|-------|--------------|--------------------|------------------------|---------|--------------|--------------------|-------------------|---------------|--------------|-------------------|---------------|--------------|-------------------------------|--|-------|--|
| | Temp (°F) | Humidity (% RH) | Voltage V12/V23/V31 | Voltage | Freq (Hz) | Voltage (Volts) | Current (Amps) | Factor (%) | Freq (Hz) | Distortion (%) | Factor (%) | Freq (Hz) | Harmonic Distortion (%) | | | |
| 1 | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | |

b, c, e






Figure 1. Temperature Versus Humidity - Enclosed Environments Outside Containment




Figure 2 . Test Set-Up for Static Inverter Environmental Test




Figure 3. Environmental Chamber in Background, Load Rack and Instruments in Foreground




Figure 4. Three Phase Static Inverter Which Supplied Source Power to the Inverter Under Test




Figure 5. Inverter Under Test at Left. (Unit to the Right is a MOD 80 Undergoing Life Test. (Not Included in this Report)




Figure 6. Instruments Used to Monitor Temperature and Humidity




Figure 7. Temperature and Humidity Recorder as Seen Through a Port Hole, Inverter is in the Background




Figure 8. Breaker Panel Located in Environmental Chamber. Door Was Closed During Test




Figure 9. Breaker Panel With Door Open to Show Breakers