

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C | C | F | S | V | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 2 | 0 | 4 | _____ | 5
7 8 9 9 14 15 25 26 30 57 58

CON'T
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 6 | 7 | 7 | 0 | 6 | 2 | 5 | 8 | 0 | 8 | 0 | 7 | 2 | 5 | 8 | 0 | 9
7 8 50 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While operating at approximately 5% thermal power, during regeneration a batch of con-
0 3 | densate polisher resin, waste water was discharged to the plant liquid effluent sys-
0 4 | tem rather than the waste neutralizing tank. As a result, limits for Cu, Zn, and pH
0 5 | were exceeded. Degraded mode of LCO NR 1.1. Reportable per AC 7.5.2(b)2. No affect
0 6 | on public health or safety. No similar occurrences.
0 7 | _____
0 8 | _____

0 9 | SYSTEM CODE | X | X | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | F | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | E | 15 | VALVE SUBCODE | Z | 16
7 8 9 10 11 12 13 18 19 20
17 | LER RO REPORT NUMBER | 8 | 0 | 21 | EVENT YEAR | 8 | 0 | 22 | SEQUENTIAL REPORT NO. | 0 | 3 | 5 | 24 | OCCURRENCE CODE | 0 | 3 | 28 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32
ACTION TAKEN | A | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 22 | ATTACHMENT SUBMITTED | Y | 23 | NPD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | B | 1 | 3 | 5 | 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A failed Beckman conductivity cell controlling the discharge valves for the regenera-
1 1 | tion system caused waste water to be released to the building liquid effluent. The
1 2 | cell was replaced and discharge valve operability was verified.
1 3 | _____
1 4 | _____

1 5 | FACILITY STATUS | E | 28 | % POWER | 0 | 0 | 5 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Routine Chemical Analysis | 32
7 8 9 10 12 13 44 45 46
1 6 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36
7 8 9 10 11 44 45
1 7 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39
7 8 9 11 12 13
1 8 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41
7 8 9 11 12
1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | N/A | 43
7 8 9 10
2 0 | PUBLICITY ISSUED DESCRIPTION | N | 44 | DESCRIPTION | N/A | 45 | 8008260 552 | NRC USE ONLY
7 8 9 10 58 59 80