



bcc to DAC:ADM:
CENTRAL FILES
PDR:HQ
LPDR
TIC
NSIC

ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

July 8, 1980

1-070-10
2-070-11

Mr. K. V. Seyfrit, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Subject: Arkansas Nuclear One-Units One & Two
Docket Nos. 50-313 & 50-368
License Nos. DPR-51 & NPF-6
IE Bulletin 80-09, Hydramotor Actuators
(File: 1510.1, 2-1510.1)

Gentlemen:

We have currently been unable to obtain all of the information necessary to respond completely to IE Bulletin 80-09, however, the following information is provided as a partial response.

There are six of the subject ITT General Controls Hydramotor Actuators used in safety related systems at ANO. Of these, four are used on Unit One and two on Unit Two. All six of these actuators were manufactured using the proper 5160 steel for their spring material.

We expect to have compiled all information needed to respond to this Bulletin by July 18, 1980. Our complete response to this Bulletin will then be forwarded to you.

Very truly yours,

David C. Trimble
David C. Trimble
Manager, Licensing

DCT:DEJ:sh

8008280022



MEMBER MIDDLE SOUTH UTILITIES SYSTEM