



72c

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

JUL 18 1980

Docket No. 50-213

Connecticut Yankee Atomic Power Company
ATTN: Mr. W. G. Council
Vice President - Nuclear
Engineering and Operations
P. O. Box 270
Hartford, Connecticut 06101

Gentlemen:

Subject: Inspection No. 50-213/80-09

This refers to your letter dated July 3, 1980, in response to our letter dated June 9, 1980.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a subsequent inspection of your licensed program.

In addition, it is our understanding, based on a telephone discussion between Mr. J. Ferguson of your staff and Mr. J. Serabian of this office on July 16, 1980, that the procedure modification for slurring reactor coolant letdown ion exchangers and the engineering study of the Volume Control Tank (VCT) vent design and the Waste Gas Holdup System have been completed. Also, we understand that the VCT vent system has been modified to limit flow.

Your cooperation with us is appreciated.

Sincerely,

George H. Smith
George H. Smith, Chief
Fuel Facility and Materials
Safety Branch

cc: R. Graves, Plant Superintendent
D. G. Diedrick, Manager of Quality Assurance
J. R. Himmelwright, Licensing Safeguards Engineer

8008280103