



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

August 22, 1980

1-080-15

Mr. K. V. Seyfrit, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Comm.
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Licensee Event Report No. 80-029/03L-0
(File: 0520)

Gentlemen:

In accordance with Arkansas Nuclear One - Unit 1 Technical Specification 6.12.3.2.b, attached is the subject report concerning the Rx Buidling Escape Lock barrel test which was found to have exceeded its testing frequency limits.

Very truly yours,

David C. Trimble
Manager, Licensing

DCT:GAC:skm

Attachment

cc: Mr. Victor Stello, Jr., Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Comm.
Washington, D. C. 20555

Mr. Norman M. Haller, Director
Office of Management & Program Analysis
U. S. Nuclear Regulatory Comm.
Washington, D. C. 20555

8008280 444

5