

72

BOSTON EDISON COMPANY
GENERAL OFFICES 800 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199

G. CARL ANDOGNINI
SUPERINTENDENT
NUCLEAR OPERATIONS DEPARTMENT

July 28, 1980

BECo Ltr. #80-153

Mr. Boyce H. Grier, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA. 19406

License No. DPR-35
Docket No. 50-293

Response to IE Bulletin 80-17 (Supplement #2)

Dear Mr. Grier:

This letter confirms that an alternate vent path was provided to the SDV vent system at Pilgrim Nuclear Power Station within 48 hours of the telephone notification on July 19, 1980. This was accomplished by cutting the vacuum relief valves off the vent valve piping, thus providing a positive vent path to building atmosphere.

We trust this letter is responsive to your concerns as outlined in the subject bulletin. However, should you have any further questions or concerns please do not hesitate to contact us.

Very truly yours,

G. Carl Andognini

8009020 110