



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

AUG 6 1980

Docket No. 50-293
IAL No. 80-26

Boston Edison Company M/C Nuclear
ATTN: Mr. G. Carl Andognini, Manager
Nuclear Operations Department
800 Boylston Street
Boston, Massachusetts 02199

Gentlemen:

This refers to the telephone conversation between you and Mr. E. J. Brunner of this office on August 5, 1980, regarding testing of the 'D' Safety Relief Valve (SRV) at Pilgrim Nuclear Power Station, Unit 1.

With regard to the matters discussed, we understand that you will take the following actions:

1. Perform Surveillance Testing to demonstrate the ability of 'D' SRV to open on demand at normal operating pressure. This test will be performed prior to 11:59 PM, August 6, 1980.
2. Continue trouble shooting to determine the cause of the previous failures of 'D' SRV to open on demand.
3. Perform additional Surveillance Testing on 'D' SRV at normal operating pressure following any work on the SRV control system.

If our understanding of your planned actions as described above is not in accordance with the actual plans and actions being implemented, please contact this office by telephone and in writing within 24 hours.

Sincerely,

Boyce H. Grier
Director

CC:
P. J. McGuire, Pilgrim Station Manager

8009120101