# LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

| LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT |
|---|---|---|---|
| C T M N S 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5) |

| REPORT SOURCE | DOCKET NUMBER | EVENT DATE | REPORT DATE |
|---|---|---|---|
| L (6) | 0 5 0 0 0 3 3 6 (7) | 1 0 2 3 8 0 (8) | 1 1 2 0 8 0 (9) |

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During power ascension testing following the unit refueling the Reactor Protection System (RPS) channel D trips on High Power, Local Power Density and Thermal Margin/Low Pressure were declared inoperable. In accordance with Technical Specifications, section 3.3.1.1, action 2b the trips were bypassed and operation continued.

| SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE |
|---|---|---|---|---|---|
| I A (11) | A (12) | C (13) | I N S T R U (14) | E (15) | Z (16) |

| LER/RO REPORT NUMBER (17) | EVENT YEAR | | SEQUENTIAL REPORT NO. | | OCCURRENCE CODE | REPORT TYPE | | REVISION NO. |
|---|---|---|---|---|---|---|---|---|
| | 8 0 | — | 0 3 6 | / | 0 3 | L | — | 0 |

| ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS (22) | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER |
|---|---|---|---|---|---|---|---|---|
| E (18) | E (19) | Z (20) | Z (21) | 0 0 0 0 | N (23) | N (24) | Z (25) | Z 9 9 9 (26) |

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The inoperable trip functions were the result of the channel D nuclear power upper and lower detector signal cables being reversed while making connections at the detectors, which were not labeled. The corrective action taken was to swap the cables where they enter the RPS and to recalibrate. The final action will be to label the detectors, reconnect cables again and recalibrate.

| FACILITY STATUS | % POWER | OTHER STATUS (30) | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION (32) |
|---|---|---|---|---|
| B (28) | 0 8 1 (29) | NA | A (31) | Operator Observation |

| ACTIVITY RELEASED | CONTENT OF RELEASE | AMOUNT OF ACTIVITY (35) | LOCATION OF RELEASE (36) |
|---|---|---|---|
| Z (33) | Z (34) | NA | NA |

PERSONNEL EXPOSURES

| NUMBER | TYPE | DESCRIPTION (39) |
|---|---|---|
| 0 0 0 (37) | Z (38) | NA |

PERSONNEL INJURIES

| NUMBER | DESCRIPTION (41) |
|---|---|
| 0 0 0 (40) | NA |

LOSS OF OR DAMAGE TO FACILITY (43)

| TYPE | DESCRIPTION |
|---|---|
| Z (42) | NA |

PUBLICITY

| ISSUED | DESCRIPTION (45) | NRC USE ONLY |
|---|---|---|
| N (44) | NA | |

8011250320

NAME OF PREPARER R. W. Bates PHONE 203-447-1791 X573