

1750 Chestnut Street Tower II

November 21, 1980

POOR ORIGINAL

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 -- DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SORC-50-327/30178

The enclosed report provides details concerning unit 1 passing from Mode
2 to Mode 1 with the containment upper compartment temperature less than
85 degrees F. This report is submitted in accordance with Sequoyah unit
1 Technical Specification 6.9.1.12.f.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. J. Green
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)

Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)

Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Lavallee
Nuclear Safety Analysis Center
Palo Alto, California 94303

NRC Inspector, Sequoyah

1002
5.11

80112503874

5