

Georgia Power Company
250 Peachtree Street
P.O. Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6000

TIC



Georgia Power

The Southern Electric System

W. A. Widner

General Counsel and General Manager
Nuclear Generation

October 30, 1980

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street, NW
Atlanta, Georgia 30303

REFERENCE:

RII: JPO

50-321/50-366

I&E Bulletin 80-17

ATTENTION: Mr. James P. O'Reilly

Gentlemen:

Pursuant to a conversation between Mr. Pete Taylor of your staff and Mr. C. T. Moore of the Plant Hatch staff, it is our understanding that we have NRC concurrence to change the frequency of surveillance on residual water in the scram discharge volume scram switches to a once per day basis as of October 28, 1980. Please let us know if your understanding of this issue differs from that described above.

Very truly yours,

W. A. Widner
W. A. Widner

RDB/mb

xc: M. Manry
R. F. Rogers, III

OFFICIAL COPY

8011260152