

U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT

REGION III

Reports No. 50-282/80-17; 50-306/80-17

Docket Nos. 50-282; 50-306 Licenses No. DPR-42; DPR-60 Safeguards Group IV

Licensee: Northern States Power Company
414 Nicollet Mall
Minneapolis, MN 55401

Facility Name: Prairie Island Units 1 and 2

Inspection At: Prairie Island Site, Red Wing, MN
NSP Corporate Offices, Minneapolis, MN

Inspection Conducted: October 20-24, 1980

Date of Last Physical Security Inspection: April 28-May 2, 1980

Type of Inspection: Unannounced Physical Protection

Inspectors: J. F. Donahue for
G. L. Pirtle
Physical Security Specialist

11/17/80
Date

J. F. Donahue for
J. J. Madedo
Physical Security Specialist

11/17/80
Date

Approved by: J. A. Hind
A. Hind, Chief
Safeguards Branch

11/17/80
Date

Inspection Summary

Inspection on October 20-24, 1980 (Report No. 50-282/80-17; 50-306/80-17)
Areas Inspected: Included a review of Security Plan; Security Program Audit; Security Organization; Protected Area Physical Barriers; Vital Area Physical Barriers; Lighting; Access Control (Identification, Authorization and Badging); Access Control (Search); Access Control (Escorting); Access Control (Vital Areas); Alarm Stations; Detection Aids; Assessment Aids; Communications; Testing and Maintenance; Compensatory Measures; Power Supply; Response; Locks, Keys, and Combinations; Records and Reports; Followup on Previous Items of Noncompliance; and independent inspection effort. The inspection involved

8012010586

86 inspector hours onsite by two NRC inspectors. The inspection began during the day shift period; 14 inspection hours were accomplished during offshift periods.

Results: The licensee was found to be in compliance with NRC requirements within the areas examined during this inspection except for the following item:

Vital Area Physical Barriers - Access could be gained to two vital areas without going through controlled access points (doors or portals).
(Infraction)

(Details 2.790(d) Information)