Georgia Power Company 230 Peachtree Street Post Office Box 4545 Atlanta Georgia 30302 Telephone 404 522-6060 . Contal tile

October 23, 1980

160121 P1: 56



W. A. Widner Vice President and General Manager Nuclear Generation

United States Nuclear Regulatory Commission Office of Inspection and Enforcement Region II - Suite 3100 101 Marietta Street, NW Atlanta, Georgia 30303

REFERENCE: RII: WAR 50-321/80-28 50-366/80-28

ATTENTION: Mr. James P. O'Reilly

Gentlemen:

Attached is a copy of our October 15, 1980, letter to the Birector of Nuclear Reactor Regulation requesting approval of exceptions taken to certain ANSI standards. These exemptions were requested pursuant to correction of infractions discussed in Mr. J. H. Miller's letter to you dated September 23, 1980.

If you have questions in this regard, please contact this office.

Very truly yours,

for W. A. Hidner WEB/mb


Attachment

xc: M. Manry

R. F. Rogers, III

CFFICIAL COPY

8012080 817



United States Nuclear Regulatory Commission Director of Nuclear Reactor Regulation Washington, D. C. 20555

NRC DOCKETS 50-321, 50-366
OPERATING LICENSES DPR-57, NPF-5
EDWIN I. HATCH NUCLEAR PLANT UNITS 1, 2
PROPOSED CHANGE TO UNIT 2 FSAR COMMITMENTS

Gentlemen:

A recent inspection by the Region II Office of Inspection and Enforcement reported by the regional director's letter of August 22, 1980, noted a failure to comply with certain portions of ANSI 45.2.2-1972 concerning receipt inspection and storage of safety-related materials and ANSI 45.2.13 concerning the handling of requisitions for such materials. In Appendix A and Section 17.2 committed, without exception, to comply with these standards. That commitment was intended to apply only to safety-related equipment and is clarified in the proposed revision to indicate this intent.

In the case of inspections upon receipt (Section 5.2.1 of ANSI 45.2.2) however, a quality control inspection detailed in plant procedures requires a more stringent inspection and provides superior assurance of quality in from the site warehouse and released for use in a safety-related function without this QC inspection. The receipt inspection thus provides only assurance of compliance with commercial terms on the part of the vendor and should not be subject to the requirements of ANSI standard.

The QC inspection upon release from storage also ensures that any damage to pipe ends, etc., which may occur during storage, will be detected and such equipment will be eliminated from use in safety-related systems. Use of pipe protective devices is thereby similarly reduced to a consideration of economics and should not be considered as a safety concern and conducted under the requirements of ANSI 45.2.2 Sections 3.5.1 and 6.4.2

The commitment to ANSI 45.2.13 requires clarification of the definition of a "requisition" as that word is used in plant procedures. A Plant Hatch and should not be accorded to Section 17.2 c the standard's requirements. The change standard.

A timely rev requested so that DUPLICATE DOCUMENT

Entire document previously entered into system under:

ANO 8010240213

No. of pages:

5

he present