

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
248TH GENERAL MEETING OF THE
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

Thursday, December 4, 1980
1717 H Street, N.W.,
Washington, D.C.

The meeting came to order, pursuant to notice, at
8:30 a.m., where were present:

ACRS MEMBERS PRESENT:

- MR. MILTON PLESSET, CHAIRMAN
- MR. J. CARSON MARK
- MR. CHESTER P. SIESS
- MR. STEPHEN LAWROSKI
- MR. MYER BENDER
- MR. DADE W. MOELLER
- MR. WILLIAM KERR
- MR. MAX W. CARBON
- MR. WILLIAM W. MATHIS
- MR. HAROLD ETHERINGTON
- MR. DAVID WARD
- MR. J. C. EBERSOLE
- MR. PAUL SHEWMON
- MR. DAVID OKRENT

DESIGNATED FEDERAL EMPLOYEE:
MR. Raymond FRALEY

8012090090

T

P R O C E E D I N G S

1
2 MR. PLESSET: The meeting will now come to order.

3 This is the 248th meeting of the Advisory
4 Committee on Reactor Safeguards. During today's meeting,
5 the committee will meet with the NRC staff and Metropolitan
6 Edison Company to discuss matters relating to the restart of
7 Three Mile Island Unit 1. It will discuss an proposed
8 interim ACRS report to NRC regarding new safety concepts for
9 future nuclear plant designs. Also it will discuss the
10 status of generic items applicable to light water reactors
11 and hear NRC subcommittee reports on safety-related
12 matters.

13 On Friday the committee will hear reports on and
14 discuss waste management and disposal activities; recent
15 operating experience, particularly the October 17th incident
16 at Indian Point 2, during which a large quantity of service
17 water was released into the containment; meet with the NRC
18 chairman and Commissioners regarding containers for shipment
19 of radioactive materials; the proposed NRC long-range
20 research program; and general design criteria for LMFBRs.
21 And then we will have a discussion with Vepco and the NRC
22 staff regarding the operation of North Anna Nuclear Power
23 Station Unit 2.

24 On Saturday the committee will discuss the
25 proposed ACRS report on BWR hydraulic SCRAM systems, Three

1 Mile Island Nuclear Station Unit 1, NRC waste procedures,
2 and new safety concepts for future nuclear plant designs.

3 The meeting is being held in accordance with the
4 provisions of the Federal Advisory Committee Act and the
5 Government in the Sunshine Act. Mr. Fraley is the
6 designated federal employee for the meeting.

7 It may be necessary for the committee to hold one
8 or more closed sessions for the purpose of exploring matters
9 involving proprietary information.

10 A transcript of portions of the meeting is being
11 kept, and it is requested that each speaker identify himself
12 or herself and speak with sufficient clarity and volume that
13 he or she can be readily heard.

14 We have not received any written statements or
15 requests to make oral statements from members of the public
16 regarding today's session.

17 The first item on today's schedule is a report by
18 the chairman, and I will now make that report. And it will
19 be very brief; I have nothing particularly interesting to
20 report.

21 You may have noted, however, an interim report
22 from the president of the oversight committee of which you
23 all received copies of this morning, and you might want to
24 look at that. I can make a comment on it, but I will
25 refrain from doing so. We have a rather lengthy session.

1 Mr. Fraley wants to make a comment.

2 MR. FRALEY: As you know, at each meeting we try
3 to mention to you any honors received by ACRS members last
4 month. And Dr. Plesset was invited to and did present the
5 Robert Henry Thurston Lecture to the AMSE meeting, and this
6 is an opportunity for a leader in science and engineering,
7 in pure and applied science, to present to the Society
8 stimulating thinking on some subject of broad technical
9 interest to engineering. Unfortunately, we don't have the
10 benefit of those stimulating comments, but we have Dr.
11 Plesset here. I am sure he will contribute to the
12 discussion during this meeting.

13 Congratulations.

14 MR. PLESSET: I didn't expect this kind of
15 accolade -- not "accolade," I would say.

16 (Laughter.)

17 MR. PLESSET: What resulted was I got a piece of
18 metal which I put in my bag, and this caused me to be held
19 up. It showed up on the X-ray scan, and I had to take it
20 all apart. That was the biggest fallout from that.

21 (Laughter.)

22 MR. PLESSET: We are going to consider this
23 morning the report of the ACRS subcommittee on Three Mile
24 Island Nuclear Station Unit 1. I would like to call on Dave
25 Moeller, chairman of that subcommittee, to take over, please.

1 Dave, would you do that?

2 MR. MOELLER: The TMI-1 subcommittee met to review
3 the current status of this nuclear power plant on Friday,
4 November 28th, and Saturday, November 29, 1980. Previously,
5 a subcommittee meeting on the same review had been held in
6 Middletown, Pennsylvania, on January 31 and February 1 of
7 1980, at that time, with Harold Etherington as chairman.
8 Attending the subcommittee meeting just last week were Bill
9 Kerr and Jerry Ray, members of the ACRS, plus the following
10 consultants: J. Buck, I. Catton, M. Keyserling, W.
11 Lipinski, and Z. Zudans. Drs. Buck and Keyserling are
12 human-factors experts, and I am sure the members of the
13 committee are thoroughly familiar with the areas of
14 expertise of the other consultants that I have mentioned.

15 A summary of the major findings and conclusions
16 during the subcommittee meeting, plus the schedule for
17 today's meeting this morning, review of the situation, these
18 things are included as loose handouts. And also in your
19 notebook is a letter on the TMI-1 plant from Mr. Marvin
20 Lewis, a member of the public. And then, in addition, a
21 notice you have just been handed, a letter from GPU to the
22 NRC chairman, dated December 1, 1980, again applying to the
23 restart of the Three Mile Island Unit 1 facility.

24 A detailed NRC staff summary of the status of
25 various licensing actions pertaining to TMI-1 is given in

1 the report NUREG-0680, which, in essence, is the SER for
 2 this plant. For purposes of restart, TMI-1 is being treated
 3 by the NRC as an NTOL, and we reviewed it at our
 4 subcommittee meeting with that approach in mind. At the
 5 time of our meeting and because the SER was written last
 6 June, the NRC staff did not have an up-to-date list of
 7 outstanding or unresolved issues. They have promised to be
 8 able to present such a list to us today.

9 The licensee, however, did present such a list at
 10 the subcommittee meeting. According to him there are nine
 11 items outstanding. And of these, three are in the process
 12 of resolution, with six remaining to be discussed further.
 13 The six unresolved issues were as follows, those that were
 14 mentioned by the licensee: first, the financial status of
 15 the company; second, what the QC list termed was the
 16 "sensitivity of the differential pressure transmitter for
 17 indicating the pressure of the valves of the PORV on the
 18 pressurizer;" fourth was the RC pump services during reactor
 19 building isolation, particularly to assure that only the
 20 right things were isolated and that central service was not;
 21 five, the pressure vessel water level indicator six was the
 22 reactor pressure vessel thermoshock.

23 One of the major impressions that I received from
 24 the subcommittee meeting was a significant way in which the
 25 licensee has turned the Net ED group around. The

1 organization is presented to us, and, indeed, the individual
2 representatives and spokesmen for the licensee showed that
3 they are strongly safety-oriented. They are not only
4 addressing the key issues raised by the NRC, but in some
5 cases they are giving -- in most cases, they are giving them
6 independent reviews in-house and, in some cases, they are
7 setting stricter standards for themselves than those
8 required by the NRC.

9 Examples of what I mean by the "turnaround"
10 include the following: first, the quality of the key upper
11 echelon personnel who have been brought into major
12 leadership positions within the organization; second, the
13 setup they have for reviewing LERs and keeping up to date on
14 operating experience within the industry; third is the
15 in-depth CERL training program that they have established
16 for their operators and associated plant personnel; fourth
17 is their applications of computer technology that they have
18 developed to help the operator know exactly what is the
19 plant status following a trip or during a transient.

20 This includes CRT display in color. And to quote
21 several of our consultants who are familiar with this area,
22 they said it was "better than what is being done at LOFT."
23 And one consultant even used the word that it is
24 "magnificent."

25 At the end of the first day, we itemized those

1 problem areas we thought would be of interest to the full
2 committee. And these issues then, at the end of the first
3 day of our subcommittee meeting were: One, the status of
4 open issues, particularly to get the NRC staff to give
5 their list. Secondly, the managerial and staffing
6 changes that the licensee has implemented; we thought you
7 should hear about that. Thirdly, the training program they
8 have established. And fourth, we thought you should hear
9 something about the applications of human factors that they
10 have considered in the redesign of the TMI control room.

11 We have asked the staff under the first item I
12 mentioned, in addition to citing the open issues, to give us
13 a detailed listing of the various supplements to the SER
14 that are in process, the subjects to be covered in each, and
15 the target dates for publication of each of these.

16 I might mention, too, that FEMA is reviewing the
17 emergency plan for the facility, and they will be issuing a
18 report which, although coming from another federal agency,
19 will in many ways simply for us be a supplement to the SER.
20 We will need to look at it and see what they have said. Of
21 course, the staff will do the same.

22 Following the second day of our subcommittee
23 meeting, we again polled the consultants and ACRS members
24 present to find out again what the key issues were which
25 should be brought to the attention of the full committee.

1 Those items were as follows: first, the RPV thermal
2 fracture mechanics; secondly, operating experience,
3 including the feedback of LERs; and the ties of the licensee
4 to NSAC and INPO; thirdly, the reactor diagnostics again to
5 have you hear about the CRT displays of plant transient
6 conditions; and fourth, the consequences of DC power
7 failure. Jesse, we asked them specifically to address that
8 today.

9 Five was the explanation of the treatment of the
10 pressurizer heaters. What I mean there is the licensee
11 stated in one place that these are not necessary for safe
12 reactor operation, and yet in another place they go into
13 extensive deliberations on how they will assure emergency
14 power to the pressurizer heaters. That seemed a little
15 twisted. One battling the other, in a sense.

16 These comments probably could be addressed as well
17 to the staff, but they treated the heaters in a major way
18 but they never talk about the sprays. And we felt that
19 maybe the sprays were as important as the heaters in certain
20 situations. So we have asked them to look into that today
21 or to tell us about it today.

22 The subcommittee did hold a closed session on
23 security. We are hoping to handle this area so that it
24 would not have to be covered again by the full committee.
25 And as a result, no formal presentation is scheduled today

1 on security, plant security. But obviously, if you have
2 questions, they are ready to respond to them.

3 Other questions that should be mentioned include:
4 One, there has been some confusion relative to which
5 questions or issues are being applied or raised relative to
6 TMI-1, which of these are unique to that plant and which are
7 generic. And that is not always easy to keep clear in your
8 mind, and I think both -- well, the licensee has clearly
9 pointed this out and the staff has acknowledged it.

10 Secondly, which requirements are strictly restart
11 items versus which should be completed by a certain date.
12 This is analogous to my first item. For example, can TMI-1
13 always simply meet the target dates enumerated for other
14 plants, or must they have the changes completed prior to
15 restart even if the date for implementation on other plants
16 is after the proposed date for the restart of TMI-1. As I
17 say, we hope to get some clarification on that today.

18 In response to comments that Dr. Okrent had made,
19 we asked several questions, and I will tell you the
20 questions and the answers we received. Number one, "What is
21 the licensee doing relative to degraded core cooling? Are
22 they looking at filtered vented containment and so forth?"
23 The answer is: "No. They have done nothing on this up to
24 the present time."

25 Secondly, "Should TMI-1 be evaluated relative to

1 high population density similar to the approach used by the
2 staff for Limerick and Zion and Indian Point?" The staff
3 said the population at TMI, the density, was a factor of
4 three less than that for these other plants and that they
5 have not gone into such a review for TMI-1.

6 Thirdly, "What is the relationship of TMI-1
7 relative to IREP?" And the answer to that was that TMI-1
8 has not been selected for this type of review. Crystal
9 River was the first plant selected for this review; and
10 that, they said, was a research effort. The next phase will
11 include four more plants, including one B&W plant, but not
12 including TMI-1.

13 Fourth -- this is not a question that Dr. Okrent
14 asked but it is one that I thought you would be interested
15 in. The current plans on TMI-1 do not call for the reactor
16 pressure vessel head to be removed prior to restart.
17 Therefore, the reactor could come back on line without the
18 fuel that will have sat there for roughly two years by the
19 time they restart, having been closely examined. The
20 licensee has indicated, however, that they have been very
21 careful in maintaining the water primary coolant water
22 chemistry and that they do not think this is a major point.

23 Number five, compliance with Reg Guide 1.97. We
24 attempted to go into that in detail, but we found there is
25 confusion here due to the status of revisions of Reg Guide

1 1.97, particularly the letter which the committee wrote on
2 the subject last month. They did enumerate 12 areas of
3 current disagreement with Reg Guide 1.97, and these are
4 enumerated in the summary of the subcommittee meeting,
5 prepared by Richard Major, which was a loose handout in your
6 notebook.

7 The sixth, although not from our list, there was
8 much discussion about mixing of hydrogen within the
9 containment, whether such mixing can be assured following
10 venting through the pressurizer or through the new remotely
11 operated valves that will be on the top of the candy canes
12 and perhaps through the RPV vents following an accident.

13 There was a question about whether the way in
14 which the gas would be released into containment would
15 enhance mixing or whether it would let it pocket in
16 localized higher concentrations. Several of our consultants
17 discussed the fact that the upper dome, upper portion of the
18 dome of the containment seemed or could be viewed as an area
19 in which little mixing would take place and might present
20 problems.

21 Today what we are going to do is go through the
22 items that I have mentioned that the consultants and
23 subcommittee thought were worthy of your attention. I would
24 say that my concert of today's meeting is that it is a
25 progress report. I am hoping that after the committee has

1 heard this progress report, that they will be willing to
2 discuss what they consider to be the issues, and that we
3 might prepare a written report to the NRC chairman,
4 presenting the status as we see it of the restart of TMI-1.

5 I believe such a report would be very helpful to
6 both the licensee and to the staff. It would not be a
7 sign-off; it would simply be an enumeration of what we
8 consider to be the major points and where they should place
9 their efforts.

10 At the subcommittee meeting, as I mentioned, both
11 Mr. Kerr and Mr. Ray -- who is not here -- both of them were
12 at the subcommittee meeting. So, Mr. Chairman, I would like
13 to call on Mr. Kerr for comments, and then I would also like
14 to ask Harold Etherington if there are any items that he
15 wanted to mention from his subcommittee meeting earlier this
16 year.

17 Mr. Kerr.

18 MR KERR: I have no additional comments, Mr.
19 Chairman.

20 MR. MOELLER: Then Mr. Etherington.

21 MR. ETHERINGTON: The previous subcommittee
22 meeting was held about 10 months ago, and Dr. Moeller's
23 report supersedes and updates, I think, everything that was
24 discussed at that meeting. So I have nothing to add.

25 MR. MOELLER: Thank you.

1 Then, Mr. Chairman, I have two -- let me ask are
2 there questions and comments from members of the committee
3 on it? Dr. Okrent?

4 DR. OKRENT: You indicated that this is an interim
5 review. When do you anticipate that the staff and the
6 utility would be ready to come in to the committee for what
7 they would hope would be a final review by the committee?
8 And what do you see are the matters that remain between now
9 and then?

10 MR. MOELLER: The licensee stated at the
11 subcommittee meeting that they were hoping, you know, to
12 have the committee write a final sign-off letter on the
13 plant for restart. What I am saying here is these are my
14 opinions, and those that I believe are supported by the
15 subcommittee members, that this at best could be a progress
16 report. The schedule date given to us by the licensee for
17 restart of the plant was, as I recall, August of 1981.

18 I think what we need -- we will need certainly
19 another subcommittee meeting, in my opinion, to review, as
20 you said, whatever these essential issues are before we can
21 wrap the thing up, if indeed we do. I believe personally
22 that we need the supplements to the SER which are in
23 progress. We need to have those in hand to see them, to
24 read them and digest them. We also need to hear today and
25 perhaps subsequently from the staff what they consider to be

1 the current status of the plant, what are the remaining
2 issues to be resolved. We did not obtain that information
3 from the staff at the subcommittee meeting.

4 I think the major issues will be the list that I
5 mentioned at the end of the first day and at the end of the
6 second day that we enumerated because we were wanting to
7 bring to the attention -- not in every case -- but we wanted
8 to bring to the attention of the full committee those issues
9 that we considered to be perhaps unresolved at this stage,
10 plus some of the items that we are asking be brought to your
11 attention this morning, what we consider to be significant
12 accomplishments on the part of the licensee. So they are
13 not all negative. Some of them are. And those would be the
14 ones that we would want to resolve before we complete our
15 review.

16 Is that helpful?

17 MR. OKRENT: Sort of. On the agenda, is there
18 today a time for other questions? It wasn't clear to me.

19 MR. MOELLER: Certainly. There always will be.
20 Right.

21 You have, incidentally, two agendas. One is the
22 one that is in your notebook, which is the proposed agenda
23 that we came forth with, and then we have handed to you
24 loosely with a letter of December 1 from Mr. Wallace, a PWR
25 license manager at GPU. We have an agenda that the licensee

1 has proposed. They are essentially the same, and we will
2 probably follow the licensee's agenda, because this is what
3 would make it most convenient; this is the sequence that is
4 most convenient for them to follow. And in line with our
5 policy of always making it as favorable and simple for a
6 licensee, we will follow their agenda.

7 Are there comments or questions?

8 (No response.)

9 MR. MOELLER: Well, if there are none, the people
10 who are here -- Mr. Silver is here for the NRC staff and
11 will be chairing and organizing and handling their
12 responses. And Bob Arnold is here from Met Ed, or GPU, and
13 he will be coordinating the licensees' responses, ably
14 assisted by Phil Clark. If that is the situation, we can go
15 on into the formal review of the restart. Is that all
16 right? We'll just go right into the sequence. Let's begin
17 then.

18 Item 1, looking at the agenda proposed by the
19 licensee, begins with NRC staff. And we will first have a
20 review of the open items in the SER. Harley Silver.

21 We will, of course, give the GPU group a chance,
22 when they first appear, to not only comment on what the
23 staff says but to comment on my opening statement.

24 MR. SILVER: Good morning.

25 (Slide.)

1 What I have done on the first two tables is to
2 rearrange the open items on the status of the -- not
3 rearrange; I listed the items differently, and I show what
4 is the current status of each of these items. I did, of
5 course, listen to Dr. Moeller's description of the open
6 items as presented by the licensee last week. And indeed,
7 these are among the open items and are quite possibly the
8 principal ones at the moment. But we did arrange or list
9 the items which are perhaps many of them not major in the
10 SER.

11 Some of the licensee lists open items are not
12 shown as open on ours because they were not open. For
13 example, the containment isolation of the reactor coolant
14 pump services was not at the time of the writing of the SER
15 considered an open item by us. We simply took a position
16 that they should be isolated. We did note, however, that we
17 would reevaluate this as we went further along in our
18 deliberations on the need for the pumps themselves. And in
19 fact, we are reconsidering these requirements right now.
20 So, in effect, they are open but not on this list.

21 Would the committee desire that I read down each
22 one?

23 MR. KERR: Mr. Silver, from what you have said, I
24 am not sure whether that is the current list of open items
25 or not. Is it?

1 MR. SILVER: This is the current status of the
2 list in the SER. There have been additional requirements
3 since then.

4 MR. KERR: I thought what we were promised at the
5 subcommittee meeting was a list of open items as of this
6 time. Do we get that later?

7 MR. SILVER: I have not had the opportunity, nor
8 do I believe has any other of the staff, to examine the
9 NUREG-0737 items or, in some cases, the 0694 items, to
10 ascertain what the actual status is at this moment. As far
11 as the 0737 items, the licensees, as are all licensees, is
12 required to respond, I guess, about the middle of December.
13 We have not, of course, seen that response.

14 MR. KERR: I don't understand your answer. I
15 thought open items referred to those -- well, I guess I
16 don't know what the status of the open items is. And how
17 can we tell? Or should we as a committee not know?

18 MR. SILVER: There is no reason you shouldn't
19 know, obviously.

20 MR. KERR: Maybe I should rephrase my question:
21 Do you think there is anyone who knows what the open items
22 are at this point?

23 MR. SILVER: The total list of items which are not
24 resolved of the items in the order and items which have
25 subsequently been added, not with total certainty, I would

1 have to say at this time.

2 MR. KERR: Thank you.

3 MR. SILVER: Insofar as the SER items, would it be
4 desirable to read down this list?

5 MR. MOELLER: I think so, yes, briefly on each one.

6 MR. SILVER: There is an analysis of anticipatory
7 fill due under Bulletin 79-05R. which we are awaiting the
8 licensee submittal on. I have indicated on this list
9 whether the item as it is is in fact a restart item. And as
10 you will see, most of them are.

11 There is a checkout procedure due on reactor
12 anticipatory trips, which will be validated during the start
13 of checkout. That is not an item which we expect to have
14 now or to be able to write off now, in any event, until the
15 checkout for restart is underway.

16 There is a general requirement for tech spec
17 changes. The licensee has in fact submitted draft tech spec
18 changes which are being reviewed by the staff. There have
19 not been, of course, formal submittals by the licensee for
20 tech spec changes which would require license amendments.

21 Inadequate core cooling procedures are in review
22 at the moment. A test exercise required as part of the
23 emergency planning requirement. And that will, of course,
24 be done prior to restart and has not yet been redone.

25 The emergency plan is in fact being reviewed at

1 this time. And when I discuss the schedule for SERs, or
2 supplements, rather, I will again discuss that. As far as
3 the order is concerned, the direct requirements of the
4 order, the only open item is the exercise. We are reviewing
5 the licensee's plan in accordance with NUREG-0564, which is,
6 as I said, well underway.

7 The detailed design of the filter under the
8 separation of the units order item is scheduled by the
9 licensee, as I understand it, in the middle of next year.
10 This does not involve an actual implementation but receipt
11 and review of the design prior to restart.

12 The plans for low-activity storage, solid rad
13 waste. The licensee has submitted some information which,
14 it appears, is not adequate. And we will indicate shortly
15 what we will require, what additional information we require.

16 The management item has changed a bit. Let me
17 explain that for a moment. We have issued, I believe it was
18 last Friday, a supplement No. 1 to our evaluation covering
19 our reevaluation of the licensee's management capability.
20 This was a Xeroxed version. Unfortunately, the number of
21 copies we were able to make was rather limited, and I think
22 the ACRS has not been supplied copies. I do have half a
23 dozen copies or so, which I will be glad to distribute. It
24 is a fairly lengthy document, in any event.

25 These items are a condensation of the items that

1 we now feel are open in the licensee's -- in the management
2 area.

3 MR. KERR: Do "unlicensed personnel" refer to
4 unlicensed personnel in management?

5 MR. SILVER: No. All unlicensed personnel on the
6 station, in the station.

7 The long-term operator training has to do with
8 verifying that indeed there are plans for training operators
9 beyond the operators that will be needed for restart and for
10 the immediate future.

11 Facility procedures again is essentially a
12 continuation of an existing item. We had a rather long list
13 of procedures. We had not reviewed it, and it is much
14 shorter now.

15 Health physics. Many of these items are a result
16 of an extensive inspection performed by I&E at the site this
17 past summer. And there are a number of items contained in
18 this. The Q list, as was mentioned by Dr. Moeller, is
19 another item.

20 MR. KERR: It wasn't clear to me whether you said
21 as a result of your recently issued supplement these are
22 still open items or whether some of these had been covered
23 in the supplement.

24 MR. SILVER: These items are open as a result of
25 our review of the licensee's current plan. I understand

1 there is an amendment due any day now which, parts of which,
2 may in fact close out some of these items. I really don't
3 know if that is so or not.

4 MR. KERR: Thank you.

5 MR. SILVER: Order item 7 in the original order of
6 the Commission is a financial item. And the open item there
7 is receipt of a revised financial plan from the licensee
8 which, if I remember, is due fairly soon as well -- but
9 again, based on verbal commitments from the licensee. I
10 don't know when that is due or when the item will be closed.

11 MR. MOELLER: Could you take this first page of
12 open items and group them several ways for us? Which are
13 really significant? Which are in contingency where there is
14 basic disagreement? And which simply are a matter of
15 further review to just be sure all of the loose ends are
16 covered?

17 MR. SILVER: Let's try the last first, eliminate
18 the fairly simple ones or the ones which we would not expect
19 to have a result now in any event. These include, in
20 general, procedure items: the tech spec changes; perhaps in
21 this case, the inadequate core cooling procedures -- I can't
22 tell whether it is in dispute or misunderstanding between
23 the licensee and ourselves -- but the item is being
24 discussed. Further meetings will be scheduled. I am sure
25 it is easily resolvable, but it has not yet been resolved.

1 These are items where essentially we want to see
2 long-term designs to convince ourselves that in fact the
3 item will be taken care of when it needs to be and are not
4 in themselves a requirement for a restart.,

5 The management issue, in general, of course, is
6 one the Commission seems to be quite interested in, and I am
7 sure we will hear more about this from the licensee today.

8 MR. MOELLER: It is mainly a case of reviewing the
9 plans? It is not that they are objecting?

10 MR. SILVER: I see no intrinsic dispute.

11 MR. MOELLER: The only item on the first page that
12 really may give problems is the inadequate core cooling
13 procedures.

14 MR. SILVER: I think that's correct. The
15 financial situation, of course, is obviously an ongoing
16 problem.

17 MR. PLESSET: Would you explain the very first
18 item? What does it mean: "The analysis of anticipatory
19 fill"?

20 MR. SILVER: As I recall it, we requested the
21 licensee to further analyze the possible difficulties of
22 anticipatory filling of the steam generator as to whether or
23 not that will or can cause additional problems.

24 MR. PLESSET: I still don't understand it.

25 MR. SILVER: My recollection is somewhat hazy. I

1 am not sure there is anyone here at the moment on the staff
2 who --

3 MR. NOVAK: I think, Dr. Plesset, the point was
4 whether the natural circulation characteristics of the plant
5 would be markedly changed if you went to a water solids
6 secondary side of the steam generator; in other words, if
7 you filled the steam generator, how are you affecting the
8 natural circulation flow characteristics?

9 One of the concerns in the earlier bulletin was
10 this. If you look on the left-hand side, I think it is
11 7905-B1. It is one of the things we were immediately
12 interested in at that time, was to better understand the
13 behavior of the plant under natural circulation where the
14 level of water on the secondary side could go above the
15 normal level.

16 MR. MARK: This is in no way special and specific
17 to TMI-1?

18 MR. NOVAK: No. It would be generic to a
19 once-through steam generator.

20 MR. SILVER: Many of these items, of course, are
21 applicable to many plants; in fact, all plants. There is a
22 benefit to having the deputy director of the task force
23 present.

24 (Slide.)

25 Continuing the list of open items, the first item

1 involves procedures having to do with the pressurizer
2 valves. And again, we are awaiting revised procedures
3 there. Valve position indication, which I believe is one of
4 the items GPU has indicated.

5 MR. KERR: What is the significance of No. 8?

6 MR. SILVER: It's the date, August 9th order, and
7 the corresponding number in the safety evaluation. These,
8 of course, are the Lessons Learned numbers. And, of course,
9 there is another set of numbers having to do with
10 NUREG-0660, which is not indicated here.

11 Our concern on this one is the ability of the
12 position -- they are not position indicators, but really
13 flow indicators -- in the safety valve tailpipes to indicate
14 that the valves are indeed open. And if there is two-phase
15 flow present, we feel the licensee is not fully justified
16 that these elbow taps will in fact indicate a flow or a flow
17 which will be of fairly low velocity in this situation.

18 Inadequate core cooling, the wording of this --
19 there may be an error here in fact. I am not sure that
20 there is an open item having to do with existing
21 instrumentation, but rather with the item basically
22 involving the reactor water level instrumentation.

23 And the licensee, of course, has taken the
24 position that such a device is neither desirable nor
25 necessary. And ours, of course, comes down on the other

1 side of the fence, basically.

2 Containment isolation, this item dealt with
3 receiving additional detailed design information rather than
4 the one indicated by the licensee. But in fact, the
5 question of reactor coolant pump services isolation is again
6 open.

7 Systems integrity has to do with the leak test of
8 this involved leakage measurement procedures, as I recall.
9 We are still awaiting receipt of those.

10 Plant shielding in the event of introducing
11 radioactive materials into lines not normally handling such
12 fluids is in progress. I don't think the licensee felt it
13 was complete, and we are probably going to say it is not, as
14 well. This is a multiphase task, and we can probably
15 improve our report on it but, again, probably not completely.

16 The next item has to do with essentially a
17 long-term -- detailed design of long-term modifications.
18 And we understand, from the licensee, that we can expect a
19 submittal in January.

20 The post-accident sampling system, the licensee
21 has not fully justified use of the existing system until the
22 long-term design is implemented.

23 As far as radiation monitor range, the licensee's
24 intention is to use the long-term system as defined in the
25 Lessons Learned report prior to restart. If indeed there is

1 a delay in receipt of equipment, the procedures have not yet
2 been submitted, will be used. The matter of procedures and
3 training of personnel having to do with iodine measurement
4 have not been received.

5 The review of analysis for inadequate core cooling
6 and review of the procedures is in progress.

7 Procedures connected with the onsite technical
8 support center are in progress, as well. This mysterious
9 nomenclature refers to the additional item 4, having to do
10 with high-point vents in the reactor coolant system. We
11 have requested a detailed design and analysis of the
12 conceptual arrangement proposed by the licensee. We are
13 told that is scheduled for July.

14 The licensee has committed to installing high-point
15 vents in the candy canes and the reactor vessel head,
16 although I think there is a question of whether the head
17 vents will in fact be installed prior to restart. As far as
18 the licensee is concerned, there is a question.

19 MR. LAWROSKI: With respect to item 2.1.8.a, does
20 that include also sampling and checking out of the
21 containment samples?

22 MR. SILVER: Yes. This is primary water
23 containment liquid.

24 MR. LAWROSKI: One of the things that was very
25 bothersome was erratic numbers obtained for oxygen in

1 hydrogen contents. It made it difficult to make a
2 meaningful calculation. I wonder what had been done, so far
3 as you can with the system, whether oxygen was reading 21.9
4 but not waltzing all over the scale.

5 MR. SILVER: I don't think I can address that now,
6 but we will certainly examine it.

7 MR. MOELLER: I think the licensee can comment.

8 MR. LAWROSKI: .9, I should say.

9 MR. MOELLER: Of the ones on the second page,
10 which ones are significant?

11 MR. SILVER: Again, let me start at the top.
12 Procedural items. I think this one is significant, but,
13 again, I would imagine that an analytical justification can
14 be presented and simply has not yet been. The question of
15 reactor water level, I believe, is a significant one.
16 Containment isolation, certainly we would want to see the
17 detailed design, and in fact, if the reactor coolant pump
18 services -- well, that position is in dispute and should be
19 resolved quite shortly. I am not saying I expect that it
20 should be resolved. It will be resolved prior to restart.
21 This is a procedural item that I think fairly significantly
22 differs from the general run of procedure requirements. The
23 plant shielding, I think we would want to see more
24 information prior to restart than we have now.

25 MR. LAWROSKI: When did you ask for more?

1 MR. SILVER: In the safety evaluation is a
2 statement of our position. And that, of course, was in
3 June. The licensee submitted revised or additional
4 information within the last month or two; I don't remember
5 the exact dates. And again, it is a phased program that the
6 licensee has defined for us. So I think they are aware of
7 our requirements.

8 MR. LAWROSKI: The thing I have in mind is
9 wondering how many of these things -- they were requested
10 only relatively recently. One could have expected
11 reasonably to have been asked such questions a lot earlier.

12 MR. SILVER: I think that is not the case. I
13 think there is no question about the requirements.

14 MR. LAWROSKI: Frequently, the NRC staff doesn't
15 say, "It is going to be this way," until a lot of time
16 passes, and then suddenly they get their letter out.

17 MR. SILVER: Yes, that has happened.

18 MR. BENDER: There are a number of things on here
19 that came out of the TMI accident experience. If I were to
20 go down through that list and ask how many of these
21 requirements are not imposed on operating reactors, could
22 you give me an answer?

23 MR. SILVER: A great many are.

24 MR. BENDER: I didn't say how many are. I want to
25 know how many are not.

1 MR. REID: Those requirements are -- in fact, the
2 nomenclature on the 2.1 items come from 0578, which is a
3 category A Lessons Learned requirements, which are and have
4 been imposed on all operating reactors.

5 Now, if you recall, those again were a phased
6 implementation program. Many were due January 1, 1980.
7 Some of those are in that category. Many of those were also
8 due January 1, 1981. Some of the January 1, 1981,
9 requirements are still January 1, 1981. But some in the
10 latest requirements for the action plan have changed in
11 schedule to a later date. So I would say all of them have
12 been required of operating reactors, but the timing of some
13 of the longer-term ones may or may not be related to restart.

14
15
16
17
18
19
20
21
22
23
24
25

1 MR. BENDER: I didn't understand that last
2 statement. The timing may not be related to restart?

3 MR. REID: I mean, in the latest action plan,
4 NUREG-0737, the implementation requirements for operating
5 reactors, some of the January 1, 1981, requirements of 0578
6 may now be due beyond the projected date of TMI-1. However,
7 these requirements were requirements under the Commission's
8 order for TMI-1.

9 MR. BENDER: I am not quibbling about that. It
10 seems to me that there should be some consistency in the
11 Commission's policy, and I am trying to find out whether
12 there are inconsistencies. And I am not sure that I have
13 learned, but I will not try to explore the matter further.

14 MR. MOELLER: Mr. Chairman, I think to wrap up
15 this stage of the staff's presentation we should ask them
16 for a written report summarizing this item, because I think
17 this approach has been inadequate. I think that Mr. Bender
18 is absolutely correct.

19 It must be extremely confusing for a licensee to
20 try to figure out which requirements are due on what date.
21 For me, as Subcommittee Chairman, I would like to see a
22 listing of the requirements.

23 I thought the NUREG-0680 did a good job in showing
24 everything required. But I would like to see a list of the
25 requirements that are still open on this plant, what the

1 source of each of those requirements is. I would like to
2 see them divided into those that are significant and those
3 that are not significant. I would like to see them further
4 divided into those which are in contention and those which
5 are simply a process of reviewing more paper to just simply
6 assure that the item is resolved.

7 I think we should request this in writing, because
8 unless we have it as well as a statement at the beginning of
9 the listing of what is the staff's policy, as Mr. Bender has
10 requested -- because only then can we really tackle this
11 situation or this plant status and really come to any sound
12 conclusions.

13 I think when you hear from the Licensee you will
14 find that they have very diligently attempted to group these
15 things in a meaningful way. I find this review here far
16 from what I need as Subcommittee Chairman.

17 MR. PLESSET: You have heard Dr. Moeller's
18 request. How long would it take to give him what he wants,
19 this written report, in other words?

20 MR. REID: Well, let me give a little bit of the
21 background. I think part of the difficulty in defining what
22 we mean by open items is that there are four different
23 sources of open items.

24 First, there is the Commission's order. Mr.
25 Silver was addressing those items that are open related to

1 the Commission's order. Within that, within the
2 Commission's order the referenced the bulletins, NUREG-0578;
3 and also laid out some other specific requirements: the
4 emergency planning, management, financial, that sort of
5 thing.

6 Now, in addition to the Commission's order --
7 these are the open items in the SER, and that is what the
8 SER-0680 addresses. There are the additional requirements,
9 which have been defined as those required of an NTOL. Now,
10 the requirements for an NTOL do overlap many of the
11 requirements that are in the Commission's order. Those
12 requirements have been identified in a letter to the
13 licensee dated November 25th. That is in the process of
14 being distributed.

15 That represents a total of about 15 additional
16 requirements. Those are -- that would be required for
17 restart.

18 A third source of requirements is the action plan
19 requirements under 0737, NUREG-0737. Many of the action
20 plan requirements also overlap those of 0694 and the
21 Commission's order. The action plan requirements, however,
22 are dated requirements, and those that would be required for
23 restart will be those for which the due date for all other
24 reactors occurs before the restart of TMI-1.

25 We can list the dated requirements based on the

1 anticipated date of the restart of TMI-1, say August of
2 1981, as open items or not. In other words, I think we can
3 list those. If we assume other dates, then the list will
4 vary. So that will always create some degree of confusion
5 with respect to the restart requirements for TMI-1.

6 MR. KERR: I think it is assuring, reassuring,
7 perhaps, to learn why we are so confused. It would also be
8 helpful if we could be given some information that would
9 unconfuse us. But perhaps that is asking too much.

10 MR. PLESSET: It might be asking a lot, but I
11 think it is something we ought to try to get anyway.

12 Do you see the point of Dr. Moeller's request?

13 MR. REID: Yes, I see the point, and I think we
14 should be able to provide that in, say, two weeks.

15 MR. MOELLER: Simply, I would urge you to choose a
16 date. Choose August the 1st, September the 1st, whatever it
17 is, tell us what the date is and tell us what will or will
18 not be required.

19 MR. BENDER: I don't have any argument about two
20 weeks. It sounds to me like the staff is confused. If it
21 is going to take two weeks to tell us this kind of
22 information, you probably don't know it. And I would like
23 to know whether you really do know it or not.

24 MR. REID: I think we know the requirements.

25 Let me add one additional factor. In the

1 clarification document, NUREG-0737, some of the requirements
2 that are defined there by the numbers listed there have been
3 changed from those that were listed in 0578. We are going
4 back to review those requirements to determine whether or
5 not they need to be -- we need to reassess any of the
6 assessments we have previously made on TMI-1, so that they
7 will meet the same requirements as any other operating
8 reactor.

9 We have the listing of all of the requirements out
10 of NUREG-0737, the first column -- I just want to show you
11 that we have performed such listings. On the left is a
12 group of requirements that is included in the Commission's
13 order.

14 The second column, which is a shorter column, is
15 those additional requirements out of 0694. And on your
16 right are the dated requirements out of NUREG-0737. Now, we
17 could give you that list right now, but we have to back out
18 then all of those that are open in the left-hand column, and
19 that is the only work we have to do.

20 MR. BENDER: I hate to extend requests that seem
21 like they involve a lot of work, but I think it would be
22 very useful if the staff would take one selected example
23 from some other place than TMI and give us the same
24 information concerning one exemplary plant of the B&W class,
25 just so we can see what the relative treatment really is for















IMAGE EVALUATION
TEST TARGET (M1-3)





**IMAGE EVALUATION
TEST TARGET (MT-3)**



1 another operating reactor.

2 I think we would know a lot more than just having
3 a current list. And if I could ask for that, Mr. Chairman,
4 I think it would be helpful to us.

5 MR. PLESSET: I think that would be useful. I
6 would hope, since you are going to take two weeks, that the
7 list would be self-contained, we wouldn't have to go to the
8 library and read off the various NUREG's what each item
9 really meant. That would help.

10 MR. SILVER: Surely.

11 MR. PLESSET: That's for both lists, both for the
12 general B&W plants and in particular for TMI-1.

13 MR. REID: Yes. That's why we didn't plan to
14 present that slide. It is only an indication of bulk, not
15 an indication of substance.

16 MR. KERR: I am glad to have seen that slide. That
17 makes things a lot clearer to me.

18 (Laughter.)

19 MR. MOELLER: Mr. Chairman, we are slipping on
20 time. Could we quickly do the other items, the ASLB
21 contentions and the schedule for the supplements?

22 MR. PLESSET: Yes.

23 MR. LAWROSKI: What about the integrated control
24 system for this plant? Is it similar to Crystal River or
25 Rancho Seco?

1 MR KERR: It is a standard integrated control
2 system for B&W plants, so far as I know. And there may be
3 some differences in detail, but I think it is significantly
4 the same control system.

5 MR. LAWROSKI: Then it has been looked into from
6 the standpoint of occurrences at Crystal River and Rancho
7 Seco?

8 MR KERR: I can't answer that question from
9 personal knowledge.

10 MR. SILVER: They responded, the licensee
11 responded, to a bulletin issued to all plants.

12 MR. LAWROSKI: Has he? Are you satisfied with the
13 response? I didn't see anything on that.

14 MR. SILVER: Again, this applies to basically the
15 August 9th order. Again, that would be in the category of
16 items applicable to all plants, as opposed to those required
17 specifically for TMI-1 restart.

18 MR. MARK: I believe there has been some
19 overlapping with 0578 mentioned in the order and 0737, which
20 in some respects supersedes 0578, let's say as the date for
21 item X. Which date takes precedence with respect to TMI-1?

22 MR. SILVER: This is a question that has not been
23 fully resolved.

24 MR. MARK: The applicant can't help you resolve
25 that very well.

1 MR. SILVER: Can or cannot?

2 MR. MARK: Cannot.

3 MR. SILVER: This is true. It should be a
4 Commission staff decision.

5 There is a question, of course, of legality
6 involved. The order is quite specific in referring to
7 0578. In general, the date changes in 737 are reliefs, and
8 it is not entirely clear whether it is intended that that
9 applies to TMI-1 or not. I am sure the licensee will think
10 it should, and they may be right.

11 MR. MARK: I rather think it should. The only
12 source of absolute decision would be some representative of
13 the Commission itself.

14 MR. SILVER: Perhaps so. This has not been
15 resolved, as I stated.

16 If I could go out of order one item and talk about
17 our supplement, it might be a little simpler.

18 (Slide.)

19 We did issue, as I mentioned, a management
20 supplement on November 28th. It presumably will require an
21 additional supplement to close out those issues which are
22 still open.

23 Emergency planning, we are expecting two
24 supplements, essentially. The staff portion dealing with
25 on-site emergency preparedness is expected on December

10th. That is a close thing, but should be on or very close
2 to that date.

3 The FEMA portion dealing with off-site
4 preparedness is scheduled to be published by January 5th. A
5 supplement dealing with financial qualification is not
6 specifically scheduled, pending receipt of the licensee's
7 financial plan. Again, the last I heard that plan was
8 scheduled for receipt, if I recall, this week or next. And
9 we have committed to the hearing board that we will issue a
10 supplement eight weeks after receipt of all information on
11 the subject.

12 Again, this will probably not be a conclusive
13 finding, because of the ongoing financial situation. But it
14 will certainly be an update.

15 The financial qualification, again because of the
16 lack of information at this moment, we do not have a
17 schedule for that item. There are additional supplements or
18 documents which are not directly related to the order, but
19 which will be issued as follows:

20 A supplement covering the control room design,
21 covering our review of the licensee's control room design
22 from the human factors standpoint, will be issued in
23 January. Environmental qualification of equipment, in
24 response to Bulletin 79-018, as I remember the number, is
25 due in February for this plant and all other plants as

1 well.

2 An evaluation of the licensee's response to the
3 NUREG-0737, a letter which I believe is required -- a
4 response is required 45 days after receipt of the letter;
5 would put it about mid-December. That is not scheduled, of
6 course, pending an evaluation of that response as to its
7 completeness and so forth.

8 Are there any questions about this slide?

9 MR. MOELLER: There appear to be none.

10 MR. SILVER: Insofar as contentions, what I have
11 done -- and this will be in several dissimilar-looking
12 pieces, because they were assembled in different places -- I
13 have been vacationing in central Pennsylvania lately -- I
14 have listed the contentions more or less in the groups that
15 we have previously identified for the Subcommittee, namely
16 design and analysis --

17 MR. MOELLER: Excuse me. Do we have copies of
18 that?

19 MR. SILVER: I'm sorry. I believe there are
20 copies.

21 In any event, the arrangement is design and
22 analysis items, separation of the units, management,
23 financial and emergency planning, which encompass the
24 major subdivisions of the hearing.

25 Under design and analysis, which is somewhere in

1 the middle of this, is about where we are in the hearing
2 now, what I have done is simply listed the items in a
3 sequence which had been recommended for the hearing by the
4 licensee, from which we had departed somewhat. But the
5 sequence, of course, is not especially important.

6 The groups, again using grouping-type headings:
7 natural and forced circulation. This nomenclature, like
8 UCS-1 and 2 and Sholly-3, is the number of the contentions
9 for reference. You may want to read the contention in our
10 testimony.

11 And the thrust of the contention itself is
12 indicated by a relatively short phrase. Again, that's the
13 thrust of the contention and not of anyone's testimony in
14 regard to the contention.

15 Also, I have indicated Board questions in various
16 places in this list, which essentially are akin to questions
17 in the hearing. That is, the Board has raised questions
18 which the parties are obliged to answer.

19 MR. MOELLER: On which of these -- roughly, could
20 you give us a percentage breakdown on how many the staff has
21 completed, where the staff has completed its testimony or
22 its paperwork to support the testimony, versus those which
23 the staff really is not complete on yet?

24 MR. SILVER: The staff has filed testimony, I
25 believe, on all of the items on this page. And I believe

1 essentially -- well, not quite all of the items in the
2 design and analysis section on the next page. I can -- I
3 will come to that.

4 We have not yet filed testimony on management
5 items, on financial items, or on emergency planning items.

6 MR. OKRENT: When you file testimony to a Board,
7 do you send copies to the ACRS?

8 MR. SILVER: Not normally. This is somewhat out
9 of sequence. Normally an ACRS meeting and letter, of
10 course, is complete by the time of the hearing.

11 MR. OKRENT: That wasn't my question.

12 MR. SILVER: I understand. We have not done that
13 that I am aware of. We have one copy of the staff testimony
14 with us. Is that correct, Bob?

15 MR. REID: Yes.

16 MR. SILVER: We will be happy to leave it here.
17 Unfortunately, one is not much help.

18 MR. OKRENT: Mr. Chairman, I raise the question as
19 a general point. There was considerable exchange of
20 information between another Board and the staff on the
21 question of reliability of A.C. power, and there were in my
22 opinion important safety considerations involved here. I
23 don't find it to be an adequate method of being informed in
24 this regard to have to look at the periodic issuance of
25 positions by the ASLB to see that they may have done

1 something in this regard, and then to have to go back to see
2 what may or may not have been said.

3 I would suggest that we ask our Executive Director
4 to develop some way of at least having the office obtain a
5 copy of submissions by the staff to hearing boards that deal
6 with technical safety issues, and then a mechanism for
7 deciding whether or not all of the Committee members should
8 get it, or at least they are made aware of it or something
9 of this sort.

10 This is a whole arena of safety of which in fact
11 we hear by chance. And I think this is in fact not the way
12 it should be.

13 MR. PLESSET: Help me in one respect. We do not
14 get these things?

15 MR. MOELLER: The NRC issuances, I presume,
16 contain them, but very late.

17 MR. OKRENT: We may get the hearing board
18 opinions. This is typically three to six months after it
19 has occurred. But in fact, prior to this the fact that the
20 Board has sent questions, in fact, you don't necessarily
21 automatically know, or what the staff has responded to. I
22 am referring now to safety questions.

23 MR. MOELLER: In this case the Licensee did
24 provide us with a summary of the staff's position and the
25 Intervenor or whoever raised the contention on each of

1 these, which personally I found very helpful. It would have
2 been much better, as Dr. Okrent points out, to have had the
3 complete --

4 MR. PLESSET: This goes beyond that kind of thing
5 and is a more general requirement.

6 MR. OKRENT: One is reminded of the fact by this
7 case -- I am raising the question generically.

8 MR. PLESSET: I understand.

9 MR. OKRENT: It is an omission.

10 MR KERR: I think this is an important issue. It
11 seems to me we ought to do something later on and not slow
12 down our current activity.

13 MR. PLESSET: I agree with you, but it would be
14 nice to settle it at this meeting.

15 MR KERR: We should, I agree.

16 MR. REID: We have brought down a set of the
17 testimony, both ours and the Licensee's and the Intervenors'
18 testimony that has been filed thus far in the hearing. We
19 will leave that with the Committee. We have only got time
20 to reproduce one copy before the TMI-1 proceeding.

21 We will provide a copy of everything that has been
22 filed from here out.

23 MR. PLESSET: Dr. Okrent has brought up a general
24 matter. I think it is an important one and relates to a
25 subject that has been brought up before: the relationship

1 between this Committee and the Board hearings. I think it
2 was a good point to consider, and we will certainly try to
3 do it at this meeting, what we should do.

4 MR. MOELLER: I think, in terms of following up on
5 Mr. Kerr's comment -- does that about wrap it up, Mr.
6 Silver?

7 MR. SILVER: Again, it depends on --

8 MR. MOELLER: We are running considerably behind
9 time.

10 MR. SILVER: There are several pages of this
11 listing.

12 MR. MOELLER: I would just let the Committee read
13 the list. And we do want to give the Licensee his fair
14 share of the time.

15 MR. OKRENT: I have a few questions that I would
16 like to ask the staff.

17 MR. MOELLER: Fine.

18 MR. OKRENT: One of my questions relates to
19 whether TMI-1 should be considered as not the same as any
20 other reactor, but perhaps, either because of its site or
21 because of its site and the combination of other reasons, be
22 looked at in a special way, either the way you are looking
23 at Zion and Indian Point or some other special way.

24 I would like to hear whether the staff gave this
25 matter specific consideration or not.

1 MR. REID: We did discuss this briefly at the
2 Subcommittee meeting.

3 MR. OKRENT: I mean within the staff. Has the
4 staff talked about this as a specific issue? Have they
5 talked about it with the Commissioners as a specific
6 question?

7 MR. REID: There is currently a Commission paper
8 in preparation on this subject, and as you are aware, this
9 general area is the subject of proposed rulemaking.

10 MR. OKRENT: What rulemaking would cover this
11 specific question?

12 MR. REID: Degraded core.

13 MR. OKRENT: That is a general kind of a
14 rulemaking and what the Commission is doing at Zion, Indian
15 Point, and Limerick is aside from that rulemaking.

16 MR. REID: That is true. However, the staff
17 deliberations on this one -- it has not been finally
18 resolved on the Indian Point, Zion and Limerick, what the
19 final actions will be for those plants. There are various
20 things --

21 MR. OKRENT: Excuse me. Your comment indicates
22 you misunderstood my question. My question is have you
23 consciously considered whether you would look at TMI-1 the
24 way you are looking, or in some way at least, in a special
25 way, as you are looking at Zion, Indian Point, and

1 Limerick?

2 MR. REID: Yes, it has been consciously determined
3 that they are in the next grouping of plants of similar
4 population density.

5 MR. OKRENT: "They" who?

6 MR. REID: TMI is not in as high a population
7 density area as are Indian Point, Zion and Limerick, and
8 they have been put in a second group, I think of eight
9 different sites, for a next priority action. But that would
10 action be determined based on the Commission action.

11 MR. OKRENT: Is there any kind of a paper that
12 discusses this matter?

13 MR. REID: It is in preparation. It is going
14 through the concurrence chain right now.

15 MR. OKRENT: Do you see anything different about
16 TMI among that group of eight? You say it is in the next
17 group of eight. Do you think it is equal to all the other
18 eight, or that it might be different?

19 MR. REID: It has been determined that it is as
20 equal as you can judge for that group of eight. In other
21 words --

22 MR. OKRENT: You don't see anything distinctive
23 about this site, as contrasted to others having the same
24 population density?

25 MR. REID: No, not sitewise. They looked at

1 difficulties of evacuation with respect to the site. They
2 found no unusual evacuation problems for the Three Mile
3 Island site. Population density then would not -- is common
4 to these other eight.

5 MR. OKRENT: Let me offer an individual opinion.
6 To me it is very different, because it is the one that had a
7 serious accident at the site. To me that is a second factor
8 that I would lump into the grouping. That is an individual
9 opinion.

10 So at the present time you are not looking to see,
11 with regard to other safety issues, some of which in fact
12 may be of more importance than this long laundry list that I
13 have seen; you see no relevance to looking at TMI-1 on a
14 special basis, not treating it as equal to all other
15 reactors?

16 MR. REID: Certainly not as a restart issue, and
17 not singling it out because of any other particular problem
18 that we can see at this point.

19 MR. OKRENT: Let me offer a comment to the
20 Committee. I fundamentally disagree with this, if I can
21 make it clear. I think TMI-1 should be receiving the
22 equivalent of an IREP, for example, should be, if possible,
23 be accelerating a look at other, what you might call generic
24 safety issues.

25 I think there are a group of these, and I don't

1 know how the Committee feels. But I think in fact this is
2 what I would consider to be fair and proper. That is
3 different than saying, the restart should be delayed. In
4 fact, it may well be that the staff has not given sufficient
5 resources to TMI-1 for this laundry list.

6 On the other hand, the utility may not have given
7 sufficient resources as to seeing what he can do to improve
8 the safety of the plant on things that are not on that
9 laundry list.

10 In any event, this to me is an important question
11 in the Committee's review and one which I certainly have
12 some opinions. I don't know what the Committee thinks.

13 MR. MOELLER: Thank you.

14 Mr. Chairman, I think we can move ahead now and
15 call on the Licensee. According to the agency, they were
16 first to give their response to the opening remarks of the
17 staff, and then immediately go into their management and
18 organization.

19 Mr. Arnold? Incidentally, you are just about on
20 time, because we started with the staff a little early.

21 MR. ARNOLD: Thank you, Dr. Moeller.

22 My name is Bob Arnold. I am with General Public
23 Utilities System. We appreciate very much the opportunity
24 to come before the Committee today, particularly following
25 so closely to the Subcommittee's meeting.

1 I also would like to express, since I was unable
2 to attend the Subcommittee meeting, my personal
3 appreciation, and I know that of the company in general, for
4 the willingness of the Committee to meet on that particular
5 holiday weekend. It has been of tremendous assistance to us
6 in trying to expedite our preparations for the restart of
7 Unit 1. And that effort on the part of the Subcommittee was
8 very much appreciated.

9 I think in response to the items that were
10 discussed by the staff, I would like to, first of all,
11 comment kind of generally on this issue of open items and
12 what is required for restart, and add my two cents to what
13 has received a fair amount of discussion already.

14 I think in trying to provide status to the
15 Committee, the approach we were taking was trying to
16 differentiate between items which were just not able to be
17 signed off 100 percent yet by the staff because of the
18 expected status or progress -- they were in process, so to
19 speak, but basically on track -- from those which were still
20 matters in contention or upon which there was still
21 disagreement.

22 So that in our list of six items, those are six
23 that are what we would say have fairly important
24 disagreements between ourselves and the staff, or different
25 viewpoints, perhaps I should say; that the way in which they

1 will be reconciled is not yet clear.

2 If we were to truly provide a list of each and
3 every specific element of the requirements for -- or the
4 requirements that we presently have to fulfil to the staff
5 that we were able to identify, those associated with restart
6 and those which may not, I am sure the list would be maybe
7 some 2,000 items. And that kind of represents the other end
8 of the spectrum, so to speak, on open items.

9 Going to the first slide that Mr. Silver put up,
10 for example, under the management, the health physics line
11 item there, which is actually health physics and emergency
12 planning and emergency preparedness, the letter that we
13 received on November 26th as a result of inspections
14 conducted during the summer had a total of 104 individuals
15 items on it. And I am sure that in the course of addressing
16 many of those, there are additional iterations of specific
17 items, and they are still in a sense open items yet.

18 I think that the letter which we delivered to you
19 this morning or which we provided you a copy of this
20 morning, and we put into the mail to the Commission on
21 Monday, from Mr. Dieckamp to Chairman Ahearne, has tried to
22 identify a process that we think has taken place over the
23 last year and a half which has not really been anticipated
24 in the summer of '79, when the orders came out.

25 And I think that process, as we now are a part of

1 it and as we are able to each of us view it, shows
2 substantial differences between what was anticipated in the
3 summer of '79 in the issuance of the NRC's order as to what
4 would be required prior to restart of the Three Mile Island
5 Unit 1 and what today we have before us as potentially
6 required items, at least.

7 The company feels that it is very important, it is
8 imperative, that we find some basis for regrouping on all of
9 these issues. And as we indicated in our meeting with the
10 Subcommittee, we would seek the Committee's help in
11 attempting to classify those issues which are before all of
12 us that are unique to TMI-1 and those which are really
13 generic issues, and to attempt to focus on the rationale for
14 those that should be required prior to restart and those
15 which really should be handled as part of the standard
16 licensing process or regulatory process.

17 We have, I think, encountered a great deal of
18 frustration on our part as we attempted to come to grips
19 with issues which have been raised that are not unique to
20 us, which in many cases, while it was identified as an issue
21 in the summer of 1979, the requirements at that time to
22 close the issue were not understood.

23 Many months have been taken up in identifying the
24 items that -- the specifics of closing those items. And
25 many of the entries on the list presented by Mr. Silver I

1 think represent the impacts of the continuation of that
2 process of refining and attempting to define in many cases
3 just what the requirements are.

4 • Perhaps the easiest example is emergency
5 preparedness, where the guidelines that the emergency plan
6 had to fulfil were not available to us until June of 1980.
7 Clearly, that is not what was envisioned when emergency
8 planning was identified in the order in the summer of
9 1979.

10 I think it should also perhaps be clarified,
11 because I am not sure there wasn't some confusion earlier,
12 with regard to the short and long-term items, the so-called
13 Category A and Category B of 0578. The order did not
14 require us to complete the long-term items of 0578, but to
15 show acceptable progress on them. So that that is an
16 example of where the approach being taken by the staff is a
17 different one for us to grapple with, when many of those
18 things have been approached as being required for restart
19 because of the anticipated duration of the hearing process
20 and the initial required dates that were given for the
21 long-term items.

22 We would still feel that adequate progress on
23 those long-term items should be the governing criteria.

24 I have one last item that I would like to perhaps
25 address, and then we will get into the next portion of the

1 agenda. The Committee report, which we did hope, coming
2 into the Subcommittee, that this perhaps could be the final
3 Committee meeting and it could lead to a letter -- and if
4 that is not the case, we would certainly hope that in this
5 status report we could have as clear an identification as
6 possible of what the additional items are that need to come
7 to further degrees of development before the Committee would
8 be ready to sign off on them.

9 We would request that you consider permitting that
10 to be done through the Subcommittee meeting if possible. And
11 clearly, if considered appropriate, we would attempt on our
12 part to address those issues as expeditiously as possible
13 and provide the Committee with a schedule for when we think
14 we would be ready to provide for close-out of those items.

15 In light of the unavailability of myself for last
16 weekend for the Subcommittee meeting and Mr. Clark's
17 participation and role in that, I feel it certainly would be
18 more efficient today if we let him take a similar role in
19 today's presentation for GPU.

20 I would address just a couple of housekeeping
21 items. In terms of our agenda, we are going to take item B
22 and drop it to follow item D, since Mr. Broughton will be
23 handling items C and D and the control and safety analysis
24 capability part of organization under A. So we will go A,
25 C, D, and then B, with Dr. Long.

1 We also will probably suggest after the break some
2 rearrangement of the technical issues to perhaps provide a
3 more optimum sequencing of those.

4 Let me ask at this point for Mr. Clark to take up
5 agenda item 2.A.

6 MR. MOELLER: Are there any questions for Mr.
7 Arnold?

8 (No response.)

9 MR. CLARK: Good morning. I have provided a
10 handout which is the same as we used with the Subcommittee.
11 In the interest of time, in summarizing I am going to use
12 only some of the pages of that handout.

13 And also, in line with the suggestion of the
14 Subcommittee Chairman, if it is agreeable, I will not, in
15 many cases, read down the slide, but simply put it there and
16 add any elaboration and respond to questions, but not try to
17 read it for you.

18 I think the Committee is aware that in January of
19 1980 the chairman of GPU announced the plan to form a GPU
20 Nuclear Corporation. I am going to present to you today the
21 status of where we are with the corporation and I think show
22 you that we have made good progress.

23 (Slide.)

24 The first slide shows the major elements we are
25 trying to achieve with the GPU nuclear reorganization. In

1 terms of the pooling of resources, I think you realize that
2 we have TMI-1 and -2, and Oyster Creek will be the three
3 nuclear plants we will be dealing with, and so we are
4 pooling the resources that previously applied to those.

5 I think also, from a technical standpoint, it is
6 important to recognize that prior to the accident perhaps
7 two-thirds or more of the technical resources of GPU were
8 being applied to Forked River, which was a plant under
9 design and construction. And subsequent to the accident
10 that project was first deferred, and now recently
11 cancelled. And all of the technical resources which had
12 been applied to Forked River were essentially redirected to
13 TMI.

14 But if you consider today the resources, and in
15 particular the technical resources, applied to TMI, they are
16 perhaps three times the level applied at the time of the
17 accident. So there has been a major increase in the
18 technical resources being applied.

19 Under personnel policies and procedures that go
20 throughout the company, I think most particularly it applies
21 to the bargaining unit question. We are dealing with IBEW.
22 We are trying to get separate contracts and locals and
23 policies with regard to training, requalification,
24 retesting, of the bargaining unit people.

25 As a major example of what is meant by the last

1 item --

2 MR. SHEWMON: On that last item, are we talking
3 about operators only, or does this get into people that
4 fiddle with instruments and do other things?

5 MR. CLARK: All the bargaining unit people. We
6 are still talking about --

7 MR. SHEWMON: I don't know what a bargaining unit
8 person is in this case, in yours.

9 MR. CLARK: Technicians, maintenance people,
10 radiation technicians, as well as the operators.

11 (Slide.)

12 We have a defined purpose for the GPU Nuclear
13 Group. Some of these slides will be labeled "Corporation"
14 and some "Group," and they are interchangeable, with one
15 exception which I will address later.

16 The purpose very clearly recognizes what we
17 believe is unique to the nuclear thing: the overriding
18 importance of the primary significance of the safety. It
19 also recognizes the other key element, which is that we are
20 in business to generate electricity.

21 But it is very clear from that policy put out by
22 our management to us that, if there is a conflict, then it
23 shows what the relative ranking is. And that has been
24 supplemented by an order put out by Arnold that we intend
25 for our people to set our own standards and not simply

1 comply with those things which are laid upon us, as was one
2 of the major conclusions or charges of the Kemeny and
3 Rogovin reports.

4 As far as establishment of the Nuclear
5 Corporation, there are a lot of approvals and lots of steps
6 required.

7 (Slide.)

8 This chart shows that we are approved by SEC. We
9 have requested other approvals. The corporation exists.
10 Officers and directors are approved. We have had our
11 organizational meeting, but we have no authority to act,
12 except in effect to talk to ourselves.

13 (Slide.)

14 Given that situation and obtaining needed
15 approvals, the steps shown here have been taken. I am going
16 to elaborate on the third point here, "Nuclear Group equals
17 Nuclear Corporation," and I think show you that in a very
18 real sense that is true and that the group has been
19 effective since September 15th.

20 (Slide.)

21 I would like to now describe the organization of
22 the Nuclear Corporation and show you briefly how that
23 relates to the Nuclear Group. We have a president, Bob
24 Arnold, who is here. The note on location is a telling
25 one. He is at TMI full-time and his headquarters is there.

1 He will move to Parsippany some time in the future. I am in
2 Parsippany.

3 We have three operating plants, each of which has
4 a vice president full-time on site in charge of that plant.
5 His role is the operation, maintenance, and what we call
6 plant engineering, which is the day-to-day engineering
7 support of operations and maintenance. Each of the plant
8 directors has that scope.

9 Unit 2 has also the decontamination scope, which
10 is unique to that plant.

11 Support functions. Number one is technical
12 functions, systems engineering, planning, project
13 engineering, and startup and tests. This is a major change,
14 or one of the major changes from the pre-accident
15 organization.

16 This group has the technical control of the plant.
17 It has the technical control of the plant configuration. It
18 reviews and confers in operating emergency procedures for
19 the plant. And it has a responsibility to be directly
20 involved in the plant performance and problems day-to-day,
21 as opposed to the prior situations where the headquarters
22 technical group was largely on call. When the plant thought
23 they needed help, they asked.

24 This group is directly charged with the technical
25 responsibility for the plant.

1 This asterisk, which you will see on all of the
2 support groups, or should, means significant full-time
3 representation at each site. So technical functions has
4 people on each site full-time assigned there monitoring the
5 plant.

6 The shift technical supervisor reports to
7 technical functions. We thought that what those people are
8 supposed to bring to the operation is an understanding of
9 systems, transient response, interactions. We look to our
10 technical functions group in systems to have that expertise,
11 and therefore the shift technical advisers should get their
12 direction from that group.

13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. SHEWMON: Where is Parsippany?

2 MR. CLARK: New Jersey, about 30 miles west of New
3 York City. It is the headquarters of General Public
4 Utilities.

5 MR. SHEWMON: How long has Mr. Finfrock been with
6 you?

7 MR. CLARK: He started with a subsidiary back
8 before Saxton, a long while.

9 MR. SHEWMON: Thank you.

10 MR. CLARK: Nuclear assurance, separated out, has
11 quality assurance, training, emergency planning; it has what
12 we call "nuclear safety assessment," which is a staff
13 function that I am going to address further later, but we
14 think is quite important, and a part of nuclear assurance
15 and independent of the other more nearly lined divisions.

16 System lab is the one nonnuclear responsibility in
17 GPU nuclear. There is one chemical metallurgy testing
18 laboratory that had to be in either nuclear or nonnuclear
19 and serve both. It has been decided to put it in nuclear,
20 in part, because we view that as part of our quality
21 assurance, which is the laboratory work that they do.

22 Administration is fairly straightforward. We have
23 our own human resources people so that we do have the
24 capability to handle our own personnel, labor relations,
25 contract negotiations. We have a vice president of

1 maintenance and construction. Basically, it takes off the
2 plant staff the burden of doing the planning and carrying
3 out the major outages. So that instead of the plant staff
4 having to, while they are running the plant for 11 months of
5 the year, also plan and get ready for and then carry out the
6 outage. This group provides that service to them on a
7 full-time basis where that is their major role.

8 We have a vice president of radiological and
9 environmental controls. All of the radiation technicians
10 report in here. The whole radiation protection function is
11 independent of the plant, except -- and, I think, a very
12 important exception -- our position and the policy we have
13 been implementing for the last year is that "Radiation
14 protection is everybody's job." So the mechanic doing the
15 work is responsible to know the radiation protection rules.
16 He is trained, and he is responsible for doing it in a
17 radiologically proper manner.

18 The radiation organization provides assistance,
19 guidance, checks, rules, procedures. But all of the
20 operating people are responsible themselves for following it
21 out.

22 MR. MOELLER: Do you have a person at each site
23 who is in charge of radiological and environmental
24 controls? I noticed Mr. Heward is at Parsippany.

25 MR. CLARK: Each site has a radiation protection

1 manager for that plant. TMI, there is one environmental
2 manager for the two units, because the environmental is
3 common.

4 MR. MOELLER: Roughly, what would be the
5 qualifications of the on-site rad protection manager?

6 MR. ARNOLD: What Phil mentioned may not have been
7 quite clear. Both Unit 1 and Unit 2 at Three Mile Island
8 each have a radiological -- a manager of radiological
9 controls. There is a number of professionals on each of
10 those two staffs, and our radiological control plan provides
11 that that manager for each of the units will himself either
12 meet the reg guide, I think it is 8.8, whichever is the
13 right reference, or we will have a deputy that meets that
14 requirement assigned to that person.

15 In the case of TMI Unit No. 1, the current manager
16 does not meet the reg guide requirements, and we have been
17 attempting to recruit a deputy who does. We have come very
18 close but have not quite had that marriage yet. However, we
19 do have an individual on the staff of Unit 1 who does meet
20 those requirements, but he is assigned as a supervisor
21 radiological engineer. So there is that kind of
22 professional capability.

23 MR. MOELLER: Thank you.

24 MR. ETHERINGTON: In a normal plant, wouldn't most
25 of these vice presidents be superintendents or managers?

1 And if that is the case, is there some philosophy behind the
2 change of title?

3 MR. CLARK: I think there is a very important
4 philosophy behind the change of title. It is not a title
5 change only. Those people represent a level of experience
6 in a capability which is above what has heretofore been
7 associated with superintendents. Mr. Finfrock, prior to
8 taking this job, was the vice president for generation, all
9 generation of Jersey Central Power and Light. Mr. Colby
10 comes with that extensive background with GE at Agnes. Mr.
11 Hukill comes to us with an extensive background from the
12 nuclear Navy in both operating and in headquarters and with
13 Burns & Rowe.

14 So what we have done is to establish a position
15 which is truly a vice-president level in terms of caliber,
16 salary, compensation, the kinds of people we have there for
17 each of those plants.

18 MR. ETHERINGTON: I would hope that would be your
19 answer. Does it apply right down the line? Don't go
20 through them. But does it?

21 MR. CLARK: Yes, sir. Vice president of
22 communications in terms of professional competence, order of
23 magnitude of what we have.

24 Maintenance and construction, also new to the
25 company, this gentleman was a commander of a naval shipyard

1 dealing with nuclear vessels. And then the deputy commander
2 of naval systems command.

3 We have brought in one, two, three, four,
4 including me, five senior people out of those nine.

5 MR. WARD: How many technical people, engineers,
6 do you have in the technical functions?

7 MR. CLARK: Today it has about 250 or 260 total
8 people. That includes secretaries and probably a dozen
9 draftsman. I would say at least 200 technical people in the
10 technical functions group.

11 Plant engineering groups has degreed engineers who
12 are important, although not doing design. They are, if I
13 remember properly, of the order of 15 or 20 degreed
14 engineers in each of those plant engineering groups.

15 We also have engineering people in radiological
16 groups. We have a few engineers in quality assurance and
17 certainly in nuclear safety assessment.

18 MR. WARD: Can you tell me what that is again?

19 MR. CLARK: I would like to defer that. It is a
20 part of a safety review process, and I will specifically
21 address it, if that is all right.

22 MR. CARBON: What is your thinking in moving your
23 headquarters to Parsippany rather than keeping it close to
24 at least one of the operating sites?

25 MR. CLARK: The headquarters has been in

1 Parsippany. GPU's system headquarters and the technical
2 function group supporting a lot of the administration and a
3 lot of these other things are in Parsippany. So it isn't
4 that we have moved them. This merely notes where they are.

5 (Slide.)

6 I would like to show you what we have in effect.
7 This was the GPU Nuclear Corporation, which existed but
8 cannot function.

9 We look at the GPU Nuclear as it is today. I have
10 over here the Nuclear Corporation, which has a board of
11 directors, which today operating as a nuclear group under a
12 management oversight committee, which management oversight
13 committee is composed of the same people who will be the
14 board of directors. That is the president of our owners,
15 the Jersey Central, Metropolitan Edison, GPU, et cetera. So
16 there is a one-for-one correspondence in personnel and
17 action and involvement as we would have with the Nuclear
18 Corporation, but it is under a different title.

19 The Nuclear Corporation will have the office of
20 the president, Mr. Arnold, and me. We have an executive
21 office of the nuclear group, with Mr. Arnold and me. We
22 will have a general office review board, which is a safety
23 group I am going to describe later. We have it in the
24 nuclear group.

25 And below that, the organization that I just

1 described to you is exactly the same, the same people, the
2 same functional responsibility, et cetera. So that as of
3 September 15, we are in fact operating as GPU Nuclear Group.

4 But the distinctions between that and the Nuclear
5 Corporation to which we are moving are, on a day-to-day
6 basis, essentially nonexistent. So we have in place and are
7 now consolidating and finishing the staffing and working out
8 the details of the nuclear group.

9 (Slide.)

10 We have in the handout for you one page on each of
11 the nine organizational divisions. I would like to show you
12 just a couple of those and point out a couple of things
13 which I think are significant changes. This is the
14 technical functions organization. Look at the summary of
15 responsibility and it doesn't say "When asked." It says,
16 "You are supposed to do it." Technical and regulatory
17 aspects of all aspects of our nuclear activities. It also
18 in all of our groups says, "In accordance with corporate
19 policies as well as laws, regulations, and licenses, to try
20 to highlight throughout the organization that we intend to
21 be setting our own policies where appropriate.

22 This shows their involvement in the review and
23 concur plant operating alarm in emergency procedures and
24 defined technical requirements for training programs. So
25 you have a very broad initiative role for the group.

'1 (Slide.)

2 The other one I was going to put up was nuclear
3 assurance, which has three main elements: the quality
4 assurance, training, and emergency planning and laboratory.
5 Training, essentially all training, including management
6 training, emergency plant training, et cetera.

7 The last thing I wanted to address -- and then I
8 would be glad to answer questions -- is what I have called
9 the "safety review process." The first thing we have on
10 this that often gets left off safety review discussions is
11 that the line organization is supposed to do it and do it
12 right. We are putting great emphasis on that, with our
13 plant staff technical functions people, that "We are
14 counting on you to do it right, and you should not be
15 relying on the committee finding it."

16 And in an operator's sense, it is very easy to
17 lose that, to find that, in fact, as we get more committees
18 and more requirements for reviews that the people are busy.
19 It is very hard to put something down and let the committee
20 find it. So they have the responsibility to do it right and
21 to get needed reviews by other organizations, radiological
22 control, quality assurance, whatever. Other functional
23 organizations should be involved, and they are responsible
24 to get it. If they don't and it gets to a review committee
25 without it, the committee is supposed to send it back, not

1 to the job.

2 I think that is a very important point. We have
3 100 percent independent before-the-fact review of all of the
4 things important to safety, whether it is operating
5 procedures or what. The plant staff prepares it; technical
6 functions reviews them. If it is a radiological procedure,
7 the site radiological group might prepare it; the staff or
8 headquarters radiological group reviews it. It is set up to
9 meet our requirements and also is supportive or meets the
10 ANSI standard or ANS standard for review.

11 That before-the-fact review includes explicit
12 consideration of whether we need a multidisciplinary review
13 where you don't just have the individuals reviewing it each
14 in his own office, but you want to get a group of people
15 together to kick it around together in a multidisciplinary
16 manner. That has to be decided "Yes" or "No" at this point.

17 We have for each plant a safety group. It is
18 full-time. It doesn't have other duties in the plant staff
19 or anywhere else. It is on site. So it is directly
20 involved in what is going on, but it reports off site. This
21 is one of the functions of that nuclear safety assessment
22 department. I said I would come back to that. I report to
23 that nuclear safety assessment department.

24 So they are independent of the plant staff tech
25 functions, anything other than nuclear assurance. And they

1 are on site. They do a before-the-fact review of defined
2 items, tech spec changes, unreviewed safety questions,
3 certain categories of procedures that they or management
4 want them to review before the fact that would be in
5 addition to this.

6 They do an after-the-fact review of all items
7 important to safety procedures, design changes, et cetera,
8 looking for trends and also looking for whether the safety
9 process is working, whether the people up above are in fact
10 carrying it out, whether things are getting proper review.
11 They have a responsibility not to just review paper, but to
12 go look.

13 So the fact that they are on site, they can go
14 look at the actual operation of the station, how people are
15 carrying out the engineering functions, what really is going
16 on, so they can assess the safety of how things are working
17 as opposed to merely the safety of what the paper says. Of
18 course, they have full access anywhere in the corporation to
19 information.

20 MR. CARBON: How large is that group, and what are
21 their qualifications?

22 MR. CLARK: The group staffing, we think, will be
23 of the order of a manager and perhaps five or six people.
24 They are all professional people, technical professional
25 people. And we are looking for a diversity of background so

1 that they will cover a defined list of disciplines: nuclear
2 safety systems, radiation, and I forget the others. But it
3 is that kind of a thing.

4 MR. WARD: I take it you don't have those groups
5 all staffed yet?

6 MR. CLARK: Right. We are in the process of
7 working out a transition from the old safety review process,
8 which we can't let go of until the new one is in place. And
9 to get the new one in place, we need to get a few more
10 details defined and then get NRC approval to substitute this
11 for the plant operations review committee, which I
12 understand is perhaps typical of a number of other plants.

13 But we do have the manager of the group. We do
14 have, if I remember, two of the people hired and some others
15 identified. But we can't quite put them in there until we
16 decide on the turnover point from the old system.

17 We are quite concerned that we don't lose
18 something by abolishing the old too quickly.

19 MR. OKRENT: I am interested in that line that
20 says, "Do it right." What is the definition of "right"?
21 How does a man decide what is right or what is safe or not?

22 MR. CLARK: I think at that level, the first thing
23 is it is in accordance with whatever company policies,
24 license requirements, laws, and regulations, et cetera, are
25 involved for everybody.

1 MR. OKRENT: What is the company policy then as
2 distinct from licensing regulations with regard to what is
3 "right"?

4 MR. CLARK: I think you have to look at specific
5 areas on that.

6 MR. OKRENT: Let me propose a specific area.
7 There has been an interest in systems interactions, as you
8 know, over the years. Has GPU decided that systems
9 interactions was something that they, on their own
10 initiative, look at to see whether there are any that have
11 been missed in construction and so forth?

12 MR. CLARK: Yes. I think I can respond to that,
13 and there is a specific presentation on that later. We have
14 set up our systems engineering group. We have people who
15 are qualified and going to get certified, if you will, by
16 NRC. I will make that distinction. We don't have our
17 analysis methods yet approved by NRC, but we are moving to
18 it. We have people in-house who are doing systems analysis
19 calculations who are looking -- analyses -- it is not a
20 calculation -- and we will show you today some of what we
21 have done and some of the things we are developing to
22 provide guidance to the operator, the SDAs, and others, in
23 how the systems respond.

24 MR. OKRENT: I think you're talking about a
25 different subject. Let me define it for you. For example,

1 . . . have had incidents in reactors where failure of a
2 non safety system carrying water flooded the safety
3 systems. If you look, you can find situations in reactors
4 possibly where during an earthquake the motion of non-safety
5 systems will lead to interference with safety systems.
6 These can arise in a variety of ways.

7 Our experience has been that certainly there are
8 no staff criteria that are detailed in this regard. Our
9 experience has been so far that, at least to my knowledge,
10 rather few, if any, of the plants have, except Diablo
11 Canyon, now, to my knowledge, have gone through in some
12 systematic way to see whether such did exist, and they did
13 it from the seismic point of view. I am trying to
14 understand from this example whether your group has
15 considered this and consciously decided it didn't need to be
16 done, it should be done, or whatever.

17 I am getting at the point, "Do it right."

18 MR. CLARK: I would like to say first I don't
19 think the way this chart is set up that that is where it
20 comes. I think perhaps that is the confusion. This is set
21 up for merely when I talk line functions. If you are going
22 to make a design change or procedural change or you are
23 going to implement something, the line function has the
24 responsibility to do it right. When we get down to nuclear
25 safety assurance department and the general office review

1 board or if we go look at the technical functions
2 organization where we have systems analysis people, those
3 people are, in fact, doing some of those things. And we
4 will show you one of them today.

5 I think the company has done a probabilistic risk
6 assessment, for example, of Oyster Creek. I don't think
7 that we are required by regulation to do that. And we are
8 now working with how to use that and how to implement that.
9 But I would think that would be an example of the kind of
10 thing that you are referring to.

11 MR. OKRENT: In fact, I think you deserve credit
12 for having done that on Oyster Creek, although I wish it had
13 been published.

14 MR. CLARK: It's not quite ready, but we are
15 making some use of it.

16 MR. OKRENT: In fact, I think it has turned out to
17 be advantageous to you.

18 But I am still exploring how you decide to "Do it
19 right," and I meant, obviously, in terms of the whole
20 function. And I think this enters not only at the
21 headquarters staff level, but in fact in the execution or
22 even trying to decide whether to report something back up.
23 A man needs some kind of a level of, if you will -- or some
24 nonacceptable level -- beyond which he has to at least
25 question. I don't know how you go at it.

1 MR. EBERSOLE: I would like a more precise
2 example. I had the privilege of examining your Unit No. 1
3 DC power system, and I observed that it met in fact the
4 regulatory minimums. And you could say "Doing it right" is
5 merely meeting those minimums. Or you could say "Doing it
6 right" is in fact exceeding those minimums -- in your own
7 interest as well as the public's -- making the functions of
8 such a system better than it had to be on a minimum basis.

9 I presume you have an operation ongoing someplace
10 that looks at matters like that. And in fact, you might
11 have in the interpretation of "Doing it right," doing better
12 than the regulatory minimums.

13 MR. CLARK: We do have that. And I find it very
14 hard to explain, and I think perhaps it is because we don't
15 have -- the industry and NPC doesn't have a level of safety
16 defined in a quantitative way so that I can say we said we
17 wanted to be twice as good, for example. I don't have a
18 quantitative way to describe that to you.

19 What we do have, we do have a policy for everybody
20 which says, "The first responsibility you have to us is to
21 decide what is needed and proper for safety. We want you to
22 write that down, and then also write down whether it meets
23 or how it meets the regulatory guidance separately." So we
24 are trying to create the environment where everyday
25 everybody has to think about that question.

1 We are also proceeding to have an internal
2 reporting system so that events which are not reportable as
3 LERs, which does not, as presently defined, cover all of the
4 classifications we are interested in, are reportable and are
5 followed up from an engineering standpoint.

6 And we have these functions down here, which I
7 will describe a little more broadly, where people have the
8 charter of going to look for things that we ought to be
9 doing from a safety standpoint that we are doing or not
10 doing properly.

11 MR. EBERSOLE: Under the present circumstances, I
12 can imagine that you must be snowed with meeting some of the
13 regulatory impositions.

14 MR. CLARK: We are. We are nonetheless putting in
15 place and doing things which we think should be done which
16 are not part of what is required.

17 MR. EBERSOLE: Thank you.

18 MR. WARD: Can I comment on that, Mr. Clark? I
19 think the members are misunderstanding what you were driving
20 at there with your first point. I think it is a very
21 important one. Let me see if this -- this is what I think
22 you mean: I think you are trying, by explicit management
23 policy, to reinforce in all of your line organizations, no
24 matter what their function, that it is their responsibility
25 to do the job right and not depend on audits or oversights

1 from other groups, even though you have those.

2 MR. CLARK: Yes.

3 MR. WARD: The responsibility is really on the
4 line organization to do it right without any expectation
5 that they are going to be audited.

6 MR. CLARK: Absolutely. And if the reviews start
7 finding that it comes to them inadequately, it is supposed
8 to go back and be done over, as opposed to having the review
9 group fix it. I think you said it very, very well.

10 MR. BENDER: I would like to follow on to Mr.
11 Ward's inquiry for a minute. I, too, think the approach is
12 probably fundamental to a successful operation. But I would
13 like to know more about how this nuclear safety assurance
14 department interacts with those people that are told to "Do
15 it right." Can you tell us something about that?

16 MR. CLARK: Yes. Let me continue and say what the
17 role of nuclear safety assurance is. They have a
18 headquarters staff, and these would be technical
19 professional, fairly experienced people, but not large in
20 number -- perhaps four to six people -- whose responsibility
21 is to overview the safety performance of the organization
22 and who have no assigned tasks. So you can't find anything
23 in the ANS standards or the reg guides or procedures which
24 say you have to look at every one of these or eight of those
25 or you have to sign off on this.

1 They have assigned responsibility, but no assigned
2 tasks. So they are free to go look for some of the kinds of
3 things we have been talking about, and decide that we ought
4 to be doing a walkdown of our systems to see under seismic
5 conditions what non-safety systems could interfere with
6 safety systems.

7 The nuclear safety assurance department has
8 reporting to them the site safety groups, so they have the
9 responsibility to oversee that those site safety groups who
10 are providing this kind of review at each site are
11 performing properly. They have an ombudsman, and we in fact
12 have the guy in place, and we have had two things brought to
13 the ombudsman. And there is a policy that anybody in the
14 company who has a safety concern that they don't feel is
15 being addressed can come up confidentially to the
16 ombudsman. Both of those had some merit. It wasn't
17 overwhelming, but it wasn't clear that they were being dealt
18 with properly by the organization, and we dealt with them.

19 And they also -- and I think, very importantly,
20 when I get down to the general office review board -- they
21 provide a staff support for general office review board so
22 that our ACRS, if you will, has got some staff that keeps
23 stuff flowing and gets stuff prepared for the review board
24 meetings. That is something that has not always been
25 effective in the past and we think is very important.

1 MR. BENDER: Let me try again to explore what you
2 are saying. If I look at the first bullet as opposed to the
3 first bullet there in the upper category, it says "Obtain
4 needed reviews." And if I look at the nuclear safety
5 assurance department, I would presume that one of their
6 functions ought to be to review something.

7 MR. CLARK: This "Obtain needed reviews" refers
8 not to reviews by any of the safety groups, but to review by
9 other line functions. For example, get quality assurance
10 review where appropriate; get radiological review where
11 appropriate. So that the line function, let's say, the
12 plant staff preparing something, is responsible to go get
13 the other divisions in the company to review it where
14 appropriate before it goes for this review (indicating).

15 MR. BENDER: Let's go back to the first bullet.
16 There is a nuclear safety assurance department. Does it
17 have any say in whether things are being done right?

18 MR. CLARK: Yes.

19 MR. BENDER: How?

20 MR. CLARK: The site safety group reports to
21 nuclear safety assurance department, and the site safety
22 group is responsible for prior review of certain categories
23 of items or after-the-fact overview of others and for
24 observation and surveillance of the whole operation on site
25 and for seeing that they are done safely.

1 MR. BENDER: Is that their channel of information;
2 the nuclear safety assurance department's channel of
3 information is through that group? Is that what I
4 understand?

5 MR. CLARK: That is one major element. The other
6 is what I call the "headquarters staff," and perhaps that
7 introduces some of the confusion. The headquarters staff is
8 not assigned to a site. But they are supposed to be out
9 there a good deal of the time looking.

10 MR. BENDER: People keep saying that they are
11 talking about quality assurance but I think that is kind of
12 a narrow context, that there should be freedom for the
13 people that have responsibility for performance assurance --
14 I will use that term so it will be broader -- to look
15 anywhere and talk to anybody. And I am trying to find out
16 how that nuclear safety assurance functions in that capacity.

17 MR. CLARK: The group on site has the full access,
18 explicitly labeled here. And second, although not labeled
19 on this chart, the headquarters staff has that access. And
20 third, there is access the other way in the ombudsman for
21 anybody to come to them.

22 MR. BENDER: Thank you.

23 MR. KOELLER: Is that about to wrap it up, Mr.
24 Clark?

25 MR. CLARK: I would like to finish very quickly.

1 Our general office review board reports to the
2 president. It is a board. We have a full-time chairman,
3 who is a very senior person. It has outside members. I
4 think out of an 11-man board, there are five outside members
5 for each board. Now, we have one board for each plant,
6 Oyster Creek, TMI-1, TMI-2, with a good many common members
7 but a few different members because some of the problems are
8 a little bit different and the expertise in boiling water
9 reactors, for example, is different than the expertise for
10 Unit 2.

11 And a broad charter is to look at the broad
12 functioning of the safety review process, to assess quality
13 assurance program adequacy. It has no other assigned tasks,
14 although it has the broad responsibility of looking at
15 everything, and our experience is they are looking at
16 everything from personnel selection to the details of the
17 widgeting in the shutdown circuit.

18 And they have access. They report to the
19 president. They have access to the chief executive officer
20 on the board if they should so desire.

21 That is the end of the planned presentation.

22 MR. MOELLER: Any questions for Mr. Clark? Any
23 additional questions?

24 MR. MATHIS: The staff has a draft document out,
25 NUREG-0731, Guidelines for Staffing and Technical Resources

1 for Utilities. Do you feel you are conforming to that
2 guideline as it is now written?

3 MR. CLARK: Yes. Basically, if I go back to the
4 last chart, we think we meet the requirements for safety
5 review and staffing in this particular area about here
6 (indicating). And essentially, what is below there, not 100
7 percent, but in greater part what is below there is
8 something that we have and have wanted over and above what
9 is specifically required.

10 MR. HATHIS: Thank you.

11 MR. MOULLER: Mr. Chairman, I think this might be
12 a good place to take 10 minutes.

13 MR. PLESSET: I am sure the members would be
14 grateful.

15 (Brief recess.)

16 MR. PLESSET: The meeting will come back to order.

17 Moving on with the agenda, as Mr. Arnold pointed
18 out, the next two items are: human factors review and the
19 LER operating experience reviews. For that we have Mr.
20 Broughton.

21 MR. BROUGHTON: I want to speak about a piece of
22 the organization which accomplishes control and safety
23 analysis work, LER review, and also speak about a human
24 factors review project which we have accomplished. There
25 are two particular items which I will address. One is the

1 capability of the organization to provide continued
2 attention to small break analyses. The second piece is to
3 review the operating experience of various power plants.

4 (Slide)

5 This is a department within technical functions,
6 the systems engineering department. There are several
7 sections within that department. One particular section of
8 the department is the systems analysis section. And within
9 that group safety analyses, plant transient analyses are
10 performed by one section. Plant analysis is performed by
11 another section, and that includes the LER review program.
12 And the human factors engineering feature of the
13 organization is also part of that section.

14 The safety analysis work we are performing
15 involves use of computer codes run in-house by in-house
16 engineers and, in particular, codes like the RETRAN code
17 developed by EPRI. That is used by us to study specific
18 transients on our power plant to evaluate design changes, to
19 aid in developing operator procedures or information for
20 operator training programs.

21 We also use other analysis tools such as risk
22 analysis tools, including fault trees and event trees,
23 safety sequence analysis tools. That has been expanded to
24 about eight engineers over the last few months. It will
25 enable us to do more of this type of work in-house.

1 The second group I will discuss, the plant
2 analysis group in the LER review, is a group which is
3 reasonably new. There is a program underway which does
4 evaluate operating experience from other plants by reviewing
5 LERs, test of primary review mechanisms. But there are also
6 inputs that particular group uses. There is a P&W program
7 to assess transient response on other B&W plants. That is
8 an input to that review process.

9 We are involved with some of the work that both
10 INPO and INSAC are setting up to provide industrywide
11 reviews of this information. And the notepad system
12 maintained by INSAC we found to be a very useful piece of
13 information for this kind of review work.

14 The additional tools we would use, or information
15 sources, would include the nuclear power plant operating
16 experience, vendor letters which come in to us.

17 Those are the comments which I had on those two
18 particular functions.

19 MR. MOELLER: Any questions on those items?

20 (No response.)

21 MR. MOELLER: Okay, let's move ahead.

22 MR. BROUGHTON: We have in progress a review of
23 the TMI-1 control room. It was started in February of this
24 year. The review is being conducted by a team made up of
25 members from GPU, the technical staff of GPU, operating

1 personnel from TMI, a consulting firm, NPR, and two experts
2 in the human factors field who provide us with specific
3 expertise for conducting the review.

4 (Slide.)

5 The major elements of the review include
6 developing guidelines and objectives for conducting the
7 review. We constructed a full-scale mock-up of the TMI
8 control room., which included all of the control panels
9 which were of import to the operators in executing the
10 operating and emergency procedures.

11 The main mechanism for evaluating the control room
12 was a controlled walk-through process in which experienced
13 operators walked through evolutions that would be performed
14 in the control room, and the suitability of instrument and
15 control layouts arrangements were evaluated using this
16 walk-through technique.

17 Following the walk-through, each of the individual
18 control panels was also reviewed to look for some of the
19 more specific details of instrument layouts to insure that
20 spacing and labeling and arrangements and so forth were also
21 proper.

22 There is a separate review of the alarm system,
23 the main enunciator panels within the control room to
24 evaluate ways of enhancing their usefulness. And the review
25 also included a review of the environmental conditions

1 within the control room.

2 (Slide.)

3 We found that the existing control room reflected
4 quite a few strengths which were the result of careful
5 design process which was initially used the walk-through
6 mock-up process. Most of the controls and displays were
7 well-grouped. There was not an excessive number of controls
8 and displays on the panel. There was a good division of
9 responsibility between control room operators and operators
10 who are normally stationed outside the plant. We looked, in
11 particular, at how well the control room components
12 performed, and we found that the hardware which had been
13 selected originally was quite reliable.

14 There was a general coordination between the alarm
15 and the control sections of the control room, such that if
16 an enunciator did illuminate, the controls the operator
17 would need to use based on that enunciator were located in
18 good proximity to it.

19 Generally, we found that the bulk of the problems
20 in the control room were ones that resulted not from
21 inadequate design initially but from addition of
22 modifications to the plant throughout its lifetime.

23 MR. WARD: The last item there, Mr. Broughton, the
24 general lack of actuated alarms, that is from the prior
25 experience with operating TMI-1. Can you be quantitative

1 about that?

2 MR. BROUGHTON: Yes. The design of the alarm
3 system was such that at full power all of the enunciator
4 panels should have been dark, unilluminated. And by
5 previous operating history, in fact, we found that there
6 were perhaps only half a dozen or so of these which might
7 have been illuminated during operation of the plant.

8 So the general concept of having a dark alarm
9 panel and then when an abnormal condition occurred to have
10 that illuminated was one that had been executed.

11 MR. WARD: Half-dozen was typical during normal
12 operations?

13 MR. BROUGHTON: Yes.

14 MR. EBERSOLE: In plants of your vintage and even
15 much later, visual information coming to the control room
16 was categorized as of non-safety grade in quality of
17 information and, in some cases, nonredundant and did not
18 have redundant power supplies, et cetera. The cable
19 groupings were even all lumped together.

20 What, if anything, have you done to compensate for
21 this general low grade of visual information that prevailed
22 prior to TMI-2?

23 MR. BROUGHTON: One thing we are looking at in the
24 control room review is the ability of the operator to get
25 information from diverse sources so he can validate various

1 key parameters.

2 MR. EBERSOLE: Even though the individual sources
3 may not be all that reliable?

4 MR. BROUGHTON: It turns out that, as a result of
5 some of the changes we are making to the plant, we will be
6 providing additional instrumentation. As that is added, we
7 are assuring it is reliable as possible and does come from a
8 diverse source and is separately routed. So the chances of
9 losing the instrumentation he would need for monitoring and
10 control of the plant are being reduced.

11 MR. EBERSOLE: That means you have a new set of
12 instruments which you have so upgraded on the boards that
13 are different from the old set which were not of that
14 caliber. How are you showing any differential in a
15 differential sense which are the good ones versus those
16 which are simply incidental instrumentation for the
17 operational process?

18 MR. BROUGHTON: I don't think we determined that
19 the ones we had in the control room are not adequate. What
20 we are doing is providing additional instruments which could
21 be used in the case of failure of the first set.

22 MR. EBERSOLE: Backing these up.

23 MR. BROUGHTON: Yes. And also displaying them so
24 that not only the control panel operator can see them, but
25 so that the supervisor can see them.

1 MR. EBERSOLE: Are they intermixed with the
2 present instrumentation or set aside in their own right?

3 MR. BROUGHTON: Eventually, they will be set aside
4 in their own panel. In some cases, we are adding new
5 instruments in the existin panel, and that is being done by
6 rearranging the instrument array so it is an integrated
7 display rather than one that has had things added to it and
8 obviously stuck on.

9 MR. EBERSOLE: Thank you.

10 (Slide.)

11 MR. MOELLER: I presume the next slide tells us
12 what was wrong with the control room? You have told us what
13 was right.

14 MR. BROUGHTON: This indicates are that we are
15 attempting to improve in the control room. The first is
16 labeling and outlining. I think this is a problem typical
17 of control rooms of this vintage. We have a program
18 underway right now to construct new labels which are much
19 more visible, which move the label of the component from the
20 actuator button, whereas it is typically placed to a
21 separate label on the control panel to make it more legibl

22 Those of you who are familiar with the EPRI work
23 done in this area would recognize many of the things we are
24 doing is similar to those, grouping instruments and controls
25 together by use of demarcation and orderings.

1 A second area where we are making improvements to
2 the panel is in the arrangement of the controls and
3 indications for the emergency feedwater system. This is a
4 typical case of where the existing layout was adequate. But
5 due to changes being made in the system, in order to keep an
6 adequate display in the control arrangement, it is necessary
7 to make modifications to the control panel.

8 The third item, readability of the safeguards
9 status panel. This is an item which we are working on to
10 make it easier for the operator to tell at a glance the
11 status of what his actuation systems are. And this again is
12 a case of where modification is being made to the safeguards
13 systems. They are requiring us to go back and make sure
14 that the information, as we will display it after the
15 modification, is useful and unambiguous to the operator.

16 The alarm prioritization and acknowledgement. In
17 addition to the longer-term study we are doing on alarms, in
18 the short term we are doing things to highlight certain
19 alarms which may be of more importance to the operator and
20 require his immediate attention.

21 The existing alarm panel has things which could be
22 considered both alarm and status indication. One thing we
23 are trying to do is separate those out so that it is clearly
24 evident which are the alarms and which are the status.

25 J. OKRENT: In the accident at TMI-2 there was a

1 time, if I recall, when more information was coming through
2 the computer than they could handle. What is the status of
3 the computer at TMI-1?

4 MR. BROUGHTON: The computer at TMI-1 has had some
5 modifications made to it to deal with the potential backlog
6 of printed material coming out of the computer, which was
7 the real problem with TMI-2. The computer itself internally
8 was able to keep up and didn't lose information, but it
9 wasn't able to display that information in hard-copy form to
10 the operator.

11 We have increased the speed of output devices to
12 preserve the hard copy. But on both of the systems there
13 are other ways to extract information from the computer
14 independently of the hard-copy output, so the operator does
15 have immediate access to any information that he desires
16 from the computer. That is both through CRT and other
17 displays that can be driven by the computer.

18 In addition, there is a program underway to
19 upgrade the entire computer system at TMI-1 to replace it
20 with a more modern computer with greater capability.

21 MR. BENDER: I assume you are reworking procedures
22 as well in this program. Has there been any effort to take
23 the procedures and see whether the symptoms that are
24 required to apply the procedures are properly correlated on
25 the control panels in any way?

1 MR. BROUGHTON: Yes, sir, there is. That is one
2 thing the walk-through was helpful for identifying. And I
3 will speak later today about a program that we had to take
4 symptoms and direct operators to take actions.

5 MR. BENDER: Thank you.

6 MR. CARBON: I am not sure what your walk-through
7 implies. Let me ask, in this activity do you assume
8 different kinds of accidents of different severities and
9 then follow through analytically what would happen, which
10 instruments would be activated, whether some would be masked
11 out, too much noise, too many things for the operator to
12 comprehend? Do you follow through simulated sequences of
13 accidents?

14 MR. BROUGHTON: We do look at accident sequences,
15 and some of the accident sequences we have looked at -- for
16 example, multiple casualties, perhaps a fire in addition to
17 some other upset in the plant -- we didn't ahead of time
18 generate sequences analytically and impose those on the
19 operators. Instead, it was a walk-through of symptoms which
20 would exist if these various conditions were present in the
21 plant.

22 Through the walk-through, we were able to
23 determine what the operators would be consulting to try to
24 gain information about the plant, where they would have to
25 go to get that information, where they would have to go to

1 act. That was the primary purpose of these walk-throughs.

2 MR. CARBON: Thank you.

3 (Slide.)

4 MR. BROUGHTON: The last item is the process we
5 are going through to make changes to the control room.
6 Since we noted that many of the control room problems were
7 due to improperly making changes in the past, we thought
8 that it was important that in correcting deficiencies we
9 found in the control room, that they were well evaluated
10 before they were implemented.

1 The general process I have described here, where
12 there may be one or more conceptual designs of how to fix
13 the human factors problem that we find in the control room,
14 we would construct diagrams which would indicate how we
15 would rearrange the controls and use those on the mock-up.

16 The revised parts of the panel would then be
17 walked through with operators again going over many of the
18 same procedures which identified that there were problems in
19 the first place. So we would now be evaluating the control
20 room as it would be after the design change.

21 We found that this is an iterative process. We
22 have not been able to produce the design change first
23 without the walk-through. So this goes on until we are
24 satisfied that what we have produced is in fact an
25 improvement.

1 . MOELLER: Any more questions for Mr. Broughton?
2 (to response.)

3 MR. MOELLER: There being none, we will move on to
4 the next item on the agenda, which is the coverage of the
5 training program that GPU has instituted for the various
6 people working at the plant. And Dr. Long will be covering
7 that.

8 Dr. Long, since you are a former professor, I am
9 sure you can modify your lecture presentation to any length
10 we desire. So five minutes would just bring tears.

11 (Laughter.)

12 MR. LONG: I would like to highlight the handouts
13 that I gave to the committee.

14 (Slide.)

15 Basically, GPU Nuclear has made a very strong
16 commitment to the training and retraining of personnel
17 throughout the corporation. They have done that by
18 establishing a position of director of training and
19 education for the corporation, which is my present
20 assignment. That position reports to the vice president of
21 nuclear assurance.

22 Under the director there are three training
23 departments, one at TMI, one at Oyster Creek, and one at the
24 corporate level. Those are headed up by people with
25 training backgrounds. In particular, at TMI the manager of

1 training is a former professor at the University of New
2 Mexico. I have to admit that I recruited him away from
3 there, having brought him on the faculty when I was chairman
4 of the department.

5 We have increased the size of our training
6 department from about seven before the accident to
7 approximately 50 people at the present time. The operator
8 training session consists of 13 people distributed between
9 licensed operator training and nonlicensed operator
10 training. These would be the auxiliary operators, mechanics
11 who are in the chain, in the pipeline, if you will, for
12 preparation to become licensed operators.

13 The training facilities at Three Mile Island have
14 been improved to the extent that we brought in additional
15 temporary trailers that are giving us the room for the large
16 number of classes which we are now teaching in many
17 different areas as well as office space for the constructors.

18 The company has made a commitment to provide a
19 training facility near site early in 1981. We have two
20 alternatives. One is the purchase of a college building,
21 and we are in the process of negotiating whether or not that
22 will happen. The second would be the construction of a new
23 building very near the site.

24 The effort in simulator training has gone forward,
25 and we presently use the B&W simulator at Lynchburg for our

1 simulator training. We are closely monitoring that
2 simulator training by sending our staff people from both
3 training and technical functions to the B&W site when we
4 have people in training. We have done that with a recent
5 group of replacement operators for all of the eight weeks.
6 We have had a few days' observation of that activity. We
7 have been feeding back to B&W changes that we think need to
8 be made in the program as well as keeping a license foreman
9 from the plant at the site at the B&W simulator all during
10 the training to closely tie the experience at the simulator
11 to that of the plant.

12 The corporation has also made a commitment to the
13 purchase of a replica simulator for TMI. We are presently
14 talking to vendors for such a simulator, and we expect to
15 proceed with preparation for acquisition of that simulator
16 in 1981.

17 MR. WARD: There are two reactors, two different
18 control rooms. How are you going to handle that with the
19 simulator? Which are you simulating?

20 MR. ARNOLD: I think the only thing we can say at
21 this time is that the eventual recovery of Unit 2 is still
22 an open issue. It is not one we will even probably be able
23 to address until '83 and '84. We really haven't considered
24 that.

25 MR. MATHEIS: This outline, I gather, pertains only

1 to operator retraining or training. What about maintenance
2 personnel, do you have a training program there?

3 MR. LONG: Yes, sir, we do. The reason it
4 pertains only to operator training is that that was the
5 subject asked to be addressed by the subcommittee.

6 We have an ongoing maintenance training program
7 both for initial maintenance personnel as well as
8 retraining. The maintenance people are on a six-shift
9 program, and one time in six weeks they are in training for
10 one week. During that time they get training like quality
11 assurance, radiation safety, as well as the various
12 maintenance activities that are involved.

13 MR. MATHIS: Do they get part of the advantage of
14 this lecture series so that they understand the systems?

15 MR. LONG: Yes. That is correct. Yes, they do
16 get systems training as well.

17 MR. EBERSOLE: I want to ask two questions that
18 may extend your five minutes a little bit. There are two
19 worlds of training. It is what you tell the operators to do
20 and what you tell them not to do. The latter one has been
21 largely ignored in the business, so they have a great deal
22 of freedom to do the wrong thing, like what was done at
23 TMI-2. Are you enhancing greatly that aspect of operator
24 training that says, "Do not do the following things"?

25 MR. LONG: Yes, sir, we are trying very hard to do

1 that. Our operators have been through what we call the
2 "operator accelerated retraining program." One aspect of
3 that program was a one-week course in decision analysis.
4 The basic thrust of the decision analysis course was to
5 instill in the operators the attitude of stepping back,
6 considering what was happening, considering alternatives
7 before they took action, and from that evaluating what was
8 the right decision or the right action. That is one of the
9 ways of doing it.

10 MR. EBERSOLE: So you are enlarging on that field
11 of instructions which has been largely nonexistent.

12 The second is: If you take your emergency
13 instruction books, usually printed in red or some such thing
14 as to show them as being very important and look at them
15 carefully, you notice from time to time as you go through
16 them there will be a call-out to the operator to verify that
17 something happens when he loses the first stage of some
18 function.

19 What I have found missing in the training manuals
20 is, having looked at this portion of the instruction manual
21 and verified, there was no further instruction if in the
22 verification process he found a given service was inactive.
23 In short, he was left off at that point, and that was based
24 on the thesis that the single-failure criterion would always
25 work and the operator would always have the prerogative to

1 say to you, "I don't need to go any further than that,
2 because it will always be there." In fact, many took that
3 position that you have no right to claim that when you came
4 to that point in the instruction manual, when you verified,
5 you would not find in fact that everything was as it should
6 be. What are you doing about that? That represents a
7 potential several stages beyond just verify that. It is
8 impractical to go all the way out, but you have to go to
9 some level.

10 MR. LONG: I think the anticipated transient
11 operating guidelines that Mr. Broughton will address later,
12 those really focus on that, giving the operator some
13 guidance as to what the symptoms are, what things he ought
14 to be looking at, and if he doesn't see what he should,
15 where does he go and what kinds of questions should he ask
16 next.

17 MR. EBERSOLE: You mean beyond the normal degree
18 of failure?

19 MR. LONG: Yes, sir.

20 MR. EBERSOLE: Thank you.

21 MR. MOELLER: Go ahead.

22 MR. LONG: I want to point out that we had a
23 one-week instructor training course that all of our
24 permanent staff are participating in. In fact, some of our
25 contractor staff have also been in that course. We focus on

1 a strong emphasis on understanding what the behavioral
2 learning objectives should be for particular types of
3 training.

4 This is, quite frankly, new to many of our
5 instructors, to identify clearly what it is that the
6 operator or the maintenance person or the rad technician
7 person should be doing, should be able to do at the
8 completion of training. And thereby we hope to focus and
9 use our available training time efficiently by giving that
10 entire focus as part of our training.

11 The on-the-job training area, I would also like to
12 comment on that, in that that has been an area that has been
13 weak in the past, and we are presently working with the
14 operations personnel to find ways of effectively monitoring
15 that on-the-job training. It has varied greatly depending
16 upon the enthusiasm of the particular shift supervisor and
17 shift foremen for training. And we are developing some
18 control methods that we think are going to greatly improve
19 the overall quality of on-the-job training.

20 I would like to say one last thing: that in terms
21 of how we have gone beyond the regulations. The regulatory
22 requirements for retraining are for 60 hours. With our
23 operators in a one-week-in-six training cycle, they receive
24 about 240 hours per year in that retraining program.

25 MR. MOELLER: Thank you.

1 Mr. Shewmon.

2 MR. SHEWMON: You divided the world into
3 operators, maintenance people, and radiation specialists --
4 my words, not yours. There are a lot of different types of
5 systems to maintain. When one is appointed as an
6 maintenance technician by you people, does he now maintain
7 everything? Or how do you break down, say, electrical
8 instrumentation, mechanical, or whatever?

9 MR. ARNOLD: Our classifications include
10 electrical maintenance, instrumentation and control
11 maintenance, a mechanical, a machinist, and then a general
12 utility classification. So we have those five different
13 classifications of maintenance personnel. The training
14 programs are tailored to the different classifications.

15 MR. SHEWMON: So when someone is called out at
16 4:00 o'clock in the morning, and the guy goes down and says,
17 "This guy has the least amount of overtime, so he is the one
18 we have to call in to look at the instrumentation and
19 control package," he will have been certified on all
20 instrumentation and control packages and, therefore, you
21 feel will be qualified to take care of whatever he had to be
22 called in for?

23 MR. ARNOLD: The issue you bring up is a very real
24 one for us. What our experience in the past has been is it
25 becomes more a matter of economy than anything else, because

1 we call out the low person and then we call out the one that
2 also in fact is qualified to do it. And Mr. Clark mentioned
3 in his presentation the adaptation or the adoption, putting
4 into place of personnel policies that apply to nuclear
5 activities.

6 The specific problem you are identifying is one
7 that we will be issuing or we will be addressing in the
8 negotiations that we will be doing with our bargaining unit
9 people in getting the kind of flexibility and specificness
10 to the assignment of people to tasks that we need.

11 But I think, pending that completion, it is more a
12 matter of the economic impact of it and not the safety,
13 because we end up calling out a person who can be trained
14 additionally and the person who can do the work.

15 MR. MOELLER: Any other questions for Dr. Long?

16 (No response.)

17 MR. MOELLER: Thank you very much.

18 We will move on into the technical issues. We
19 have seven different subjects that we are going to try to
20 cover in the next hour and a half, and the first of these is
21 hydrogen.

22 MR. ARNOLD: I would like to suggest, for flow of
23 the presentation, that we pick up item G up first, and then
24 item C, both of which will be handled by Mr. Broughton, and
25 then we will pick up the remainder in the sequence they are

1 presented.

2 MR. MOELLER: We are doing G and C?

3 MR. ARNOLD: Yes.

4 MR. MOELLER: These are the ATOG
5 pressure/temperature plots and the reactor vessel water
6 level indicator.

7 MR. ARNOLD: While Gary is going up there -- in
8 further response to the question on the procedures as to
9 "Suppose the action isn't there that is asked to be checked
10 for," for our procedures on inadequate core cooling
11 specifically, the procedures have been expanded to say, "If
12 it is not there, then do this," so that there is not that
13 sort of assumption of the right answer.

14 MR. BROUGHTON: The abnormal transient operating
15 guideline program is an attempt to satisfy the NUREG-0578
16 requirements to look in more detail at different transients,
17 providing realistic assessments to be used for a training
18 and procedural basis. We are participating in a program
19 jointly sponsored by other B&W owners which develops both
20 guidelines which can be converted into procedures for a
21 plant, and it also develops a training package which
22 explains how to use the guideline, how plants should respond
23 to these various transients, and how the plant may respond
24 if there are other abnormal conditions that exist during the
25 transients.

1 There has been one set of these guidelines,
2 developed for the Arkansas plant, and most of the comments
3 that I make today will be based on those TMI-1 specific
4 guidelines are being developed but do not yet exist.

5 There was a human factors input into these
6 guidelines in helping us determine things like what level of
7 detail is appropriate in helping us evaluate the guidelines
8 on a simulator to make sure that they were really useful in
9 addressing problems which the operator might be expected to
10 face.

11 A guideline that results from this work would be
12 executed each time the reactor tripped. From that
13 standpoint, it is a one-for-one replacement of the reactor
14 trip procedure. It has instructions in it based on key
15 symptoms within the reactor plant, things like reactor
16 power, temperatures, pressures, flows. Based on whether
17 those symptoms are normal or abnormal, specific actions will
18 be directed for the operator. It is not necessary for the
19 operator to understand at the early point in this guideline
20 exactly what event has occurred so that he can deal with it
21 properly. That is in contrast to the existing procedures
22 which are most frequently used, which are event-oriented
23 procedures such that the operator must decide ahead of time
24 what event he has before he can pick up the procedure and
25 find the guidance to deal with it.

1 The symptoms in this procedure are arranged,
2 however, to allow him to be diagnosing what the event is at
3 the same time he is treating the symptoms. There is a
4 prioritization in the response, in that if several different
5 events have occurred, he will be treating the ones with the
6 greatest potential for adverse consequences first and the
7 ones of lesser importance later on.

8 MR. WARD: How is that priority established? In
9 the training?

10 MR. BROUGHTON: It is established, first of all,
11 technically by the analyses that went into making up the
12 procedures. There was an extensive analysis based behind
13 the procedures, and then it is established in his training,
14 which is the training package not used as part of the
15 guidelines. And third, it is an effort to be established in
16 the guidelines themselves.

17 MR. EBERSOLE: Is he helped in that process by CRT
18 printouts that really follow the recipe?

19 MR. BROUGHTON: He can be helped. And I will have
20 an example that shows how he might be able to use these
21 guidelines. The procedure is capable of detecting
22 combinations of malfunctions. It is not limited to dealing
23 with one specific event at a time. If two or three events
24 should occur simultaneously, the capability is within the
25 procedure to deal with those.

1 Once the specific event has been diagnosed, then
2 there may be a different set of instructions which the
3 operator follows to deal with it. For example, if the event
4 were a tube rupture, then there is an appendix to this
5 procedure which gives him specific instructions for dealing
6 with the tube rupture event.

7 There is a very important aid which is used to
8 help the operator follow the procedure and ask various
9 questions which are posed by it. It is a very simple
10 temperature plot used to evaluate three particular
11 conditions, one of them being a loss of subcooling, a
12 condition which could occur because of a loss of coolant
13 accident, an overcooling event or a loss of heat sink event.

14 I have some examples of how this
15 pressure/temperature plot works that I think will help show
16 the use of that and also explain a little more about the
17 procedure.

18 MR. MOELLER: Perhaps for these we ought to turn
19 all of the lights off, because they are rather dark.

20 (Slide.)

21 MR. BROUGHTON: This explains the basic
22 temperature plot used. There is a plot of primary system
23 pressure versus hot leg temperature. The saturation curve
24 is that determined by the steam table. This range marked
25 "expected" is the condition that the plant should wind up in

1 following the trip if there are no malfunctions.

2 So if I design this, that the plant should
3 stabilize in this condition, the plant may be in some other
4 regime on the plot at the time of the trip, but the trend of
5 this plot of pressure versus temperature should be in the
6 direction toward the expected range.

7 MR. SHEWMON: Is this something the operator sees
8 on a CRT, or is this what you use to teach them, or what?

9 MR. BROUGHTON: This is used for teaching. It is
10 the concept. I will show examples of what he would actually
11 see on the CRT..

12 (Slide.)

13 The second piece of the diagnosis is very
14 similar. Here we look at steam generator pressure and
15 compare that to cold leg temperature of the coolant out of
16 the steam generator. Again, there is an expected range and
17 a characteristic trend for normal operation. This is also
18 the saturation curve. Basically, what this plot tells you
19 is how efficient the steam generator is in transferring
20 energy out of the primary coolant.

21 (Slide.)

22 Now, combining the primary plot at the top and the
23 secondary plot at the bottom, we can look at the trends
24 expected for certain abnormal conditions. This is the type
25 of trend you would expect to see if you saw a loss of

1 coolant accident in which pressure continues to decrease,
2 and it may decrease down to the saturation curve or even
3 below.

4 (Slide.)

5 This trend is typical of a loss of heat sink event
6 in which there is abnormal heat removal from the primary,
7 and the result is that the temperatures in the system will
8 heat up and the trends will be to the right. The downward
9 trend here is typical of losing heat removal in one steam
10 generator while temperature is still being controlled by the
11 other. You would note there would be a pressure decrease in
12 the generator which was inefficient. Any trends off in this
13 direction are indicative of the loss of heat sink.

14 (Slide.)

15 The third would be overcooling, in which
16 temperature is reduced down below the expected range on both
17 the primary and the secondary.

18 (Slide.)

19 Now, the next few slides were taken from some work
20 that GPU has been doing to use this technique for training
21 operators and also to evaluate how it may be used in the
22 control room to present this information in real time during
23 a transient.

24 What I have plotted here is the same
25 pressure/temperature plot we have been looking at with the

1 two expected ranges for primary and secondary. These
2 additional lines on the plot help to further define these
3 areas. The green region being the overcooling, anything to
4 the right or below this magenta line would be the loss of
5 heat sink, and violation of this red dashed line would
6 indicate a loss of subcooling. So the typical trends for
7 abnormal conditions would also be reinforced by the location
8 of the data on the plot.

9 This list over here indicates the major steps of
10 the abnormal transient operating guideline procedure. There
11 are a series of questions asked by the procedure; and to
12 answer some of these questions, these latter few, for
13 example, this plot becomes particularly valuable.

14 What I will show you is actual data from the TMI-2
15 accident plotted using this accident, and indicate how it
16 would be addressed by this abnormal transient procedure.

17 (Slide.)

18 MR. BENDER: I think we are not too clear. There
19 is a red line and a blue line and a magenta line. What are
20 they intended to plot? Are they plots of --

21 MR. BROUGHTON: The blue line that cuts diagonally
22 is the saturation curve. The red line above it is some
23 minimum margin above the saturation curve. If I go below
24 the minimum margin, then the operating procedure will
25 require that the event be considered as a loss of subcooling

1 or a LOCA event and action taken that is appropriate for
2 that event. So this region keys me to use that feature,
3 that section of the procedure.

4 The magenta line indicates a boundary of normal
5 heat transfer and heat removal to the left of that line,
6 abnormal if I am to the right of that line or below that
7 line. So if I wind up in this particular region here, that
8 keys me to use a separate part of the procedure to deal with
9 that particular abnormal condition. The green line here
10 indicates I have overcooled the primary, excessively reduced
11 the temperature. There is a section of the procedure which
12 tells me what to do if those conditions arise.

13 There are two other reference lines on here. The
14 2500 line is simply the safety, primary safety system set
15 points. It is another limit which should not be reached
16 during normal operation. The 600 line is an automatic steam
17 isolation line which would activate a system which would
18 isolate feedwater to the steam generators.

19 The procedure can also deal with events that occur
20 in those regions. I would be concerned primarily with the
21 subcooling line and the loss of heat sink area.

22 MR. MATHIS: The operator will know what all those
23 lines mean from his training?

24 MR. BROUGHTON: He knows what they mean from the
25 training, and he knows what the trends mean from the

1 training. We have had actual experience with training of
2 TMI operators. We have introduced this method to them. It
3 has been a method which they have been able to learn
4 quickly. They found it very useful. And in fact, they can
5 use this to diagnose events in real time.

6 MR. SHEWSON: How often will an operator in
7 routine operation be using that plot?

8 MR. BROUGHTON: This particular
9 pressure/temperature plot would be displayed following a
10 trip of the reactor, so that might be in normal operations
11 seldom. However, through the training program where he is
12 trained on what to do following events like that, he would
13 probably be exposed to this quite frequently.

14 MR. LAWROSKI: In the Three Mile Island accident,
15 can you find on that curve where one would have been for
16 what duration?

17 MR. BROUGHTON: The next series of slides will
18 show that. This slide indicates the data for the TMI-2
19 accident one minute after the reactor was tripped, so the
20 primary trace has gone up to the SCRAM set point and begun
21 to drop down -- not atypical yet. The steam generator trace
22 has increased in pressure and temperature.

23 MR. LAWROSKI: Do we have a flashlight that could
24 be used instead of the pointer?

25 MR. BROUGHTON: The primary trace is in the upper

1 part of the picture. First increase is to the SCRAM set
2 point and then begins to decrease. The trace in the lower
3 part of the picture is the steam generator trace, and that
4 begins to increase in pressure and temperature, and at the
5 end of one minute it is here -- it has moved to the right.

6 Now, from this point on, for a normal transient,
7 what we would expect to see would be the steam generator
8 trace moved to this lower blue box, and the primary trace
9 would move to this upper blue box.

10 MR. EBERSOLE: It would help to have arrows on
11 your curves. That represents timespan.

12 MR. BROUGHTON: Yes. We are looking at things
13 like arrows or tick marks that mark intervals, or some other
14 method of portraying the time response.

15 MR. LAWROSKI: How large of a display is he seeing?

16 MR. BROUGHTON: This was photographed from a
17 12-inch CRT. It could be placed on any size CRT available.

18 MR. BENDER: I think it tells you just from
19 looking at the curve, it tells you what actions to be
20 concerned with; that is, overcooling or overpressure or some
21 such as that. Does it tell the operator what the accident
22 really is?

23 MR. BROUGHTON: It tells him what it is if he
24 winds up being in one of these abnormal regions. For
25 example, if he ends up being in this region marked by the

1 magenta line where heat removal is inadequate, that would
2 correspond to a total loss of feedwater event, no emergency
3 feedwater, no removal for high-pressure injection.

4 Now, there are many different combinations of
5 events that could lead to a total loss of heat removal.
6 Rather than calling it by the name of all the components
7 that malfunctioned to get him there, it is termed
8 generically by: this is a loss of heat removal event.

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 The first one he would see, he has inadequate
2 feedwater flow one minute after the trip, and that would be
3 based on no main feedwater flow and no emergency feedwater
4 flow. There is a step in the procedure that should call his
5 attention to that fact.

6 (Slide.)

7 Moving on to the next time frame, this is two
8 minutes after the trip. Instead of the primary system
9 turning and running over toward the blue box, it continues
10 to decrease in pressure and it reaches the point of
11 engineered safeguards actuation, which is this flag here
12 (Indicating).

13 While that doesn't require any action from the
14 operator other than to verify that the safeguards system has
15 functioned, he is now starting to get symptoms of
16 additional abnormal performance

17 (Slide.)

18 At three minutes, the secondary trace, the lower
19 trace, crosses over this magenta line, which indicates that
20 there is inadequate heat removal from the steam generators.
21 That has resulted from the inadequate feedwater, but it is
22 now picked up by the information obtained from this plot.

23 There is a separate section of the procedure which
24 would tell the operator what should be done based on the
25 fact that he has inadequate feedwater.

1 MR. OKRENT: The lower line is a plot of pressure
2 on the secondary against temperature where?

3 MR. BROUGHTON: Yes. The lower curve is steam
4 generator pressure versus cold leg pressure, the primary
5 coolant coming out of the generators. So it indicates there
6 is inadequate transfer of energy from the primary system
7 into the steam generator.

8 MR. BENDER: All he is looking at is the curve, I
9 take it? He doesn't have that printout, does he?

10 MR. BROUGHTON: We would envision that this kind
11 of a diagnostic tool would not be the primary plot used by
12 the man who stands at the control panel. The basic reason
13 is, we are only looking at four variables here. And in
14 order to properly control the plant during normal operation
15 or during upsets, you need to monitor more than four
16 variables.

17 We would look at this information as information
18 being provided to another operator in the control room,
19 perhaps a supervisor, such that he has the perspective of
20 whether or not the plant transient is normal, and if it is
21 not where his particular problems are.

22 It may also be possible to implement an automated
23 checklist like this via the computer to assist him in
24 knowing which parts of the procedure apply. The logic
25 required to evaluate these conditions is quite basic. It is

1 very well within the capability of the computer system. So
2 he could have both. He could have a plot and a checklist.

3 MR. OKRENT: The information going to this is not
4 all safety-grade, is it?

5 MR. BROUGHTON: The information which goes to this
6 plot would, of course, depend on the plants. At TMI some of
7 the information that we would feed to the plot currently is
8 safety grade. There are other pieces of information which
9 would not be safety grade.

10 One of the questions we are addressing before
11 implementing a method like this is what do we need to make
12 sure that the data and display is adequately reliable to
13 prevent the operators from taking incorrect action.

14 MR. WARD: How elaborate is the programming? You
15 have three flags over there, three yellow items. Does that
16 indicate that the latest point is outside the box or does it
17 indicate something about the trend?

18 MR. BROUGHTON: We have not made up the algorithms
19 to enable us to use this display. The answer is that it
20 could be as simple as looking at the latest point, although
21 we will see a point later in this transient where that would
22 be an undesirable way to evaluate some of these conditions.
23 In other words, trends and routes of change should be
24 included in some of those algorithms.

25 (Slide.)

1 MR. BROUGHTON: This point at four minutes I
2 display because it shows that pressure continues to
3 decrease, and we have not violated the subcooling margin
4 curve. There are four appendices to this procedure as it
5 exists and there will be a fifth.

6 The appendices are tube leak, subcooling, heat
7 removal. These appendices would be prioritized such that if
8 you had a tube leak and some other condition, he would deal
9 with the tube leak first. If he has a subcooling problem
10 and a heat removal problem, he deals with the subcooling
11 problem first.

12 This is the case of a multiple casualty, where
13 there has been some forethought into which of those abnormal
14 conditions should be dealt with first.

15 (Slide.)

16 This point at eight minutes shows the most extreme
17 condition of the loss of heat removal in the steam
18 generator, that is, the steam generator trace is furthest
19 away from the saturation curve. It also shows that the
20 primary system has come down to the saturation condition in
21 the system. And as the temperature increases because of no
22 heat removal, the primary system pressure also increases.

23 This was a fact that was confusing to operators by
24 looking at those things individually, and when they are
25 correlated like this it becomes clear as to why the pressure

1 increased.

2 (Slide.)

3 This trace shows that as feedwater is admitted to
4 the generators, as it was at eight minutes, that the system
5 pressure began to recover in the steam generator. From here
6 on out, the pressure trend in the steam generator would
7 converge on this expected range.

8 (Slide.)

9 This shows that the steam generator is restored to
10 normal performance, even though the primary remains in this
11 inadequate subcooling region. These were conditions at
12 about 20 minutes after the trip at TMI-2.

13 MR. MOELLER: Are there further questions on this?

14 MR. OKRENT: Is the report written which gives the
15 details of the rationale for the establishment of the
16 particular display, and then the way in which the operator
17 is taught, or whoever it is that is taught, how to react to
18 it?

19 MR. BROUGHTON: The P&W guidelines for Arkansas,
20 all that material is available. There is also a report, a
21 paper which CPU has prepared, which is a much more
22 consolidated version of that, which we make available to you.

23 MR. OKRENT: I think it would be of interest to
24 Subcommittee members to have a chance to look at that. I
25 suggest we get copies of what is available.

1 MR. WARD: I would like to make a comment. This
2 looks like a noble effort, a little elaborate perhaps. I
3 worry perhaps more about the quality assurance of the
4 software involved than the hardware, although that is a
5 concern, too.

6 Have you thought much about that?

7 MR. BROUGHTON: Yes. First of all, the
8 implementation of the procedure does not require that you
9 use an automated plot like I have shown you. The procedure
10 can be implemented without the use of that plot. It is
11 simply required that the operator be able to answer those
12 three questions posed by -- that are answered by the plot:
13 Do I have enough subcooling, do I have too much or too
14 little heat removal?

15 There are other ways to obtain those answers. The
16 automated plot is certainly the easiest. As a backup to
17 that, we found that the operators can manually plot that
18 data, and all the data they would need to make those
19 determinations is displayed in the control room. And on a
20 plotting form pre-established with those limits on it,
21 operators are able to plot that and draw those same
22 determinations.

23 In fact, that is the method we used to teach this
24 concept when we teach it to the operators.

25 We think we can implement procedures completely

1 independently of having to have the CRT display.

2 MR. BENDER: You partially answered my question,
3 but I will try to get it amplified a little bit. In the
4 training program, how would you make use of this
5 information? I think you pointed out that the operator
6 doesn't necessarily have to rely on it. I guess I have to
7 think in terms of what is he going to be trained to react
8 to? That is the fundamental question.

9 I would like to get some insight from you now as
10 to -- given that you have a new set of procedures that have
11 evolved over the last several months, and now you have new
12 kinds of displays that are available, how the operator is
13 going to establish his first and second line of symptomatic
14 diagnosis, whatever you want to call the thing, to know what
15 to do?

16 MR. BROUGHTON: It turns out that, although this
17 is a one-for-one replacement with the reactor trip
18 procedure, because it covers many other events, it replaces
19 many other procedures. So first of all, he can now approach
20 the problem of transient response using a different
21 procedural format.

22 Secondly, we have gone through training with the
23 operators in periods of about two weeks' worth of work with
24 the operators, in which we covered transients that they are
25 used to covering, events like loss of feedwater and LCCA's

1 and so forth, showing them how diagnosis by this method
2 compares with diagnosis by other methods. So there has
3 already been this new approach introduced.

4 And the operators themselves are now starting to
5 categorize events which we give to them in training in terms
6 of these three basic categories, which is a much more
7 logical way to approach them. And it turns out that their
8 actions are really based on the category of event now,
9 rather than knowing specifically that a particular steam
10 valve may be stuck open.

11 So that transition has already started, and when
12 we get the guidelines that we are ready to implement at LMI
13 that transition will be completed.

14 I should also mention, if I may, that in doing
15 this training we rely very heavily on actual data from
16 operating plants. We use simulations to some extent, but to
17 the maximum extent possible we have gathered data from
18 operating plants which shows normal and abnormal
19 performance. And it has shown that this method is effective
20 in diagnosing those particular malfunctions.

21 MR. BENDER: I don't challenge that. I was more
22 trying to understand how the operator is going to do
23 things. I would presume after he gets the event
24 categorized, then he just has a sequence of events that he
25 goes through.

1 MR. BROUGHTON: That's correct. If he diagnosed
2 an inadequate heat removal event, there is a section of that
3 procedure which says, given that you have an inadequate heat
4 removal event, these are the steps that you take.

5 MR. BENDER: There are steps and there is the
6 analytical process, and steps that would presume to be here
7 operating actions that are done. But are there analytical
8 questions that he has to address?

9 He has lost the heat sink. How does he go about
10 determining what is interfering with the heat sink?

11 MR. BROUGHTON: Those are the types of things that
12 will be put into the procedure, that says, these are the
13 steps you need to take to get the heat sink back. Those
14 would be specific to his plant. He should be looking to see
15 if he has a feedwater system available and there is flow
16 through the feedwater system.

17 MR. BENDER: I won't pursue it further.

18 MR. ETHERINGTON: The subcooling is in essence a
19 temperature-measuring device, which is combined to give you
20 some curves --

21 MR. MOELLER: We can't hear you.

22 MR. ETHERINGTON: I just said, the meter is one
23 instrument and a steam table. Now, if you had to invoke
24 such a thing as the feed-bleed process, we know that the
25 process involves a suppression of primary fluid down to a

1 certain low level, which may well be below the level that
2 you have the subcooling meter temperature measurement.

3 Do you know where that level is? I am saying you
4 might lose your signal.

5 MR. BROUGHTON: You might lose your signal on our
6 subcooling meter.

7 MR. ETHERINGTON: And your signal goes to zero.
8 Water is suppressed below that point.

9 MR. BROUGHTON: And the operator is instructed to
10 use the core thermocouples in determining in lieu of the
11 subcooling meter.

12 MR. ETHERINGTON: You have accounted for the
13 potential blindness of the subcooling meter?

14 MR. BROUGHTON: Yes, sir.

15 MR. MOELLER: Any other questions on this topic?

16 MR. LAWROSKI: What kind of experience underlies
17 the reliance that you can put on this? From some other
18 reactor plant, whatever?

19 MR. BROUGHTON: All of the technical information
20 used in deriving the procedures is technical information
21 available from both plant operating experience and
22 simulation. I think that is fairly sound and specific to
23 this industry.

24 One of the things that the human factors
25 consultant did for us was to help us evaluate this type of

1 an approach, that is, a symptomatic approach to
2 problem-solving. That is an approach which has been used in
3 other fields, particularly in the military. There is a good
4 history from these other fields that this is an effective
5 way of dealing with problems.

6 MR. CLARK: To date, our reliance on this concept
7 has been solely to help us develop improved procedures. We
8 are now moving into using it to help train the operator to
9 understand what happens.

10 We are not about to put a CRT in the control room
11 for the operator to use during a transient instead of his
12 normal instrumentation. After a while, we may well put a
13 CRT for the shift technical adviser or the shift supervisor
14 to look at while the operator uses the primary
15 instrumentation. So we are going to feel our way into
16 reliance on this thing.

17 MR. MOELLER: Why don't we move ahead with the
18 pressure vessel water level indicator. Mr. Broughton, if
19 you can do this briefly, it will help. I think we
20 understand that this is a matter that is under debate.

21 MR. BROUGHTON: Yes. I think the slide and the
22 handout summarizes the current status of this. We have not
23 found the need to use the water level indicator in existing
24 guidelines, and we are not clear on how we would use it if
25 it were available in the guidelines.

1 We are concerned about being able to provide
2 something to the operator which would be unambiguous and
3 useful rather than confusing. However, we are participating
4 in programs to review what can be done in terms of providing
5 such a measurement device, and we are committed to look into
6 these and work with, in particular, the other owners in the
7 B&W group to evaluate promising alternatives. And we may
8 get involved in additional R&D efforts ourselves.

9 MR. MOELLER: Questions or comments?

10 MR. KERR: I am told by some who have looked at the
11 St. Lucie incident, which involved some loss of coolant,
12 that the operators there would have been assisted
13 considerably had they had a water level meter.

14 Have you looked at that incident and convinced
15 yourself, at least insofar as it might apply to your plant,
16 that a level meter would be of no assistance in a similar
17 incident?

18 MR. BROUGHTON: Yes, we looked at the St. Lucie
19 event and, while I wouldn't go so far as to say water level
20 indicator might not have been of help, it would depend on
21 how you could install that. If you could get it up at the
22 very top of the vessel, for example, it might be a help.

23 However, there are other ways to determine that
24 you have voiding in the upper head of the reactor vessel
25 which we believe are more feasible and less ambiguous, and

1 that would be to use a temperature sensor to evaluate
2 saturation conditions there, like we are evaluating
3 saturation conditions in the loop.

4 MR. KERR: Then you may be saying that a
5 temperature indicator would be a water level indicator.

6 MR. BROUGHTON: It wouldn't indicate water level.
7 All we would know is that we had some voiding in the head.
8 We wouldn't know whether we had a very small amount or
9 whether we had voiding almost down to the nozzles. It would
10 be an indication of something of a less than full condition,
11 but it wouldn't tell us how much less.

12 MR. LAWROSKI: What kind of magnitude of
13 temperatures would you be observing if you were getting that
14 voiding?

15 MR. BROUGHTON: As I understand the St. Lucie
16 event, there was a fair amount of subcooling in the loops,
17 perhaps on the order of 50 degrees or more, throughout the
18 entire cooldown.

19 MR. LAWROSKI: I am talking about the use of
20 temperature indicators.

21 MR. BROUGHTON: The loops were kept subcooled by
22 50 degrees or more, and the head had to be at saturation.
23 So it would have had no subcooling in order to have given us
24 the voiding. We are looking at a difference of at least 50
25 degrees between the two, which is well within the capability

1 of the instruments to detect.

2 MR. EBERSOLE: Isn't the saturation meter, the
3 temperature-measuring part of the saturation meter, isn't it
4 in fact a level indicator which goes blind at a discrete
5 level? You don't know -- once it passes that, if it goes to
6 saturation, then that's all it knows. Beyond that, it has
7 to be submerged?

8 MR. BROUGHTON: Yes.

9 MR. EBERSOLE: So it is a level gauge in indirect
10 context.

11 MR. BROUGHTON: It has the limitation that it may
12 tell you that you are not full in the system, but it doesn't
13 tell you how far away you are.

14 MR. EBERSOLE: It has no sense that way, right.

15 MR. BROUGHTON: It is more of a yes-no type
16 indicator than an analog.

17 MR. EBERSOLE: A level meter would be an analog.

18 MR. BROUGHTON: A level meter could be an analog.

19 MR. CLARK: I think one other thing on the St.
20 Lucie incident is that our review shows that with the
21 existing instrumentation and procedures the operator had
22 everything he needed to decide what to do. That really
23 underlies our position on the reactor vessel water level.

24 And if you look at the first two items on the
25 slide, it says, you don't use it in the guidelines of

1 telling the operator what to do. And even if you had it,
2 you couldn't tell him anything else to do. A review of the
3 St. Lucie incident in our view confirmed that.

4 MR. OKRENT: I must say, I find it less than
5 convincing to be told that a review of an event a day or a
6 month or some months after it occurs shows one that there
7 was enough information for the operator to know what to do.
8 That is really not the issue, in a sense. The issue is --

9 MR KERR: Let me clarify his comment. I thought
10 you were saying that the operators at the time knew what to
11 do, not that they would have known what to do had you been
12 operating.

13 Did I misunderstand your comment?

14 MR. CLARK: Somewhat. Let me clarify first.

15 I don't expect to convince myself or you on the
16 basis of one event, one day. The only reason I alluded to
17 the St. Lucie incident is that it is recent. A question was
18 asked. And we had already made a review with B&W and our
19 own people of TMI-2 and other incidents of which we are
20 aware of general analyses of the plant, and asked ourselves
21 for everything that we could postulate, is there enough
22 instrumentation available to the operator to tell him what
23 to do.

24 And we had concluded, based on all of that, that
25 the answer was yes. St. Lucie did not change that prior

1 conclusion.

2 MR. OKRENT: I will stay with my point. It is a
3 hell of a lot easier for an analyst after the incident, when
4 he sees it all in front of him, in the same way it is for a
5 Monday morning quarterback to see whether he should have
6 gone for a touchdown or a field goal, than it is for the
7 operator during the event, when there is a complexity of
8 things going on, and he may just be thinking along another
9 line.

10 I think it is in that context that one asks
11 himself, even if you think you have a system like this,
12 which I think is not completely straightforward, might
13 knowing the water level by some other way be of use or
14 confirm something or be there when another signal is
15 unavailable or whatever.

16 We have a history of instrumentation being there,
17 but the operator not in fact having taken an action.

18 MR. CLARK: We don't disagree, but we feel we need
19 to balance that potential advantage with the disadvantage of
20 potential complexity and additional possibilities of
21 confusion. That is a balance. Our judgment has come out on
22 one side of that.

23 MR. EBERSOLE: I find it interesting to find us
24 discussing the saturation meter in the absence of a level
25 meter, against the narrow context of a theory that we have a

1 pressurizer level system, one that we can in fact put water
2 into and get some pressure in it and so control and maintain
3 a saturation, a margin above saturation.

4 Suppose we have a condition where in fact we have
5 lost the ability to pressurize, and now we need to know
6 where the water is, so that we can cut off any one of X
7 pumps, or else watch them quit, and still declare we're
8 safe. I don't find then that the saturation meter is worth
9 a nickel, and I need to know how much core cover I have.
10 How am I going to know that?

11 I can't fill up to the pressurizer.

12 MR. BROUGHTON: Our guidelines would require that
13 in the absence of a subcooled system that maximum flow
14 through all the available pumps be maintained.

15 MR. EBERSOLE: So I lose X pumps. What do I do
16 then?

17 MR. BROUGHTON: If you have already tried to
18 isolate the leaks you have and you have lost available
19 pumps, you have no more active equipment which you can
20 start. You have all of your active equipment running, you
21 try to repair pumps and you monitor the exit core
22 thermocouple temperatures.

23 MR. EBERSOLE: You would declare that when I reach
24 X number of pump failures, that is the point of calling out
25 the emergency plan or something?

1 MR. BROUGHTON: I believe our emergency plan would
2 have been activated well before that time.

3 MR. MOELLER: Any other comments on this subject?

4 MR. NOVAK: If the Committee wishes, we have about
5 a five-minute presentation -- it could certainly be limited
6 to that -- which might put into focus some of the staff
7 concerns. It is one of the points where I would say -- it
8 is one of the half dozen points where we do disagree with.

9 MR. MOELLER: We haven't heard from the staff for
10 some time, so why don't we listen.

11 MR. NOVAK: Larry Phillips will make the
12 presentation.

13 MR. MOELLER: I was going to comment a little bit,
14 too. There is dispute as to the commercial availability or
15 the status of the potential commercial availability of such
16 instrumentation.

17 MR. PHILLIPS: Before you get frightened by the
18 handout, I only intend to use the first page. The rest is
19 just some information on some various level-monitoring
20 systems which have been proposed and a table showing the
21 general development status and so forth for your
22 information.

23 MR. MOELLER: All right.

24 (Slide.)

25 MR. PHILLIPS: I just want to briefly address the

1 whole concept of the staff review. The objective is to
2 detect and respond to non-mechanistic symptoms of inadequate
3 core cooling, without regard to how we got there or what is
4 causing it.

5 It is indicated by core overheating, the core
6 overheating, that could be due to a two-phase froth level
7 below the top of the core or by local voiding due to flow
8 blockage, a situation of the type at TMI.

9 The requirement is that we want to provide
10 instrumentation to detect the approach to ICC by monitoring
11 coolant saturation conditions and increasing void fraction
12 for decreasing liquid level. Generally, we would speak in
13 terms of increasing void fraction while the pumps are
14 running, and we see it in terms of decreasing liquid level
15 when we cut them off.

16 We want to also detect the existence of ICC by
17 monitoring the two-phase froth level below the top of the
18 core and increasing fuel temperature or coolant superheat.
19 We also want to monitor recovery from this condition, if it
20 should occur. That would be generally your flow blockage
21 condition that we are talking about.

22 The information needs --

23 MR. KERR: You say monitoring recovery would mean
24 core blockage? I don't understand.

25 MR. PHILLIPS: Monitoring recovery from a

1 condition in case it should occur. I am saying, if we think
2 in terms of core exit thermocouples being an aid, for
3 instance, it would be looking at a local flow blockage
4 condition or a gross flow blockage condition, such as we had
5 in TMI, where we saw the thermocouple temperatures come
6 down. We would also see level rise.

7 Now, the information needs are twofold. GPU
8 addresses only the first one, as a basis of operator action
9 to prevent or recover from ICC -- I will come back to that.

10 Secondly, there is a reason for having the level
11 information. This is to assist the operator and supporting
12 emergency operations staff to assess the recovery progress
13 from unidentified situations. Basically, we feel that a
14 level measurement system definitely enhances the operational
15 safety if you get into this type of condition.

16 It definitely gives you, not only the staff at the
17 site but everywhere -- it is valuable information as to
18 where you are and whether you are trending up in level or
19 you are trending down, the situation is getting better or it
20 is getting worse.

21 MR KERR: Can you give me an example of a decision
22 that you would make based on knowing where the water level
23 is?

24 A. PHILLIPS: Yes. Possibly if you can't get the
25 level up, whether to evacuate or not, if in spite of

1 everything you do, you can't get it up. That is a rather
2 gross one, I think. But if I thought for a few minutes I
3 could come up with some better ones.

4 MR. KERR: This is just an indication of whether
5 there is water on the core, not an indication of the water
6 level. I thought you said it was important to know what the
7 water level is during the process.

8 MR. PHILLIPS: What the trend is, sure.

9 Yes, I can give you an example, that is really
10 coming back to the second one, I think -- I mean the first
11 one, the basis for operator actions. If you look at the B&W
12 GPU guidelines, the guidelines are given only for the
13 existing instrumentation, that is, using the core exit
14 thermocouples. We have reviewed guidelines using similar
15 instrumentation on other plants and have determined that
16 those provide adequate safety for those plants to operate.

17 Now we get to the point of enhancement of the
18 guidelines. GPU and B&W, of course, have not -- or anyone
19 else, for that matter -- have not provided guidelines for
20 recovery from ICC with level instrumentation available,
21 because it is not there. Therefore, we question, number
22 one, whether they themselves have taken --

23 MR. KERR: I didn't make my question clear. I'm
24 not trying to be critical. Since you have thought this
25 through, you must have thought of some situation in which

1 knowing the level trend would make you do something
2 different than what you would do if you didn't know it. I
3 am just asking for one example of something you do
4 different.

5 MR. PHILLIPS: What I am saying is we have not
6 reviewed those types of guidelines. So the example I am
7 going to give may or may not be a good thing to do.

8 MR. KERR: I'm not asking if GPU has thought of
9 it. I am asking what you would have thought of that you
10 would do differently if you had this.

11 MR. PHILLIPS: The level right now, GPU calls for
12 depressurizing using the steam generator, and also opening
13 the PORV after the water level has fallen into the core, as
14 depicted by overheating of the -- by superheat on the
15 thermocouples.

16 I question whether, if the water level is falling,
17 definitely trending down after you have -- number one, your
18 first indication would be the saturation meter. Now, after
19 you have gone saturated, if your water level is still
20 falling, trending down, I question whether it wouldn't be
21 wise to depressurize your secondary system earlier in order
22 to increase your WPI flow, and in order to bring in low
23 pressure sources of additional injections, such as
24 accumulators.

25 So I don't think -- I think that you want to

1 avoid, if at all possible, opening the PORV when your water
2 level is already into the core. So I think there is a
3 possibility, even though there are small breaks which will
4 go to core uncover and without -- by design, getting into
5 an ICC type of condition, those events are so rare that
6 possibly, before the possibility of ICC, you may want to
7 consider depressurizing earlier.

8 MR. MOELLER: Does that answer your question, Mr.
9 Kerr?

10 MR. KERR: I don't see why, if you are going to
11 depressurize before the water gets down that low, that the
12 level indication would make you do anything differently. It
13 seems to me that you are saying that with the existing
14 instrumentation you would make a different decision than GPU
15 proposes to make.

16 I am looking for --

17 MR. PHILLIPS: No, I didn't say that. With the
18 existing instrumentation, you don't have an indication until
19 you have fallen into the core. You have the saturation
20 meter.

21 MR. KERR: All right.

22 MR. MOELLER: Does that about wrap it up?

23 MR. PHILLIPS: One couple of other small points.
24 I believe that the level indication definitely enhances your
25 use of the vent system, if you ever go to use that system.

1 That is the top head vent. It definitely would tie into
2 that.

3 I am not sure that the point was clear that, even
4 if we agree with GPU that there are no immediate operator
5 actions, that is, in his emergency procedures due to the
6 inclusion of a water level system, that we still feel that
7 that system should be provided for the second function here
8 of information needs. Now, that is to provide the
9 additional information on the status of the system.

10 MR. BENDER: Given that we or somebody agrees that
11 you need level indication, there is a matter of urgency.
12 We're going to license this plant, and I think the question
13 we need to address is, does the licensing imply a level
14 indicator before you start operating? I think that is a
15 matter of practicality.

16 Is there a level indicator you could get if you
17 needed it? Do you have an answer to that?

18 MR. PHILLIPS: To answer the first part of your
19 question, our position has been that this plant is like
20 other OL's. There is a date of requirement for level
21 instrumentation. That requirement is January 1st, 1982.

22 Yes, we believe there are level indicators that
23 are available which are at least sufficiently developed that
24 there is high confidence that they will do the job.

25 MR. KERR: I thought when I asked Mr. Ross this

1 question at the Subcommittee meeting -- and the question I
2 asked was whether there existed one that could be ordered,
3 that would be approved by NRC -- that his answer was no.
4 Perhaps I misunderstood him.

5 MR. PHILLIPS: I don't think I said anything
6 different. In order to approve it, we need a great deal of
7 additional test information.

8 MR. KERR: The answer is, if a Licensee wanted to
9 order one today, he could not order an NRC-approved one.

10 MR. PHILLIPS: That's right.

11 MR. BENDER: Given you could satisfy the other
12 requirements and get ready before 1982, there would be
13 nothing in the way of running this plant as far as level
14 indication is concerned?

15 MR. PHILLIPS: That's right.

16 MR. BENDER: That's the interpretation I put on
17 it.

18 MR. PHILLIPS: That's right.

19 I would want to make one more comment. The point
20 on the thermocouple in the vessel head, that is a level
21 indicator. It is at discrete axial locations. There have
22 been experiments in LOFT which show that it makes a very
23 effective level indicator.

24 MR. OKRENT: Getting back to Professor Kerr's
25 question, there was a time, I have to assume, when people

1 thought that exit thermocouple temperatures wouldn't be
2 important to safety, or they would have done things
3 differently than they did. I don't really think it would be
4 too hard to develop some scenario where you would like to
5 know whether the level was holding steady after you dropped
6 somewhat below the top of the core, whether it was going
7 down very rapidly or so forth.

8 I would suggest, if one set himself to find some
9 scenario of this type --

10 MR. KERR: I agree with you, and I assumed that the
11 staff had gone through such scenarios and I was looking for
12 one.

13 MR. NOVAK: I have been trying as hard as you to
14 come up with something realistic. It is unlikely that we
15 can follow a specific accident and pin down, okay, here is
16 where a water level indicator would be of use. The thing
17 that happens is you look at operating experience.

18 And I will take the case where you are doing some
19 sort of maintenance on a steam generator and you have opened
20 up the system and you are on decay heat cooling. And all of
21 a sudden, all of your decay heat pumps become air-bound.
22 Now you are sitting there with an open vessel and no way of
23 putting in water.

24 It took you a couple of hours to try to clear the
25 vapor lock on the pumps. And it would be good then to know

1 how quickly your water level is dropping just due to
2 boil-off. Clearly, it is a scenario that you might
3 bootstrap your way around, because something like that has
4 already happened and clearly people thought they had the
5 situation under hand.

6 But a level instrument might have been of use if
7 something else had happened, if you didn't clear those pumps
8 in a couple of hours. So it is hard.

9 MR KERR: I'm not disagreeing. I thought, if you
10 had given it more thought, that you could give me several
11 incidents.

12 MR. PHILLIPS: Basically what I am trying to say
13 is that the saturation meter does not provide an unambiguous
14 indication of impending inadequate core cooling. Therefore,
15 they have to wait until they get into the core to have
16 advance indication. That is, the core is already uncovered,
17 the fuel is heating up, the steam superheat shows it. The
18 level indicator trending down, in spite of the HPI being on,
19 provides them with advanced warning of inadequate core
20 cooling.

21 MR. MOELLER: We will close out on this topic with
22 Mr. Ebersole. It is a generic problem, and of course it is
23 applicable to TMI-1, but I am not sure we are going to solve
24 it here.

25 MR. EBERSOLE: The last statement implies that the

1 saturation meter temperature device is located right above
2 the core. In fact, there is quite a dead band of water
3 between where it is put and the top of the core, within
4 which you might say you are in a dead band, an ignorance
5 band, wherein you could take extraordinary action.

6 MR. PHILLIPS: Absolutely.

7 MR. EBERSOLE: That may be a rather comfortable
8 amount of water, for which you could invoke massive
9 evacuation. I don't think we would do it prior to that. If
10 we were doing pretty good, we could do a variety of things:
11 depressurize the primary loop and so enhance the flow of
12 systems, do things that we might otherwise not do prior to
13 that time.

14 And I don't think we have really worked out the
15 potential of the meter at all. We have tended to try to
16 find ways to discredit the meter, rather than find ways to
17 use it.

18 MR. PHILLIPS: The saturation meter, the thing is
19 that when we have a gross overcooling event, that just a
20 transient will go to saturation. So we don't know that we
21 are as far from an indication that we are going toward
22 inadequate core cooling. We may not be losing cooling at
23 all.

24 Level indication would show the loss of cooling on
25 top of that.

1 MR. EBERSOLE: Right.

2 MR. MOELLER: Thank you, Mr. Phillips.

3 Looking at the agenda, Mr. Arnold, I see you have
4 40 minutes' worth of material remaining, and we have 20
5 minutes on the clock. Which are we going to take up next?
6 Are you ready to go with the hydrogen?

7 MR. ARNOLD: We suggest that items A and B have
8 the higher priority. And Mr. Croneberger will cover item A
9 and will be followed by Mr. Levandoski of B&W.

10 MR. CRONEBERGER: I would like to discuss the
11 general subject of hydrogen inside of containment. I will
12 be summarizing very briefly some of the aspects, primarily
13 of measurements inside of containment, and more especially
14 cover the area which we were unprepared for on the
15 Subcommittee meeting on what studies were performed to
16 address the possibility of stratification of hydrogen inside
17 of containment.

18 (Slide.)

19 First I would like to discuss the reactor coolant
20 high point vents. We are installing vents on each of the
21 hot legs, the top of the candy cane, one vent on the reactor
22 vessel. And we are modifying the pressurizer vent line to
23 permit remote operation.

24 As far as each of the hot leg vents as well as the
25 reactor vessel vent we have the capability of venting

1 one-quarter of the system volume in one hour as a design
2 basis.

3 MR. MOELLER: Can you install the RPV vents
4 without taking the head off the pressure vessel?

5 MR. CRONEBERGER: You can install it without
6 removing the head.

7 MR. EBERSOLE: You are expressing this in the
8 context of noncondensibles, right, not water?

9 MR. CRONEBERGER: Right. As far as the flow
10 diagram, I'm trying to describe one vent back from the head
11 to the atmosphere. And when I talk about the atmosphere,
12 this would be the large air space above the refueling deck
13 in the building. Likewise, a vent path off each of the
14 candy canes to that same air space, and off the pressurizer,
15 venting to the reactor coolant drain tank.

16 Again, as far as the possibility of using the vent
17 system, the major flow, should the system ever have to be
18 used, would be to the major air space above the operating
19 deck.

20 MR. SHEWMON: Do all of those little squiggles and
21 the line on top of the one coming out of the pressure vessel
22 say that you can do it remotely from the control room?

23 MR. CRONEBERGER: Yes, sir.

24 MR. SHEWMON: What about on the candy cane?

25 MR. CRONEBERGER: They can all be operated

1 remotely.

2 MR. EBERSOLE: Are these safety grade vents?

3 MR. CRONEBERGER: They are safety grade. But for
4 each vent path, you do have double valving to maintain
5 isolation. You don't have what might be characterized as a
6 Christmas tree for the flow paths.

7 MR. EBERSOLE: But as a set?

8 MR. CRONEBERGER: That's correct.

9 MR. EBERSOLE: Any pair of these vents is in fact
10 a safety grade configuration; is that right?

11 MR. CRONEBERGER: That's right.

12 MR. EBERSOLE: Have you considered them as
13 alleviating a problem of having inadequate PORV relief?

14 MR. CRONEBERGER: That has been studied, although
15 I don't think that study is complete yet, is that correct?

16 It is being studied right now.

17 (Slide.)

18 The other area discussed briefly is post-accident
19 sampling. We are installing modifications to provide the
20 ability to take a grab sample of the containment atmosphere.
21 This is using existing containment penetration, where we are
22 drawing the sample out of one of the air return ducts in the
23 ventilation system to a point external to the containment.
24 drawing the sample and making provisions for analysis in the
25 lab at the plant.

1 (Slide.)

2 I will show you schematically where that location
3 is. We have within the plant a number of ducts, including
4 these downcomers, which are the return to the building
5 cooling units. We have on this side of the plant a
6 downcomer where we are drawing the air for the grab sample.

7 In addition, divorced from the ventilation
8 ductwork, we are installing two points for permitting
9 continuous measurement of hydrogen in the containment
10 atmosphere post-accident.

11 Thirdly, we are installing hydrogen recombiners, a
12 hydrogen recombiner. And what is shown schematically here
13 is the piping which connects to the installed hydrogen
14 recombiner, which again is drawing air from one of these
15 return ducts.

16 From the hydrogen recombiner standpoint, the
17 concept is that we would have one permanently installed
18 recombiner, which is sized to take the design basis accident
19 generation of hydrogen, and have the ability to install in
20 series -- I'm sorry, in parallel -- an additional
21 recombiner, with that recombiner currently being located at
22 the Unit 2 site on the Island.

23 I would like to spend a little bit more time
24 talking in terms of some of these studies that we have
25 performed on the whole subject of hydrogen dispersion.

1 (Slide.)

2 The first study -- all of these studies that we
3 performed on hydrogen dispersion tend to be relatively gross
4 in scope, to understand what kinds of problems as to
5 potential stratification might exist within the containment
6 volume. The first series of studies, which I will summarize
7 in the next three slides, are based upon some work which was
8 done for us by an outside consultant.

9 What I would like to do is discuss, on the Lehigh
10 studies, in the reverse order as presented here types of
11 scenarios that we felt should be evaluated. One of the
12 evaluations was a concern that on some of the essentially
13 completely enclosed compartments in the basement level,
14 there might be hydrogen generated from radiolysis of the
15 water which would be accumulating in there, and in fact the
16 mechanism for dispersion of that hydrogen outside of that
17 cubicle would be sufficiently slow that we could get a
18 combustible concentration of hydrogen there.

19 Indeed, in that particular case some analyses were
20 performed which indicated that from strictly a molecular
21 diffusion standpoint that no substantial hydrogen
22 concentrations would exist in those enclosed compartments.
23 When I say "enclosed," there are doorways out, but other
24 than that they are complete boxes.

25 MR. SHEWMON: You mean absolutely no convection.

1 MR. CRONEBERGER: Right.

2 The thought was that they might be sufficiently
3 removed from the normal ventilation mixing of the air in
4 there that it was strictly conservatively looking at
5 molecular diffusion.

6 Another area was the controlled venting of the
7 hydrogen to the reactor coolant tank. In this particular
8 case, as I described on the one venting flow path, it was to
9 continue to make use of the pressurizer vent flow path down
10 to the drain tank. And in that case, as a result of the
11 study, it was concluded that, with that controlled venting,
12 which is a relatively slow venting of the primary system,
13 one can control the buildup of pressure in the drain tank
14 until the rupture disc would blow and permit exhausting the
15 hydrogen in spaces outside of the enclosed drain tank
16 compartment.

17 The other area, working up, was control venting of
18 the hydrogen to what at the time of the study was going to
19 be the containment fan cooler system exhaust. At the time
20 of the study, we were considering taking the vents from the
21 reactor vessel and the top of the hot legs and taking them
22 down to the basement and simply exhausting the hydrogen
23 where in fact the air cooler exhaust is also.

24 The study involved a calculation of what, looking
25 at a turbulent jet exhaust from half-inch tube, to determine

1 for the velocities that would be predicted, in trying to vent
2 the primary system, what the dimensions would be at which
3 point the hydrogen concentration within the jet would be
4 down to 4 percent, with 4 percent being used as the lower
5 flammability limit.

6 That calculation predicted that the concentration
7 of hydrogen to the 4 percent limit, where we were exhausting
8 hydrogen from the system, would be something like 18 feet.
9 Now, indeed the designs investigation at that point
10 suggested that there was no real advantage of discharging in
11 the exhaust ventilation system. So we subsequently modified
12 the design to simply vent directly into the large air space
13 above the refueling deck.

14 The fourth area that was investigated in this area
15 was to simply look at the rupture of one of the hot legs and
16 determine what happens when you release the hydrogen
17 concurrent with the release of the fluid.

18 (Slide.)

19 Again, just repeating the model that was used
20 before, the model that I will describe the results here now,
21 it is simply a turbulent jet, with our attempt to identify
22 this Z dimension, which I will show in tabulation, with the
23 Z dimension being that dimension at which the hydrogen
24 concentration no longer exceeds 4 percent.

25 In this particular case, the analytical model --

1 and this analytical model is based upon the hydrogen first
2 being generated at time 25 seconds and exiting this
3 three-foot diameter pipe for a two minute duration. So the
4 entire amount of hydrogen that would be generated would be
5 exhausted at a uniform mass flow rate for that two-minute
6 period of time.

7 The important conclusion from this particular
8 result is that upon first releasing this hydrogen -- and the
9 hydrogen in this case is being released at a substantially
10 lower velocity because of the larger diameter nozzle -- that
11 during this period when you are releasing strictly pure
12 hydrogen this jet would have a dimension, the 4 percent
13 hydrogen concentration, of approximately 70 feet. And this
14 shows the similar dimensions for how far you would have the
15 relatively enriched hydrogen.

16 (Slide.)

17 Now, another scoping study we did do -- and this
18 was being done entirely -- was to say nevertheless, although
19 from a general standpoint there should be general mixing of
20 the hydrogen which would be released into the building, both
21 as a result of ventilation system mixing and as a result of
22 a turbulent jet effect, we wanted to take another scoping
23 study to see what the prospects were for general molecular
24 diffusion, taking no credit for other mixings.

25 In this particular case, we have a two million

1 cubic foot containment, and we assumed 40,000 cubic feet of
2 hydrogen, pure hydrogen, would be released and simply,
3 contrary to previous studies, accumulated at the top of a
4 cylinder like this (Indicating).

5 We assumed conservatively that we were at ambient
6 pressure and we had only 70-degree temperature inside of
7 containment. And what we were trying to find out is, for
8 time zero, with this being the profile, how long would it
9 take to establish both basic equilibrium inside of
10 containment and how long would it take until the
11 concentration here got down to the point where you were
12 substantially below flammability limits.

13 (Slide.)

14 As a result of this study, indeed, with this very
15 conservative model it takes quite a long while before you
16 get steady state conditions inside the building. In a
17 period of one day you are down around 6 percent at the top,
18 which had been the 100 percent hydrogen mixture, with this
19 being a profile, where the bottom of the building still
20 hasn't seen any of the hydrogen due to the diffusion.

21 And at 20 days you are down here at 4 percent.
22 This calculation was relatively gross, a gross scoping
23 calculation.

24 One of the other variables that was looked at was,
25 if instead of 70-degree temperature one was looking at

1 280-degree temperature within the building, this would cause
2 what is shown as the one-day transient to be occurring in
3 approximately six hours, basically a factor of one-fourth of
4 the previous calculation. Again, these were very gross,
5 conservative types of scoping calculations.

6 It does suggest that in fact what had been
7 considered concerns for initial stratification and no basic
8 movement or diffusion of the hydrogen as probably not being
9 realistic.

10 MR. ETHERINGTON: At equilibrium is there any
11 difference, any noticeable difference between top and bottom?

12 MR. CRONEBERGER: It is a small percentage
13 difference, due to the density. That line --

14 MR. ETHERINGTON: That is not equilibrium. It
15 would be essentially straight.

16 MR. CRONEBERGER: that's right.

17 MR. MOELLER: But if it takes 120 days at 70
18 degrees to reach even a sense of equilibrium, that is a long
19 time in comparison to what we are dealing with.

20 MR. CRONEBERGER: The important thing is not
21 having achieved equilibrium, but how long has it taken to
22 get below what might be a detonation limit up here at the
23 top. It does show that if in fact you don't get the general
24 mixing either due to jet effects or the building
25 ventilation, you will have higher concentrations in the --

1 certainly the scope of calculations suggests that shouldn't
2 occur.

3 But even should you, within a matter of hours you
4 start getting relatively rapid molecular diffusion.

5 MR. BENDER: How short does the time interval have
6 to be before you decide to ignore the problem? I think that
7 is really what the question is. Is six hours short enough?
8 Is an hour short enough? That is kind of what we want to
9 know.

10 MR. EBERSOLE: What is the value of time?

11 MR. CRONEBERGER: Let me dismiss the case where
12 you are dealing with the hydrogen being released with a
13 relatively major LOCA, at which I would think that both the
14 jet effects that I talked about before plus the pressure
15 that would result in building spray actuation, that would
16 tend to have major mixing.

17 So we are talking about a case where we are
18 talking in terms of not having any major pressure excursion
19 in the containment, but instead trying to vent the reactor
20 coolant loops themselves. The design basis, as I said,
21 would be to try to vent within one-quarter of the volume of
22 the loop within about one hour.

23 You have the ability to control the rate of
24 release, and I think what one would be concerned about would
25 be something in the order of three to four hours program

1 MR. PLESSET: I think it is a highly idealized
2 calculation. If you are going to make the calculation, you
3 should ask a different question: How long would it take
4 before you had a detonable mixture near the top of the
5 dome? Because the hydrogen comes down. You will get to a
6 detonable mixture at some point.

7 MR. CRONEBERGER: The calculations as far as the
8 turbulent jet would suggest that you would never have a
9 detonable mixture.

10 MR. PLESSET: You are starting with another
11 calculation.

12 MR. CRONEBERGER: Just a bounding calculation.

13 MR. BENDER: You have a release rate and you have
14 a mixing rate, and somehow or other you have got to put
15 those two together. I don't see that that has really been
16 done. Maybe I didn't understand what you told us.

17 MR. CRONEBERGER: Let me go back to what I tried
18 to describe on the turbulent jet associated with venting
19 through one of the vents of the primary system. That
20 analysis suggested that approximately 18 feet from the
21 nozzle -- this was a very idealized case -- that you would
22 have gotten mixing to the point where you were below not a
23 detonable mixture, but a flammable mixture; and which means,
24 because of the location of that, by the time you got up to
25 the dome you would have a mixture substantially below the

1 flammable limit.

2 MR. BENDER: That is a certain kind of jet you are
3 starting with.

4 MR. CRONEBERGER: That is correct.

5 MR. BENDER: It is the right jet?

6 MR. CRONEBERGER: That would be a jet associated
7 with having the system at pressure and completely opening
8 one of those vent paths.

9 MR. PLESSET: I would still think it is more to
10 the point to calculate where you would have a detonable
11 mixture.

12 MR. BENDER: I am uncomfortable with the answer,
13 because if hydrogen burned in TMI-2 then your answer
14 wouldn't have predicted it. That's what worries me. I
15 would like to be able to predict that event and then be able
16 to rationalize why I should or shouldn't worry about it.

17 MR. CRONEBERGER: Indeed, it was because of the
18 investigation of TMI-2 that some of our designs on these
19 vents looked the way they did. Certainly, our evaluation of
20 the data would indicate that the detonation occurred in
21 compartments of the lower portion of containment, where in
22 fact we were above the detonable limit on containment on
23 hydrogen concentrations. And we simply at that time,
24 because we were discharging at a very low point in a
25 relatively enclosed area, hadn't gotten the dispersion of

1 hydrogen.

2 What we are trying to do with the vents is,
3 instead of doing that, is to vent up into the large air
4 space at the top of containment.

5 MR. BENDER: I guess it is coming through better.
6 I apologize for being a little dense.

7 The physical changes which you made in how the
8 stuff is coming out are said to eliminate the possibility of
9 detonation occurring.

10 MR. CRONEBERGER: We are trying to stay away from
11 enclosed compartments as far as releasing hydrogen sources
12 from the system.

13 MR. BENDER: Thank you. I wasn't clear.

14 MR. SHEWMON: How is the operator to know that he
15 should vent his hydrogen out of the top of the candy cane or
16 wherever instead of what he did at TMI-2, I think is the
17 next question in that line?

18 MR. CRONEBERGER: We have some guidelines provided
19 by ESW on how to operate this vent system. These guidelines
20 are under review, and I believe at this time we haven't
21 completed our review. Is that correct?

22 MR. ARNOLD: Yes.

23 MR. SHEWMON: You are saying that - your answer
24 to Mr. Bender was, if he vents the way we hope he vents it,
25 then we don't have problem like we had at TMI-2.

1 MR. CRONEBERGER: The guidelines, as I said, we
2 haven't reviewed yet. Presumably, if one had major venting,
3 it would have to be done not through the pressurizer to the
4 drain tank, but would have to be through one of the other
5 vent paths.

6 MR. SHEWMON: Since you don't have hydrogen
7 detectors on the core, then he has to deduce its existence
8 from something else, which hopefully is in the procedures.

9 MR. CRONEBERGER: Yes, sir.

10 MR. CARSON: Would you please speak a little
11 louder. I'm having difficulty hearing you.

12 MR. EBERSOLE: I would ask -- I thought the
13 venting program was oriented to getting, if you could, a
14 water solid condition in the coolant loop and in no way,
15 except for undesirable aspects, had anything to do with
16 controlling the hydrogen problem.

17 You are trying to use the venting complex, in
18 addition, in a way to control the hydrogen explosion
19 problem. Isn't it to no avail that you tried to do this,
20 since the operator may have had a vent in the system in the
21 very worst possible place and he has a vent that he can't do
22 anything about?

23 MR. PLESSET: I think that's right. But I think
24 he feels -- I am putting words in his mouth -- that since he
25 has to have a venting arrangement, he might as well take an

1 additional advantage.

2 MR. EBERSOLE: But it will only go so far.

3 MR. PLESSET: That's right. The hydrogen might be
4 coming out somewhere else.

5 MR. BENDER: Just being able to turn loose the
6 hydrogen through the vent valve in a better place is
7 certainly an improvement, and we ought to accept that as
8 such. I think I would support the idea. I just didn't
9 understand it well.

10 MR. PLESSET: I object to the calculation that was
11 made. If it's all up there at the top, I would like to say,
12 forget about that calculation with the diffusion.

13 MR. CRONEBERGER: I am showing you what were
14 intended to be broad scoping calculations on the problem.

15 MR. PLESSET: No criticism intended. I guess you
16 were asked to do it.

17 MR. MOELLER: Mr. Chairman, we are now at the time
18 that had been scheduled for the lunch break. We have four
19 of the technical issues that we have not covered. Of the
20 four, perhaps two I would suggest we consider covering, and
21 that is B and F.

22 However, I would like to know the Committee's
23 desires.

24 MR. PLESSET: And leave the others out?

25 MR. MOELLER: Yes. We would leave D and E out.

1 But again, I would want to know whether the Committee would
2 agree with that approach. Hopefully we could do those.
3 They say ten minutes each, but maybe we could do them in 15
4 minutes and then go to lunch.

5 Personally, I would prefer to wrap it up now
6 before lunch.

7 MR. PLESSET: I think we should. I don't hear any
8 great urge to do them all this time.

9 MR. MOELLER: Let's allow five minutes for B and
10 five for F. Mr. Arnold, would that work?

11 MR. ARNOLD: We will do our best.

12 Mr. Levandoski is going to make this presentation
13 for us. He is with Babcock & Wilcox Company.

14 MR. MOELLER: We wanted to be sure to have this
15 one in, so Mr. Shewmon wouldn't be disappointed.

16 MR. LEVANDOSKI: Good morning. Mr. Arnold pointed
17 out, I am from Babcock, Wilcox. I have been asked to come
18 up here to address the item of reactor vessel thermal
19 fraction mechanics at GPU's request.

20 What I will try to do is perhaps summarize the
21 presentation I gave to the Subcommittee last week, and then
22 go back and fill in any missing material if the questions
23 require it.

24 The issue we are talking about has currently been
25 designated by the staff as item 2.X.2.13 of draft

1 NUREG-0737. The staff's request is that a detailed analysis
2 of the reactor thermomechanical conditions be performed on
3 the reactor vessel, assuming a small break has occurred,
4 with an extended loss of all feedwater. We also include the
5 loss of all reactor coolant flow in our analysis
6 assumptions. The staff has asked for a report to be
7 submitted to them by January 1st, 1981.

8 Very quickly, the scenario we are looking at is
9 small break occurring; all feedwater has been lost, all
10 reactor coolant flow has stopped. That then forces you into
11 the situation of providing long-term core cooling by taking
12 water from the borated water storage tank, injecting it into
13 the reactor coolant system cold legs via the HPI system.

14 The fundamental question to be answered in this
15 analysis is that, for a long-term situation where relatively
16 cold water is being injected into the system, do you
17 potentially run the risk of initiating some kind of brittle
18 fracture concern on the reactor vessel due to the cold
19 downcomer fluid?

20 The final objective of the calculation, as I point
21 it out here by key issue number one, is to assess the
22 potential for thermal shock of the reactor vessel, resulting
23 from this long-term safety injection flow. You have to
24 perform a fracture mechanics analysis on the vessel and the
25 weld material.

1 Without going into any of the details, which I
2 gave to the Subcommittee Saturday, this is a very, very
3 complicated situation to try to provide some hard
4 quantification for which would undergo or be sufficient to
5 undergo a rigorous defense. The problem is not so much the
6 mechanics analysis, but more the thermal hydraulics
7 analysis.

8 MR. OKRENT: Which of these two is your specialty,
9 or is it both?

10 MR. LEVANDOSKI: Thermal hydraulics more than
11 mechanics. For example, what you have to do is determine
12 the transient temperature gradient in the reactor vessel
13 walls. To do that, you have to know the coolant temperature
14 next to the wall.

15 To know that coolant temperature, that requires a
16 pretty good knowledge of the mixing and flow rates taking
17 place between the vent valve flow and the flow rate coming
18 into the downcomer from the inlet nozzle.

19 The temperature in the cold leg itself is also a
20 function of the fluid residing in the cold leg, plus the
21 temperature and the flow rate of the HPI fluid being
22 injected. Obviously, the mixing occurring in these regions
23 is the area where we have the principal uncertainty. It is
24 highly flow-dependent, temperature-dependent, to a certain
25 degree pressure-dependent, and probably more than anything

1 else, geometry-dependent.

2 And we are talking about a very complex geometric
3 situation between the injection point for the HPI water and
4 finally the location out here, against the reactor vessel
5 weld.

6 MR KERR: The suspense is getting to me. Are you
7 going to tell me that this was impossible, or it was very
8 difficult and B&W is clever?

9 (Laughter.)

10 MR. LEVANDOSKI: I'm not going to tell you it is
11 impossible. I will tell you we probably don't know how to
12 do it right now to the point where we think we could walk
13 into the staff and say, this is the answer.

14 MR. PLESSET: Then don't try it here.

15 (Laughter.)

16 MR. LEVANDOSKI: I'm not going to.

17 (Slide.)

18 As a result of that uncertainty, what we have done
19 is put together a very, very generic, conservative -- the
20 word "cross" has been used several times this morning. I
21 think it applies here more than any other place I have heard
22 it.

23 We have put together, as I said, a very generic
24 bounding analysis set of assumptions to cover all of the B&W
25 operating plants. This is not to say that we think the

1 problem should end here with this type of bounding
2 calculation. But it is a model we have put together as an
3 initial step with the staff, so that ongoing actions can
4 continue and discussions with the staff can commence on what
5 is actually the best way to try to quantify the situation.

6 This conservative evaluation primarily consists of
7 five gross assumptions. For example, rather than trying to
8 address the mixing explicitly, we have simply made the
9 assumption, no mixing occurs between the vent valve fluids,
10 the HPI fluids, and the fluids residing in the cold leg
11 inventory.

12 So in fact, what this essentially means is that
13 water coming from the borated water storage tank is assumed
14 to eventually directly lie up against the reactor vessel
15 wall. We have used the minimum allowable fluid temperature
16 in the borated water storage tank allowed by the technical
17 specifications. In the case of TMI-1, this would be 40
18 degrees, even though in fact TMI-1 BWST temperature is being
19 heated to 68 degrees.

20 We have assumed an infinite heat transfer
21 coefficient between the wall, the fluid next to the wall,
22 and the wall material itself. . . that accomplishes for
23 you is it makes the wall temperature of the vessel
24 instantaneously cooled down to the 40 degree temperature
25 that we have assumed for the BWST fluid.

1 MR. SHEWMON: Sir, let me ask a couple of
2 questions. You are talking about the downcomer only, this
3 calculation. And this is well above its ductile brittle
4 transition temperature. You know that much about it. And
5 you are talking about a one-cycle strain-limited fatigue
6 test; is that right?

7 Now, even if you had instantaneous cooling for 30
8 degrees, so what? Is it really going to make any
9 difference?

10 MR. LEVANDOSKI: We are talking about decreasing
11 the temperature about from 550 down to 40 degrees.

12 MR. SHEWMON: Then it is not above the
13 ductile-brittle transition. And this is a hotday pipe in
14 your plant, is that right?

15 MR. LEVANDOSKI: The hot leg?

16 MR. SHEWMON: Whatever you are doing your 100
17 degree subcooling on.

18 MR. LEVANDOSKI: I'm not at that point yet. Let
19 me put this in perspective.

20 MR. SHEWMON: Let me try to find out what the pipe
21 is and what the temperature excursion is.

22 MR. LEVANDOSKI: The temperature excursion. Let
23 me address that first. The vessel wall material subjected
24 is 550 down to 40 degrees.

25 MR. SHEWMON: So you will get out of the downcomer

1 and into the -- okay, let's go on.

2 MR. KERR: I think you are trying to rush him,
3 Professor Shewmon.

4 MR. SHEWMON: Yes.

5 MR. LEVANDOSKI: Let me just quickly say that we
6 have also assumed the worst weld material properties to
7 exist directly in the flow stream of the 40-degree coolant,
8 and that we have allowed this situation to exist despite
9 operator guidelines which would cause him to take actions to
10 help alleviate this situation.

11 What we have found, the results show that with the
12 operator throttling HPI flow to maintain 100 degrees
13 subcooling, that for the conservative bounding analysis
14 which has been carried out to an irradiation value of an
15 additional .5 effective full power years beyond where we are
16 now for the worst plant, the results are still acceptable.

17 As I pointed out to the Subcommittee -- and I will
18 repeat it here -- this is not to say that in one-half an
19 effective full-power year we necessarily have a problem.
20 This is just the time frame to which the analyses have been
21 taken out.

22 MR. SHEWMON: The half effective full-power year
23 doesn't mean that he keeps running cold water over this for
24 that long. It must mean that it gets that much more
25 irradiation in it.

1 MR. LEVANDOSKI: That is exactly right. The
2 actual term of the transient we are talking is about ten
3 hours.

4 MR. OKRENT: Implicit is some flaw size?

5 MR. LEVANDOSKI: Yes. We used the Section 11
6 ASME, and the flaw size was .5 inches, initial flaw size.

7 MR. OKRENT: We ought to consider it in a sense
8 probabilistic. Some things are taken conservatively and
9 some things according to regulation.

10 MR. EBERSOLE: I have two questions. When you
11 said instantaneous cooldown of metal to HPI fluid
12 temperatures, you are just talking about the interface for
13 the metal, a few thousandths?

14 MR. LEVANDOSKI: Yes, the surface temperature.

15 MR. EBERSOLE: So you have a gradient in which the
16 inside is contracting and the outside is still hot. And the
17 second one is, in B&W's opinion is this the worst sort of
18 thermal transient that you can have in the context of
19 repressurization and achieving maximum rates of cooldown and
20 take into account massive secondary side failures as being
21 one mechanism? And if you want to be conservative, you can
22 augment that by run-on of main feedwater?

23 Is this the worst end of the cooldown problem and
24 the resulting repressurization, or is it just a place
25 somewhere in between that the staff pointed to?

1 MR. LEVANDOSKI: The analysis of the size of
2 breaks that we have addressed so far range from .007 square
3 feet to .023 square feet.

4 MR. EBERSOLE: I said zero breaks; secondary side
5 depressurization.

6 MR. LEVANDOSKI: The thinking there is that
7 secondary side, you have a certain amount of natural
8 circulation flow occurring in the primary loop.

9 MR. EBERSOLE: But you have a severe cooldown,
10 however.

11 MR. LEVANDOSKI: True. But we don't see --

12 MR. EBERSOLE: Have you looked at the thermal
13 transients associated with the full-scale steam line break,
14 the continuity of run-on --

15 MR. LEVANDOSKI: The answer is no.

16 MR. EBERSOLE: Do you not now know whether that is
17 at the worst end of this thermal shock spectrum, or do you
18 know where that is? What transient event can produce the
19 worst shock event?

20 MR. LEVANDOSKI: I have to say we haven't
21 evaluated all of the possible events to come up with that
22 final conclusion.

23 MR. EBERSOLE: Just do that one, then, the
24 secondary side main steam line failure and prolonged
25 cooling. The primary loop will come down in temperature.

1 The reactivity problem will bucket for a while, but in the
2 final array you will have cooling to the secondary circuit
3 at atmospheric pressure. And if you have the pumps running
4 on, you will have a prodigious rate of cooling.

5 u can, of course, argue that you will turn the
6 pumps off and go ahead and do that.

7 MR. LEVANDOSKI: Okay.

8 MR. MOELLER: Does that about wrap it up? That
9 pretty much wraps up what I have.

10 MR. ETHERINGTON: I don't understand the 30-degree
11 downcomer mixing, the 30 percent, rather. What is the
12 condition of the water in the downcomer?

13 MR. LEVANDOSKI: I really haven't addressed
14 this.

15 A second analysis was performed, for comparative
16 purposes more than anything else. Assuming that we did have
17 30 percent mixing --

18 MR. ETHERINGTON: At what temperature is the water
19 it is mixing with?

20 MR. LEVANDOSKI: We are talking about 40-degree
21 water coming in the cold leg and the vent valve fluid, which
22 is in the temperature range of about 500 degrees, 500 to
23 600.

24 MR. ETHERINGTON: Hasn't that all been replaced by
25 the HPI; the continual inflow of cold water there, haven't

1 you? How do you have hot water remaining in the downcomer?

2 MR. LEVANDOSKI: You find that the vent valves
3 remain open throughout this transient.

4 (Slide.)

5 MR. PLESSET: He has hot water from the core
6 spilling down from the downcomer into the open vent valve.
7 So he does have the two different --

8 MR. LEVANDOSKI: The vent valve fluid has
9 traversed the core and is coming out.

10 MR. PLESSET: That is a special feature of this
11 design, that he can get that.

12 Dade, I would urge that we move along.

13 MR. MOELLER: I think so. Does this wrap this
14 up?

15 MR. LEVANDOSKI: Yes.

16 MR. MOELLER: Why don't we handle item F simply by
17 questions. I think the Subcommittee had questions of the
18 staff, probably primarily in the sense that we read the
19 quotation or what we understood was a quote that the
20 pressurizer heater was not essential to save reactor
21 performance.

22 They used several different words.

23 MR. KERR: You have to be careful about the
24 language.

25 MR. MOELLER: Right. Can you offer comments and

1 clarify the questions that we have?

2 MR. PLESSSET: I thought the questions related to
3 the fact that putting the pressurizer heaters on this
4 emergency supply degraded other systems?

5 MR. MOELLER: Yes. It has to be phased in just a
6 certain way and so forth.

7 MR. PLESSSET: Thanks.

8 MR. CONRAN: As I understood the question, it
9 involved discrepancies between two pieces of testimony,
10 Walter Jensen's testimony on Contention UCS-3 about
11 pressurizer heaters and my testimony, which is a more
12 general treatment of definitions: what is important to
13 safety, what is safety-grade, which of the pieces of
14 formerly non-safety pieces of equipment that came into play
15 at TMI-2 should now be considered safety grade, and that
16 sort of thing.

17 In that context, Mr. Jensen's testimony said
18 pressurizer heaters are not important to safety and they do
19 not have to be safety-grade. And just to get right to the
20 point, that is inconsistent with the definition of important
21 to safety that is in my testimony, that has been accepted by
22 the organization. And we are all instructed now to use that
23 definition.

24 I think the problem was, Mr. Jensen's testimony
25 was finalized before mine was, and it reflects inconsistent

1 usage of the term "important to safety" by different people
2 on the staff. The fix is to change the testimony to read
3 something like, by definition it is important to safety, but
4 the decision with respect to safety grade still is that it
5 does not have to be safety grade. The pressurizer heaters
6 are not required to mitigate accident consequences that were
7 in question, and therefore they do not have to be safety
8 grade.

9 MR. EBERSOLE: That implies that devices that
10 prevent accident sequences don't have to be safety grade,
11 and that's not so.

12 MR. CONRAN: It doesn't imply at all that such
13 components would not have to be safety grade. With respect
14 to the pressurizer heaters, they are important to safety
15 because they fall within a definition given within the
16 preamble to the general design criteria.

17 But more to the point, I think, in the discussion
18 that was going on with the Subcommittee meeting, they are
19 not required -- they are not required to perform critical
20 accident mitigation functions. There are other safety
21 systems or components that can be relied upon. So even
22 though they are important to safety by definition, they are
23 not critically important to that critical safety, that very
24 specific safety function. And therefore they do not have to
25 be safety grade.

1 MR. JENSEN: I would like to make one
2 clarification. What I was trying to show in my testimony
3 was that if the pressurizer heaters failed, there would be
4 no -- the public health and safety would not be affected.
5 There are other systems, the makeup systems, the letdown
6 systems, that could be operated by the operator, and the
7 high pressure injection system could be put into play by the
8 operator to maintain an adequate pressure in the primary
9 system.

10 MR. MOELLER: Are there questions on that?

11 (No response.)

12 MR. MOELLER: I think, Mr. Chairman, we might, I
13 presume, let the staff have a minute for any wrapup they
14 want, and then the licensee a minute for any final comments
15 from them. That way, we will finish at 1:30.

16 MR. NOVAK: Just a point. We will go back and
17 read the transcript with regard to the need to provide a
18 document which identifies what is the status of the open
19 items.

20 I think the problem here is that if you had a head
21 count there are very many of them that improved. The
22 significant ones, I think we can highlight them and provide
23 enough of an understanding of them so that the document
24 itself that you read would give you enough understanding of
25 where the staff feels that the licensee is still missing

1 information for us to complete our review regarding the
2 restart.

3 Also, in terms of writing a letter regarding the
4 status as you see it today, I would certainly encourage the
5 Committee, if they feel that there are portions of our
6 requirements that should be enlarged upon -- and again, I
7 will just use the point of the deciding consideration that
8 was discussed by Dr. Okrent earlier -- if the Committee
9 desires these kinds of studies, I think it is incumbent on
10 them, then, to identify it in the letter.

11 At this point in time we do not have any plans to
12 do anything in specific with regard to Three Mile Island 1
13 and its site. In a sense, this is no different than the
14 Commission itself suggesting that the order should be
15 reviewed with regard to its sufficiency, that the staff, for
16 example, beyond the orders themselves, has decided that
17 Three Mile Island 1, as a prerequisite to startup, should
18 meet the essentials of a near-term operating license.

19 Many of the things with regard to control room
20 review are a reflection of that position. We would
21 certainly look at the letter and, in concert with the
22 direction that the letter gave us, go ahead on that basis.

23 MR. MOELLER: Thank you.

24 MR. SHEWMON: I am not sure when -- and it
25 certainly doesn't come from him, so let -- bring one last

1 question up with the staff. One of the things that the
2 staff has in their five-year plan has to do with possible
3 hydrogen damage to the pressure vessel head from reasonable
4 temperature and high hydrogen pressure.

5 I wondered if or where I might get an
6 authoritative description of what the pressure-temperature
7 history was for that head, how much level there was, and
8 what was being interpreted as a bubble wasn't particularly
9 clear to me and may have changed. I would be interested in
10 seeing that.

11 And if you could give us a reference on where I
12 might find that, I would appreciate it.

13 MR. KERR: You are talking about TMI-2 and not
14 TMI-1?

15 MR. SHEWMON: Right.

16 MR. MOELLER: Mr. Arnold, for a final minute.

17 MR. ARNOLD: I will make it only 60 seconds. The
18 company very much appreciates a chance to be before the
19 Committee. We appreciate your patience through what has
20 been a significant overrun on the schedule.

21 I would ask consideration or re-emphasis,
22 reiteration I think of only one point that we have made
23 previously, and that is that I think any assistance that the
24 Committee can give in helping to clarify or to provide their
25 viewpoint on what are those things that are in fact required

1 to be in place prior to restart, I am sure all parties would
2 find that helpful.

3 MR. MOELLER: Thank you.

4 MR. PLESSET: Thank you, Dade, and thank you, Tom
5 and Mr. Arnold.

6 And maybe when you come back on this subject
7 again, you will be ahead of schedule rather than behind.

8 We will recess for lunch, until 2:30.

9 (Whereupon, at 12:29 p.m., the Committee recessed,
10 to reconvene at 2:30 p.m. the same day.)

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: 248TH GENERAL MEETING OF THE ADVISORY
COMMITTEE ON REACTOR SAFEGUARDS

Date of Proceeding: December 4, 1980

Docket Number: _____

Place of Proceeding: Washington, D. C

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Barbara L. Whitlock

Official Reporter (Typed)

Barbara L. Whitlock

Official Reporter (Signature)

RESTART SER OPEN ITEMS

NUREG-0680 OPEN ITEMSSTATUS

79-05B-1	NATURAL CIRCULATION - ANALYSIS OF ANTICIPATORY FILL	AWAITING LICENSEE SUBMITTAL (RESTART)
79-05B-5	ANTICIPATORY TRIPS - CHECK OUT PROCEDURE	START UP CHECKOUT
79-05B-7	TECH SPEC CHANGES	DRAFT AWAITING REVIEW (RESTART)
79-05C-5	INADEQUATE CORE COOLING PROCEDURES	REVIEW IN PROGRESS (RESTART)
3	EMERGENCY PLANNING - TEST EXERCISE	(RESTART)
4	SEPARATION OF TMI-1 & 2 GASEOUS RADWASTE - ESF FILTER DETAIL DESIGN	SUBMITTAL SCHEDULED JUNE 1981 (RESTART)
5	WASTE MANAGEMENT SOLID RADWASTE SYSTEM - PLANS FOR LOW ACTIVITY STORAGE	RESPONSE INADEQUATE (RESTART)
6	MANAGEMENT	
--	TRAINING PROGRAM FOR UNLICENSED PERSONNEL	LICENSEE TO RESPOND (RESTART)
--	LONG-TERM OPERATOR TRAINING	LICENSEE TO RESPOND (RESTART)
--	FACILITY PROCEDURES	LICENSEE TO RESPOND (RESTART)
--	HEALTH PHYSICS	LICENSEE TO RESPOND TO 11/26/80 LETTER (RESTART)
--	OPERATIONAL QA - Q LIST	AWAITING LICENSEE RESPONSE (RESTART)
7	FINANCIAL - REVISED FINANCIAL PLAN	AWAITING LICENSEE RESPONSE

RESTART SER OPEN ITEMS

NUREG-0680 OPEN ITEMS

STATUS

8 - 2.1.1	EMERGENCY POWER SUPPLY FOR PRESSURIZER LEVEL & BLOCK VALVES - PROCEDURES	AWAITING REVISED PROCEDURES
8 - 2.1.3.A	VALVE POSITION INDICATION - ADDITIONAL JUSTIFICATION FOR SV'S - PROCEDURES	AWAITING LICENSEE RESPONSE (RESTART)
8 - 2.1.3.B	INADEQUATE CORE COOLING - EXISTING INSTRUMENTATION ANALYSIS, COMMITMENT, SCHEDULE DESCRIPTION	RESPONSE OF DECEMBER 79 CONSIDERED ADEQUATE BY LICENSEE, NUREG-0737 REQUIRES ADDITIONAL RESPONSE BY 12/15/80 (RESTART)
8 - 2.1.4	CONTAINMENT ISOLATION - DETAIL DESIGN INFORMATION	SUBMITTAL SCHEDULED JANUARY 1981 (RESTART)
8 - 2.1.6.A	SYSTEM INTEGRITY - PROCEDURES	AWAITING PROCEDURES (RESTART)
8 - 2.1.6.B	PLANT SHIELDING - DESIGN REPORT	REVIEW IN PROGRESS - PROBABLY NOT COMPLETE (RESTART)
8 - 2.1.7.A	AFW AUTO INITIATION - DETAIL DESIGN OF LEVEL INDICATION AND LONG-TERM MODS - TECH SPECS	CONCEPTUAL DESIGN REVIEW IN PROGRESS. DETAIL SUBMITTAL JANUARY 81 (RESTART)
8 - 2.1.8.A	POST-ACCIDENT SAMPLING - SYSTEM DESIGN, PROCEDURES	JUSTIFICATION FOR EXISTING SYSTEM NOT COMPLETE. (RESTART) IMPLEMENTATION OF NEW DESIGN DELAYED UNTIL 1/82.
8 - 2.1.8.B	RADIATION MONITOR RANGE - LONG-TERM DESIGN DETAILS - PROCEDURES	AWAIT SUBMITTALS. LONG-TERM EQUIPMENT AND PROCEDURES PRIOR TO RESTART. IF DELAY SHORT-TERM PROCEDURES WILL BE USED.
8 - 2.1.8.c	IODINE INSTRUMENTATION - PROCEDURES & TRAINING	AWAITING LICENSEE RESPONSE
8 - 2.1.9.B	TRANSIENT & ACCIDENT ANALYSIS FOR INADEQUATE CORE COOLING - REVIEW ANALYSIS - PROCEDURES	REVIEW IN PROGRESS (RESTART)
8 - 2.2.2.B	ONSITE TECH SUPPORT CENTER - PROCEDURES	REVIEW IN PROGRESS (RESTART)
8 - Add 4-RCS	VENTING - DETAIL DESIGN & ANALYSIS	SUBMITTAL SCHEDULED JULY 1981 (RESTART)
LONG-TERM 2	SMALL BREAK ANALYSIS - PROVIDE ADDITIONAL INFORMATION	REVIEW IN PROGRESS

TMI-1 RESTART HEARINGS
EMERGENCY PREPAREDNESS CONTENTIONS
(ONSITE)

1-3

GENERAL CATEGORY	NUMBER OF CONTENTIONS	CONCERNS RAISED
ASSIGNMENTS OF RESPONSIBILITY (ORGANIZATIONAL CONTROL)	7	<ul style="list-style-type: none"> ● NEED FOR IMPROVED AGREEMENTS TO PERFORM EMERGENCY SERVICES
ONSITE EMERGENCY ORGANIZATION	3	<ul style="list-style-type: none"> ● INSUFFICIENT PERSONNEL TO CONDUCT DOSE ASSESSMENT AND MONITORING ● MULTIPLE RESPONSIBILITIES ASSIGNED CERTAIN INDIVIDUALS IN EMERGENCY ORGANIZATION
EMERGENCY CLASSIFICATION SYSTEM	2	<ul style="list-style-type: none"> ● VALIDITY OF EMERGENCY CONDITION INDICATORS ● IMPROPER CLASSIFICATION OF SPECIFIC ACCIDENTS TO EMERGENCY CATEGORIES
NOTIFICATION METHODS AND PROCEDURES, AND COMMUNICATIONS	7	<ul style="list-style-type: none"> ● NOTIFICATION OF AGENCIES AND COUNTIES ● EDUCATION OF PUBLIC ON EMERGENCY RESPONSE ● AVAILABILITY OF INFORMATION TO OFFSITE GROUPS ● SUFFICIENCY OF COMMUNICATION LINKS
ACCIDENT ASSESSMENT	7	<ul style="list-style-type: none"> ● ADEQUACY OF RADIOLOGICAL INSTRUMENTATION AND PROCEDURES ● OFFSITE MONITORING CAPABILITY ● EXPERTISE OF EMERGENCY MANAGERS
PROTECTIVE RESPONSE	8	<ul style="list-style-type: none"> ● ADVERSE CONDITION PROTECTIVE RECOMMENDATIONS ● RESPONSE AND ASSESSMENT TIMES ● SELECTION OF EMERGENCY PLANNING ZONES
MAINTENANCE OF EMERGENCY PLANNING	2	<ul style="list-style-type: none"> ● ADEQUACY OF DRILL SCENARIOS ● PLAN MODIFICATIONS DUE TO CHANGING CONDITIONS OF OBSERVED PROBLEMS

TMI-1 RESTART HEARINGS
EMERGENCY PREPAREDNESS CONTENTIONS
(OFFSITE)

GENERAL CATEGORY	NUMBER OF CONTENTIONS	CONCERNS RAISED
ASSIGNMENTS OF RESPONSIBILITY	12	<ul style="list-style-type: none"> ● LACK OF COORDINATION BETWEEN VARIOUS FIRE/POLICE SERVICES ● EMERGENCY WORKER COMMITMENTS AND AVAILABILITY
EMERGENCY RESPONSE SUPPORT AND RESOURCES	13	<ul style="list-style-type: none"> ● POLICE/MILITARY COMMAND AND CONTROL ● ADEQUACY OF EMERGENCY RESOURCES AT LOCAL LEVEL (PERSONNEL AND EQUIPMENT) ● LACK OF EMERGENCY CONTINGENCY FUNDS
NOTIFICATION METHODS AND PROCEDURES	13	<ul style="list-style-type: none"> ● EDUCATION OF PUBLIC ON EMERGENCY RESPONSE ● PROMPT NOTIFICATION IN PLUME EPZ
EMERGENCY COMMUNICATIONS	7	<ul style="list-style-type: none"> ● INADEQUATE EMERGENCY COMMUNICATION LINES AND OPERATORS ● STATUS OF LOCAL EOC INSTALLATIONS
PUBLIC INFORMATION	4	<ul style="list-style-type: none"> ● DISSEMINATION OF PUBLIC INFORMATION ON PROTECTIVE ACTIONS TO BE TAKEN DURING EMERGENCY
EMERGENCY FACILITIES AND EQUIPMENT	8	<ul style="list-style-type: none"> ● PROVIDING EQUIPMENT AND MAINTAINING IT ● STATUS OF LOCAL EOC FACILITIES ● FACILITIES FOR PROTRACTED ACCIDENTS AND EVACUATIONS

TMI-1 RESTART HEARINGS
EMERGENCY PREPAREDNESS CONTENTIONS
(OFFSITE)

GENERAL CATEGORY	NUMBER OF CONTENTIONS	CONCERNS RAISED
PROTECTIVE RESPONSE	35	<ul style="list-style-type: none"> ● ADEQUACY OF EVACUATION PLANS ● EVACUATION DURING ADVERSE CONDITIONS ● PROTECTIVE ACTIONS FOR ELDERLY, INSTITUTIONS AND SPECIAL CASES ● PROTECTION OF LIVESTOCK ● SELECTION OF EMERGENCY PLANNING ZONES ● TIME PERIODS FOR PROTECTIVE ACTIONS
RADIOLOGICAL EXPOSURE CONTROL AND PUBLIC HEALTH SUPPORT	8	<ul style="list-style-type: none"> ● DISTRIBUTION OF THYROID BLOCKING AGENTS (KI) ● DECONTAMINATION FACILITIES AND PROCEDURES ● CARE FOR RADIATION VICTIMS ● AVAILABILITY OF CARE FOR EVACUATED HOSPITAL PATIENTS
MAINTENANCE OF EMERGENCY PREPAREDNESS	7	<ul style="list-style-type: none"> ● ADEQUACY OF DRILLS TO TEST EMERGENCY ORGANIZATIONS ● ADEQUACY OF TRAINING OF EMERGENCY WORKERS

CONTENTIONS & BOARD QUESTIONS

DESIGN AND ANALYSIS

NATURAL & FORCED CIRCULATION

- UCS-1 NATURAL CIRCULATION IS INADEQUATE TO COOL THE CORE
- UCS-2 FORCED COOLING METHODS DO NOT MEET REGULATIONS
- BOARD QUESTION 6D, 6E, 6F - QUESTIONS ON FEED AND BLEED

ADDITIONAL LOCA ANALYSIS

- UCS-8 PERFORM ANALYSES FOR SPECTRUM OF SMALL BREAKS
- ECNP-1E

BOARD QUESTION UCS-8 ADDRESS RECOMMENDATIONS OF NUREG-0565 AND 0623. JUSTIFY RELIANCE ON OPERATOR ACTION

EFW RELIABILITY

BOARD QUESTIONS 6.A-C, G-K QUESTIONS ON RELIABILITY OF EFW

SAFETY SYSTEMS BYPASS AND OVERRIDE

- UCS-10 SAFETY SYSTEM FUNCTIONS SHOULD NOT BE MANUALLY OVERRIDDEN OR SHOLLY 3 BYPASSED

SAFETY CLASSIFICATION

- UCS-12 SAFETY-RELATED EQUIPMENT TO BE ENVIRONMENTALLY QUALIFIED BY RESTART.
- UCS-14 ALL COMPONENTS WHICH CAN CAUSE, AGGRAVATE, OR MITIGATE ACCIDENTS SHALL BE SAFETY GRADE.
- UCS-3 PZR HEATERS SHOULD BE SAFETY GRADE
- BOARD QUESTION UCS-12 ENVIRONMENTAL QUALIFICATION, INCLUDING RADIATION

VALVES AND VALVE TESTING

- UCS-5 PORV AND BLOCK VALVES SHOULD BE SAFETY GRADE
- UCS-6 PERFORM QUALIFICATION TESTS ON SAFETY AND RELIEF VALVES
- BOARD QUESTION ON UCS-6- WILL VALVES PERFORM IN ACCIDENT ENVIRONMENT

CONNECTION OF PRESSURIZER HEATER TO DIESEL

- UCS-4 PZR HEATERS WILL DEGRADE EMERGENCY POWER

INTEGRATED CONTROL SYSTEM

- SHOLLY 6A - FMEA OF ICS SHOULD BE SHORT-TERM

CONTAINMENT ISOLATION

SHOLLY 1 - SAFETY GRADE RADIATION SIGNALS FOR PURGE AND SUMP.

FILTERS

LEWIS - UPGRADE AUX BUILDING FILTERS

ANGRY V(D) - PROVIDE EFFLUENT FILTRATION FOR LARGE VOLUMES OF GAS AND LIQUID BY RESTART

COMPUTER

SHOLLY 13 - COMPUTER UPGRADE PRIOR TO RESTART

ECNP-1A - COMPUTER IS INADEQUATE - SLOW AND AMBIGUOUS

SAFETY SYSTEM STATUS PANEL

UCS-9 - A R.G. 1.47 SYSTEM STATUS PANEL SHOULD BE PROVIDED

ECNP-1C - CONTROL SYSTEM SHOULD RECORD ALL NECESSARY PARAMETERS

INSTRUMENT RANGES

SHOLLY 5 - HIGH RANGE EFFLUENT MONITORING PRIOR TO RESTART

ECNP-1D - ALL MONITORING INSTRUMENTS COVER FULL RANGE OF CONDITIONS

DETECTION OF INADEQUATE CORE COOLING

UCS-7 - REQUIRE RV WATER LEVEL MEASUREMENT

ANGRY-V(B) - REQUIRE WATER LEVEL INDICATION BY RESTART

SHOLLY-6B - REQUIRE ICC DETECTION INSTRUMENTATION BY RESTART

CONTROL ROOM DESIGN - HUMAN FACTORS

SHOLLY-15 - COMPLETE CRDR BY RESTART

ANGRY-V(C) - ANALYZE AND MODIFY CONTROL ROOM BY RESTART

CLASS 9

UCS-13 - TMI-1 DOES NOT PROTECT AGAINST CLASS 9 ACCIDENTS

SHOLLY-17 - ANALYZE HEALTH EFFECTS OF CLASS 9 SEQUENCES BEFORE RESTART

ECNP-4B - EVALUATE CONSEQUENCES OF TMI-2 ACCIDENT WITH EOL CORE

4C - EVALUATE CONSEQUENCES OF TMI-2 ACCIDENT WITH LOSS OF ACCESS TO SPENT FUEL.

ADDITIONAL BOARD QUESTIONS

1. STAFF POSITION ON NUREG-0694 REQUIREMENTS.
2. HOW HAS STAFF IDENTIFIED ALL REQUIREMENTS AND ACCIDENT SEQUENCES.
3. WILL IREP BE APPLIED TO TMI-1.
4. PLACEMENT OF DOSE RATE METERS.
5. STAFF POSITION ON NUREG-0660.
7. APPLICATION OF NUREG-0667 (CRYSTAL RIVER).
9. GROUNDWATER CONTAMINATION.

SEPARATION OF UNIT 1 AND 2

- CEA-5 - IMPACT OF UNIT 2 DECONTAMINATED WATER ON WATER STORAGE SPACE AND OPERATION FOR UNIT 1.
 - CEA-6 - "LEAKAGE" FROM UNIT 2 IMPACT ON WATER STORAGE CAPACITY.
 - CEA-7 - ADEQUACY OF RADIATION MONITORING TO DISCRIMINATE BETWEEN UNIT 1 AND 2 EFFLUENTS
- BOARD QUESTION 8 - PARALLELS CEA-7

MANAGEMENT

- AAMODT 2 - CERTIFICATION BY INDEPENDENT ENGINEERING FIRM FOR TECHNICIANS AND MANAGEMENT PERSONNEL.
- ANGRY 4 - INSUFFICIENT MANAGEMENT CAPABILITY AS DEMONSTRATED BY ACTIONS BEFORE AND DURING ACCIDENT.
- TMIA 5 - LACK OF TECHNICAL QUALIFICATION. EMPHASIS ON MAINTENANCE ACTIVITIES
- BOARD QUESTION 10 - EXPLAIN 6/27/80 ACCIDENT, DISCUSS MAINTENANCE HISTORY.
- SHOLLY 14 - INSUFFICIENT MANAGEMENT CAPABILITY. ADM. STRUCTURE, STAFFING, HP, SAFETY REVIEW, MAINTENANCE.
- CEA-13 - TRAINING OF OPERATORS - (MINDSET)

T-2,5

GPU NUCLEAR GROUP
ORGANIZATION

GPU NUCLEAR GROUP

PURPOSE

MANAGE AND DIRECT THE NUCLEAR ACTIVITIES OF THE GPU SYSTEM TO PROVIDE THE REQUIRED HIGH LEVEL OF PROTECTION FOR THE HEALTH AND SAFETY OF THE PUBLIC AND THE EMPLOYEES.

CONSISTENT WITH THE ABOVE, GENERATE ELECTRICITY FROM THE GPU NUCLEAR STATIONS IN A RELIABLE AND EFFICIENT MANNER IN CONFORMANCE WITH ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND OTHER REQUIREMENTS AND THE DIRECTIONS AND INTERESTS OF THE OWNERS.

GPU NUCLEAR CORP

STATUS 11/80

- o FORMATION OF GPU NUCLEAR CORP APPROVED BY SEC
- o DIRECTORS AND OFFICERS ESTABLISHED
- o NOT AUTHORIZED TO ACT
- o APPROVAL OF NJ BPU AND PA PUC REQUESTED FOR OPERATING AGREEMENTS
- o REQUEST FOR NRC APPROVAL OF GPU NUCLEAR AS OPERATOR TO BE SUBMITTED

GPU NUCLEAR CORP


STATUS 11/80 - PENDING NEEDED APPROVALS

- o STRUCTURE ESTABLISHED AND KEY JOBS FILLED
- o TECH SPECS APPROVED FOR GPU NUCLEAR GROUP
- o NUCLEAR GROUP EQUALS NUCLEAR CORP EXCEPT FOR REPORTING
- o NUCLEAR GROUP EFFECTIVE 9/15
- o NEEDED STAFFING AND ORGANIZATION DEVELOPMENT UNDERWAY

GPU NUCLEAR
MAJOR ELEMENTS


- o FULL TIME ORGANIZATION DEDICATED SOLELY TO NUCLEAR GENERATION
- o INCREASED ON-SITE TECHNICAL AND MANAGEMENT RESOURCES
- o STRONG CENTRAL TECHNICAL CONTROL
- o FULL TIME ON-SITE MANAGEMENT FOR PLANT OPERATION AND MAINTENANCE - -
WITH SUPPORT IN ADMINISTRATION, ENGINEERING, RADIATION PROTECTION,
AND OTHER AREAS BEING PROVIDED SEPARATELY
- o INDEPENDENT NUCLEAR ASSURANCE DIVISION - ENCOMPASSING TRAINING,
QUALITY ASSURANCE AND A NUCLEAR SAFETY ASSESSMENT DEPARTMENT
- o POOLING OF RESOURCES FOR SUPPORT OF SEVERAL GENERATING STATIONS
- o PERSONNEL POLICIES AND PROCEDURES APPROPRIATE FOR NUCLEAR GENERATION

Organization Chart GPU Nuclear Group




GPU NUCLEAR MANAGEMENT OVERVIEW


NOW



LATER



GPU NUCLEAR CORPORATION



*Significant full time representation at each site.

**Responsible to and takes general direction from Office of the President. Has direct access to CEO and Board of Directors.

OYSTER CREEK DIVISION

SUMMARY OF RESPONSIBILITIES

- OPERATE AND MAINTAIN THE OYSTER CREEK PLANT IN A SAFE, RELIABLE, AND EFFICIENT MANNER IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.

MAJOR FUNCTIONS

- ESTABLISH AND MAINTAIN PLANT LEVEL POLICIES, PROCEDURES, STANDARDS, AND PRACTICES RELATED TO THE OPERATION AND MAINTENANCE OF THE PLANT.
- PROVIDE AND MAINTAIN A PLANT STAFF QUALIFIED TO OPERATE AND MAINTAIN THE PLANT IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.
- OPERATE THE PLANT IN A SAFE, RELIABLE, AND EFFICIENT MANNER IN ACCORDANCE WITH CORPORATE PROCEDURES, THE ELECTRICAL NEEDS OF THE GPU SYSTEM. ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.
- ESTABLISH AND IMPLEMENT PREVENTATIVE AND CORRECTIVE MAINTENANCE PROGRAMS TO MAINTAIN THE STATION IN A SAFE, RELIABLE, AND EFFICIENT MANNER IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.
- ENSURE THAT PLANT OPERATIONS AND MAINTENANCE ACTIVITIES ARE CARRIED OUT IN ACCORDANCE WITH CORPORATE RADIATION CONTROL, QUALITY ASSURANCE, SECURITY, AND EMERGENCY PREPAREDNESS PROGRAMS.

THREE MILE ISLAND UNIT 1 DIVISION

SUMMARY OF RESPONSIBILITIES

- OPERATE AND MAINTAIN THE TMI-1 PLANT IN A SAFE, RELIABLE, AND EFFICIENT MANNER IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.

MAJOR FUNCTIONS

- ESTABLISH AND MAINTAIN PLANT LEVEL POLICIES, PROCEDURES, STANDARDS, AND PRACTICES RELATED TO THE OPERATION AND MAINTENANCE OF THE PLANT.
- PROVIDE AND MAINTAIN A PLANT STAFF QUALIFIED TO OPERATE AND MAINTAIN THE PLANT IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.
- OPERATE THE PLANT IN A SAFE, RELIABLE, AND EFFICIENT MANNER IN ACCORDANCE WITH CORPORATE PROCEDURES, THE ELECTRICAL NEEDS OF THE GPU SYSTEM, ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.
- ESTABLISH AND IMPLEMENT PREVENTATIVE AND CORRECTIVE MAINTENANCE PROGRAMS TO MAINTAIN TMI-1 IN A SAFE, RELIABLE, AND EFFICIENT MANNER IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.
- ENSURE THAT PLANT OPERATIONS AND MAINTENANCE ACTIVITIES ARE CARRIED OUT IN ACCORDANCE WITH CORPORATE RADIATION CONTROL, QUALITY ASSURANCE, SECURITY, AND EMERGENCY PREPAREDNESS PROGRAMS.

THREE MILE ISLAND UNIT 2 DIVISION

SUMMARY OF RESPONSIBILITIES

- o OPERATE, MAINTAIN, AND CONDUCT DECONTAMINATION AND RECOVERY OPERATIONS OF TMI-2 IN A SAFE AND EFFICIENT MANNER IN CONFORMANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, TECHNICAL REQUIREMENTS, AND OTHER REQUIREMENTS. THIS INCLUDES CONSTRUCTION OF REQUIRED FACILITIES.

MAJOR FUNCTIONS

- o ESTABLISH AND MAINTAIN PLANT LEVEL POLICIES, PROCEDURES, AND PRACTICES RELATED TO THE DECONTAMINATION, RECOVERY, OPERATION, AND MAINTENANCE OF THE PLANT.
- o PROVIDE AND MAINTAIN A PLANT STAFF QUALIFIED TO DECONTAMINATE, RECOVER, OPERATE, AND MAINTAIN THE PLANT.
- o OPERATE AND MAINTAIN ALL SYSTEMS AND EQUIPMENT REQUIRED FOR DECONTAMINATION, RECOVERY, AND LAYUP OF SYSTEMS IN A SAFE, RELIABLE, AND EFFICIENT MANNER.
- o DECONTAMINATE AND CLEAN UP THE WATER AND DECONTAMINATION FLUIDS IN A SAFE AND EFFICIENT MANNER.
- o DIRECT AND CONTROL THE PLANT RECOVERY PROGRAM.
- o DIRECT AND CONTROL THE CONSTRUCTION OF FACILITIES REQUIRED FOR THE DECONTAMINATION AND RECOVERY PROGRAMS.
- o ESTABLISH AND IMPLEMENT PREVENTATIVE AND CORRECTIVE MAINTENANCE PROGRAMS TO ASSURE THAT THE PLANT IS MAINTAINED IN A SAFE AND RELIABLE STATUS.
- o ASSURE THAT ALL PLANT ACTIVITIES ARE CARRIED OUT IN ACCORDANCE WITH CORPORATE RADIATION CONTROL, QUALITY ASSURANCE, SECURITY AND EMERGENCY PREPAREDNESS PROGRAMS.

TECHNICAL FUNCTIONS DIVISION

SUMMARY OF RESPONSIBILITIES

- ASSURE TECHNICAL AND REGULATORY ADEQUACY OF ALL ASPECTS OF NUCLEAR ACTIVITIES TO PROVIDE SAFE, RELIABLE, AND EFFICIENT OPERATIONS IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, ETC.

MAJOR FUNCTIONS

- PERFORM, MANAGE, AND DIRECT ALL OUT-OF-PLANT ENGINEERING, DESIGN, SAFETY ANALYSIS AND PLAN AND DIRECT STARTUP AND TEST ACTIVITIES.
- MAINTAIN ALL PLANT TECHNICAL BASIS AND CONFIGURATION CONTROL DOCUMENTS INCLUDING FUEL MANAGEMENT.
- CONTROL AND PERFORM INTERFACE ACTIVITIES WITH REGULATORY GROUPS.
- PERFORM PLANT TECHNICAL MONITORING/ASSESSMENT/PRODUCTIVITY ANALYSIS, INCLUDING MAJOR EQUIPMENT FAILURE ANALYSIS.
- PREPARE/REVIEW/CONCUR WITH ALL ENGINEERING AND LICENSING PROCEDURES AND LICENSING DOCUMENT CORRESPONDENCE AND PREPARE SARs, TECHNICAL SPECIFICATIONS AND ENVIRONMENTAL SPECIFICATIONS.
- SPECIFY, MANAGE, AND DIRECT ALL NUCLEAR FUEL MATERIAL, CONVERSION, ENRICHMENT, AND FABRICATION CONTRACTORS.
- REVIEW AND ASSESS THE SAFETY SIGNIFICANCE OF NRC NOTICES, BULLETINS, REPORTS, AND PLANT OPERATING EXPERIENCE INFORMATION.
- PROVIDE AND DIRECT OPERATING PLANT SHIFT TECHNICAL ADVISORS.
- REVIEW AND CONCUR IN ALL PLANT OPERATING, ALARM, AND EMERGENCY PROCEDURES FOR TECHNICAL ADEQUACY.
- DEFINE TECHNICAL REQUIREMENTS FOR TRAINING PROGRAMS.

NUCLEAR ASSURANCE

SUMMARY OF RESPONSIBILITIES

- MONITOR ALL NUCLEAR ACTIVITIES TO ASSURE THAT THEY PROVIDE THE REQUIRED HIGH DEGREE OF SAFETY AND RELIABILITY AND ARE CARRIED OUT IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.
- PROVIDE TRAINING OF CORPORATION PERSONNEL AS NEEDED TO CARRY OUT THEIR DUTIES AND TO MEET CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.
- PROVIDE SUPPORT TO THE OPERATING STATIONS IN THE AREAS OF EMERGENCY PLANNING AND ANALYTICAL LABORATORY SERVICES.

MAJOR FUNCTIONS

- MONITOR, EVALUATE, AND ASSURE THAT ALL ACTIVITIES HAVING THE POTENTIAL FOR COMPROMISING NUCLEAR SAFETY ARE ADEQUATELY ADDRESSED.
- PROVIDE AND MAINTAIN THE QUALIFIED PERSONNEL TO DEVELOP AND ADMINISTER THE OPERATIONAL QUALITY ASSURANCE PROGRAM AND ASSURE THAT IT IS IMPLEMENTED IN ALL ACTIVITIES IMPORTANT TO SAFETY.
- DEVELOP AND IMPLEMENT ALL NECESSARY GENERAL EMPLOYEE OPERATOR, TECHNICIAN, AND MANAGEMENT TRAINING PROGRAMS.
- DEVELOP THE SITE EMERGENCY PLANS AND ASSURE THAT EMERGENCY PLAN PREPAREDNESS IS MAINTAINED.
- PROVIDE THE GENERATING STATIONS WITH CHEMISTRY AND METALLURGICAL ANALYTICAL SERVICES AND RECOMMENDED CHEMISTRY REQUIREMENTS AND SPECIFICATIONS.

RADIOLOGICAL AND ENVIRONMENTAL CONTROLS DIVISION

SUMMARY OF RESPONSIBILITIES

- o ESTABLISH AND IMPLEMENT UNIFORM RADIOLOGICAL AND ENVIRONMENTAL POLICIES, PRACTICES, AND PROCEDURES REQUIRED TO ASSURE SAFE, RELIABLE, AND EFFICIENT OPERATION IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, AND LICENSES.

MAJOR FUNCTIONS

- o ESTABLISH AND MAINTAIN CORPORATE LEVEL POLICIES, PROCEDURES, STANDARDS, AND PRACTICES RELATING TO RADIOLOGICAL AND ENVIRONMENTAL ACTIVITIES.
- o PROVIDE THE PERSONNEL, PROCEDURES, AND ADMINISTRATIVE CONTROLS TO IMPLEMENT THE PLANT RADIATION AND ENVIRONMENTAL PROTECTION PROGRAMS.
- o PROVIDE ADMINISTRATIVE AND TECHNICAL GUIDANCE APPLICABLE TO RADIATION PROTECTION, RADIOACTIVE MATERIALS, RESPIRATORY PROTECTION, AND RADIOLOGICAL ENGINEERING INCLUDING ALARA PROGRAMS AND DOSIMETRY CONTROL.
- o PROVIDE ADMINISTRATIVE AND TECHNICAL GUIDANCE APPLICABLE TO ENVIRONMENTAL PROTECTION, ENVIRONMENTAL MONITORING, AND NPDES.

MAINTENANCE AND CONSTRUCTION DIVISION

SUMMARY OF RESPONSIBILITIES

- ESTABLISH AND MONITOR UNIFORM POLICIES, PRACTICES, AND PROCEDURES FOR ALL MAINTENANCE, REPAIR, AND CONSTRUCTION ACTIVITIES IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.
- CARRY OUT ASSIGNED PLANT MODIFICATIONS, REPAIRS, AND CONSTRUCTION ACTIVITIES AND CONDUCT MAJOR AND SPECIALIZED MAINTENANCE WORK IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND TECHNICAL REQUIREMENTS.

MAJOR FUNCTIONS

- MONITOR, EVALUATE, AND ASSURE THAT MAINTENANCE ACTIVITIES AT THE GENERATING STATIONS ARE BEING PERFORMED IN ACCORDANCE WITH CORPORATE POLICIES, PROCEDURES, AND GOOD MAINTENANCE PRACTICES.
- ESTABLISH AND MAINTAIN THE NECESSARY CORPORATE LEVEL MAINTENANCE AND CONSTRUCTION PROCEDURES, STANDARDS, AND PRACTICES FOR THE PERFORMANCE OF MAINTENANCE AND CONSTRUCTION ACTIVITIES.
- PLAN, SCHEDULE, AND DIRECT PLANT MODIFICATIONS, PLANT CONSTRUCTION PROJECTS, AND MAJOR AND SPECIALIZED MAINTENANCE JOBS.
- PLAN, SCHEDULE, AND DIRECT MAJOR AND SPECIAL MAINTENANCE AND CONSTRUCTION ACTIVITIES INVOLVED IN PLANNED AND FORCED OUTAGES.
- DEVELOP AND IMPLEMENT A FORMAL METHODS IMPROVEMENT/PRODUCTIVITY PROGRAM.
- DEVELOP PREPLANNED METHODS, PLANNING, AND SUPPORT FOR FORCED OUTAGES.

COMMUNICATIONS

SUMMARY OF RESPONSIBILITIES

- ESTABLISH AND IMPLEMENT POLICIES AND PROGRAMS FOR COMMUNICATIONS WITH THE NEWS MEDIA, LOCAL GOVERNMENT, CITIZENS GROUPS, AND INDIVIDUALS DURING BOTH NORMAL AND EMERGENCY CONDITIONS IN ACCORDANCE WITH CORPORATE POLICIES AND APPLICABLE REGULATIONS, ETC.
- ESTABLISH AND IMPLEMENT POLICIES AND PROCEDURES WHICH ASSURE INFORMATION OF GENERAL INTEREST TO EMPLOYEES IS DISSEMINATED FULLY, EFFECTIVELY, AND IN A TIMELY MANNER.

MAJOR FUNCTIONS

- MONITOR, EVALUATE, AND ASSURE THAT APPROPRIATE COMMUNICATIONS WITH OUTSIDE ORGANIZATIONS OR INDIVIDUALS WHICH ARE NOT THE SPECIFIC RESPONSIBILITY OF OTHER FUNCTIONAL DIVISIONS ARE ESTABLISHED AND MAINTAINED.
- ESTABLISH AND MAINTAIN CORPORATE LEVEL POLICIES, PROCEDURES, STANDARDS, AND PRACTICES RELATING TO INTERNAL AND EXTERNAL COMMUNICATION OF OTHER FUNCTIONAL DIVISIONS WITH NEWS MEDIA, LOCAL GOVERNMENTS, CITIZENS GROUPS, ETC.
- ESTABLISH AND MAINTAIN CONTACTS WITHIN LOCAL GOVERNMENT AND CITIZEN GROUPS TO ASSURE EFFECTIVE COMMUNICATIONS BETWEEN THOSE ORGANIZATIONS AND THE CORPORATION.
- COORDINATE COMMUNICATIONS ACTIVITIES WITH GENERAL PUBLIC UTILITIES, THE GPU SERVICE CORPORATION, AND THE OPERATING COMPANIES.
- SUPPORT THE DEVELOPMENT OF A POSITIVE ATTITUDE ON THE PART OF LOCAL OFFICIALS AND THE LOCAL PUBLIC TOWARD THE PRESENCE, ROLE IN THE COMMUNITY, AND SAFETY OF GPU NUCLEAR CORPORATION OPERATING PLANTS.

ADMINISTRATION DIVISION

SUMMARY OF RESPONSIBILITIES

- PROVIDE IN AN EFFICIENT AND RELIABLE MANNER AND IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND OTHER REQUIREMENTS, ALL REQUIRED BUSINESS MANAGEMENT AND ADMINISTRATIVE SUPPORT SERVICES FOR PRUDENTLY CONDUCTING THE ACTIVITIES OF THE GPU NUCLEAR GROUP.

MAJOR FUNCTIONS

- ASSEMBLE, REVIEW, AND ISSUE BUDGETS ON A CORPORATE-WIDE BASIS AND REGULARLY MONITOR AND REPORT PROJECTS, PROGRESS, AND EXPENDITURES AGAINST CAPITAL AND O&M BUDGETS AND ASSOCIATED WORK PLANS.
- PROVIDE MATERIALS MANAGEMENT SERVICES INCLUDING CONTRACTING AND PROCUREMENT, CONTRACT ADMINISTRATION, WAREHOUSING, AND INVENTORY CONTROL ON A CORPORATE-WIDE BASIS.
- DEVELOP AND ADMINISTER SECURITY, FACILITIES, SERVICES, AND INDUSTRIAL SAFETY PROGRAMS DIRECTED TO CREATING A SAFE, CONVENIENT, AND PROTECTED ENVIRONMENT FOR COMPANY EMPLOYEES AND PROPERTY IN ACCORDANCE WITH CORPORATE POLICIES AND ALL APPLICABLE LAWS, REGULATIONS, LICENSES, AND OTHER REQUIREMENTS.
- PROVIDE HUMAN RESOURCES PERSONNEL SERVICES IN THE AREAS OF RECRUITING, INDOCTRINATION, AND ORIENTATION OF NEW EMPLOYEES, WAGE AND SALARY ADMINISTRATION, CAREER COUNSELLING AND PLANNING, EMPLOYEE BENEFITS ADMINISTRATION, EMPLOYEE RELATIONS SERVICES FOR PROFESSIONAL EMPLOYEES AND BARGAINING UNITS, EEO, AND OTHER EMPLOYEE RELATIONS AND RETENTION PROGRAMS.
- NEGOTIATE AND ADMINISTER UNION CONTRACTS AND GRIEVANCE AND ARBITRATION PROCESSES.

ADMINISTRATION DIVISION
(continued)

- PREPARE, REVIEW, COORDINATE, AND ISSUE CORPORATE ADMINISTRATIVE POLICIES AND PROCEDURES.
- PROVIDE INFORMATION MANAGEMENT AND DOCUMENTATION CONTROL SERVICES.
- PROVIDE LEGAL SERVICES IN SUPPORT OF THE GROUP OPERATIONS INCLUDING PRESUBMISSION REVIEWS OF MAJOR PURCHASE TRANSACTIONS AND VENDOR NEGOTIATIONS, SUPPORT LITIGATION AND ARBITRATION OR ADMINISTRATIVE PROCEEDINGS AND REVIEW, AS APPLICABLE, PROPOSED CORPORATE ADMINISTRATIVE POLICIES AND PROCEDURES.

ELEMENTS OF SAFETY REVIEW PROCESS

- EMPHASIS ON RESPONSIBILITY OF LINE FUNCTION
 - DO IT RIGHT
 - OBTAIN NEEDED REVIEWS
- 100% INDEPENDENT BEFORE THE FACT
 - INVOLVEMENT OF SUPPORT GROUPS
 - EXPLICIT CONSIDERATION OF MULTIDISCIPLINARY
- SAFETY GROUP FOR EACH PLANT
 - FULL TIME ON SAFETY
 - ON-SITE - REPORT OFF-SITE
 - PRIOR REVIEW OF DEFINED ITEMS
 - AFTER THE FACT OVERVIEW
 - DIRECT OBSERVATION/SURVEILLANCE
 - FULL ACCESS
- NUCLEAR SAFETY ASSURANCE DEPARTMENT
 - HEADQUARTERS STAFF
 - OVERVIEW
 - NO ASSIGNED TASKS
 - OVERSEE SITE SAFETY GROUP
 - OMBUDSMAN
 - STAFF TO GORB
- GENERAL OFFICE REVIEW BOARD (GORE)
 - FULL TIME CHAIRMAN
 - OUTSIDE MEMBERS
 - BROAD CHARTER
 - FUNCTIONING OF SAFETY REVIEW PROCESS
 - QUALITY ASSURANCE PROGRAM ADEQUACY
 - NO OTHER ASSIGNED TASKS
 - ACCESS TO CEO & BOARD

TMI-1 CONTROL ROOM DESIGN REVIEW TEAM

- MEMBERS OF THE GPU ENGINEERING STAFF
- TMI UNIT 1 OPERATING PERSONNEL
- ENGINEERS FROM MPR ASSOCIATES, INC.
- TWO WELL KNOWN EXPERTS IN THE HUMAN ENGINEERING FIELD, DR. J. M. CHRISTENSEN AND DR. T. B. SHERIDAN

TMI-1 CONTROL ROOM DESIGN REVIEW

- DEVELOPMENT OF GUIDELINES AND OBJECTIVES
- CONSTRUCTION OF A FULL SCALE CONTROL ROOM MOCK UP
- WALK-THROUGH/TALK-THROUGH OF KEY OPERATING PROCEDURES.
- INDIVIDUAL REVIEW OF DISPLAYS AND CONTROLS.
- REVIEW OF ALARM SYSTEMS
- SURVEY OF ENVIRONMENTAL CONDITIONS.

STRENGTHS OF TMI-1 CONTROL ROOM

- GROUPING OF CONTROLS AND DISPLAYS
- UNCLUTTERED CONSOLE AND PANEL
- DIVISION OF OPERATIONAL RESPONSIBILITY
BETWEEN CONTROL ROOM AND LOCAL STATIONS
- RELIABILITY OF CONTROL AND DISPLAY
HARDWARE
- RELATIVE LOCATION OF CONTROLS AND ASSOCIATED
DISPLAYS
- RELATIVE LOCATION OF ALARM ANNUNCIATORS
TO RELATED CONTROLS AND DISPLAYS
- GENERAL LACK OF ACTUATED ALARMS DURING
NORMAL OPERATION.

AREAS WHERE IMPROVEMENT IS BEING
PURSUED

- LABELING AND OUTLINING
- ARRANGEMENT OF EMERGENCY FEEDWATER CONTROLS AND INDICATORS.
- READABILITY OF THE ESAS PANEL
- ALARM PRIORITIZATION AND ACKNOWLEDGEMENT.
- CONTROL ROOM ENVIRONMENT UPGRADE.

METHOD OF MAKING CHANGES

- DEVELOP CONCEPTUAL DESIGN
- CONSTRUCT FULL SCALE DRAWING FOR USE ON
MOCKUP
- CONDUCT WALK-THROUGHS WITH LICENSED OPERATORS
- CONSTRUCT OTHER MODELS AS NEEDED
- MAKE FINAL DECISION ON CHANGES


SMALL BREAK ANALYSIS AND FEEDBACK
OF OPERATING EXPERIENCE

LONG TERM ORDER ITEM No. 2:

"... GIVE CONTINUED ATTENTION TO TRANSIENT ANALYSIS AND PROCEDURE FOR MANAGEMENT OF SMALL BREAKS BY A FORMAL PROGRAM SET UP TO ASSURE TIMELY ACTION OF THESE MATTERS".


PROCEDURES FOR FEEDBACK OF OPERATING
EXPERIENCE

PERFORMED BY PLANT ANALYSIS SECTION OF
SYSTEMS ENGINEERING DEPARTMENT



INDICATES ON-SITE
LOCATIONS FOR MAJORITY
OF PERSONNEL

GPU NUCLEAR
TECHNICAL FUNCTIONS DIVISIONS
SYSTEM ENGINEERING DEPARTMENT



NOTE 1: EFFECTIVE AT OYSTER CREEK
WITH TECH SPEC CHANGE

OPERATOR RETRAINING PROGRAM

PHILOSOPHY - EXTENSIVE RETRAINING PROGRAM VITAL IN CONTINUOUSLY UPGRADING OPERATOR PERFORMANCE TO PROMOTE SAFE, RELIABLE PLANT OPERATIONS.

MANAGEMENT COMMITMENT

- NUCLEAR ASSURANCE
- OPERATOR TRAINING SECTION
- MANAGEMENT AND SUPERVISORY CAPABILITIES
- TRAINING FACILITIES
- SIMULATOR
- INSTRUCTOR QUALIFICATIONS AND TRAINING

GOAL - PROVIDE RETRAINING PROGRAM FOR OPERATORS EXEMPLIFYING PHILOSOPHY OF PROMOTING SAFE, RELIABLE PLANT OPERATIONS, INCLUDING PROPER RESPONSE TO TRANSIENTS. PROGRAM MEETS OR EXCEEDS REQUIREMENTS IMPOSED VARIOUS NUREGS, REG GUIDES, CFR, AND ANSI STANDARDS AND RECOMMENDED BY INPO.

PERSONNEL IN RETRAINING PROGRAM

- . 16 SRO LICENSED
- . 13 RO LICENSED
- . 2 RO'S IN TRAINING FOR SRO
- . 10 INDIVIDUALS IN TRAINING FOR RO
- . 8 STA'S

ELEMENTS OF RETRAINING PROGRAM

- . REQUALIFICATION LECTURE SERIES (ONE IN SIX SHIFT ROTATION ~ 240 HOURS/YR)
 - . HEAT TRANSFER AND FLUID FLOW
 - . MITIGATING CORE DAMAGE
 - . PLANT TRANSIENTS
 - . ICS MANUAL OPERATIONS

- . ON-THE-JOB TRAINING

- . ANNUAL EXAMINATION

ATOG

ABNORMAL TRANSIENT OPERATING GUIDELINE PROGRAM

INTENDED TO SATISFY NUREG 0578 RECOMMENDATION 2.1.9c

"PROVIDE THE ANALYSES, EMERGENCY PROCEDURES,
AND TRAINING TO SUBSTANTIALLY IMPROVE OPERATOR
PERFORMANCE DURING TRANSIENTS AND ACCIDENTS,
INCLUDING EVENTS THAT ARE CAUSED OR WORSENERD
BY INAPPROPRIATE OPERATOR ACTIONS"

B&W PROGRAM FUNDED BY SIX OWNERS

PLANT SPECIFIC GUIDELINES

TWO PARTS: PROCEDURE GUIDELINES
TRAINING MATERIAL

HUMAN FACTORS CONSULTANT WITH MILITARY PROCEDURES EXPERIENCE

GUIDELINES

EXECUTED AFTER EACH REACTOR TRIP

INSTRUCTIONS BASED ON KEY SYMPTOMS

SYMPTOMS ARRANGED TO DIAGNOSE EVENTS

RESPONSE PRIORITIZED

CONSIDERS LOSS OF INSTRUMENTATION AND CONTROL POWER

DETECTS COMBINATIONS OF MALFUNCTIONS

APPENDICES FOR SPECIFIC EVENTS

PRESSURE-TEMPERATURE PLOT CAN BE USED AS AID TO IDENTIFY:

LOSS OF SUBCOOLING

OVERCOOLING

LOSS OF HEAT SINK

IMPLEMENTATION

TMI-1 DRAFT EVENT TREES

OCTOBER '80

TMI-1 DRAFT GUIDELINES

APRIL '81

TMI-1 FINAL GUIDELINES

JULY '81

REVISED PROCEDURES AND
OPERATOR TRAINING

SEPTEMBER '81

II.F.2
**INADEQUATE CORE COOLING
(ICC) CONSIDERATIONS**

T-9

Detect and respond to nonmechanistic symptoms

Core overheating

- Two-phase froth level below top of core
- Local voiding (e.g., flow blockage)

Provide instrumentation to

- Detect approach to ICC by monitoring coolant saturation conditions and increasing coolant void fraction or decreasing liquid level

- Detect existence of ICC by monitoring two-phase froth level below top of core and increasing fuel temperature or coolant superheat

- Monitor recovery

Information needs

- Basis for operator actions to prevent or recover from ICC
- Assist the operator and supporting emergency operations staff to assess the recovery progress from unidentified situations

POOR ORIGINAL

REACTOR WATER LEVEL SYSTEMS UNDER EVALUATION

LEVEL ABOVE CORE LEVEL WITHIN CORE

ΔP measurement


Heated
thermocouples

Neutron detectors
above and below
reactor vessel

ΔP measurement

Core exit thermocouples
In-core TCs in instrument
thimble
SPNDs in instrument
thimble

Neutron detectors above
and below reactor vessel



CONTAINMENT

FIGURE 1

WESTINGHOUSE
REACTOR VESSEL WATER LEVEL
MEASUREMENT SYSTEM





FIGURE 2
CE HEATED JUNCTION THERMOCOUPLE



POOR ORIGINAL




FIGURE 3
NDC NEUTRON DETECTOR
SIMPLIFIED DIAGRAM OF
SYSTEM TO MEASURE
WATER LEVEL IN SHUTDOWN REACTOR
(AMPLIFIERS AND POWER
SUPPLIES NOT SHOWN)





FIGURE 4
 DAVCO MICROWAVE LIQUID LEVEL GAUGE
 FOR USE IN A
 HIGH RADIATION ENVIRONMENT

POOR ORIGINAL

TABLE 1

REACTOR VESSEL WATER LEVEL DETECTOR

System	Supplier	Status	Problems	Test Dates	Special Features
Heated Junction T/C (Differential Temp. Type)	ORNL	Some testing performed on prototype units	Droplet effects; Need droplet shield	Semiscale late 1980 Possible LOFT to be scheduled	Indicates wet or dry surface reflecting the heat removal capability of the coolant quality existing at discrete axial levels
Heated T/C (Absolute Temp. Type)	INEL	New prototype; Need further evaluation	No commercial development	ORNL late 1980	
Heated Junction T/C (RVLMS)	CE	Conceptual design similar to ORNL's HJTC	Suitable for level detection above core only	Under development & test at CE Semiscale or LOFT early 1981	
Ultrasonic	ORNL	Built & tested under research & development	Funding and development problems	ORNL early 1981	Near continuous level indication
Neutron Detector	NNC (EPRI sponsored)	Proof of principle needed Some prototype testing performed	Reliability of signal interpretation	LOFT late 1980	No leads in vessel
Differential Pressure (RVLIS)	<u>W</u>	Built commercial	Need further evaluation under simulated accident condition	Semiscale late 1980 Possible LOFT to be scheduled	Continuous level indication - can possibly be installed within one year
Microwave Liquid Level Gauge	DAVCO	New Conceptual Design	Need further development & system design	Semiscale or LOFT late 1981	Continuous level indication

T-10

THERMAL MECHANICAL REPORT - EFFECT OF HPI
ON VESSEL INTEGRITY FOR SMALL BREAK LOCA
WITH NO AFW

REQUEST (DRAFT NUREG - 0737, II.K.2.13)

PERFORM DETAILED ANALYSIS OF THERMAL/MECHANICAL CONDITIONS
IN THE RV DURING RECOVERY FROM SMALL BREAK WITH EXTENDED
LOSS OF ALL FEEDWATER. SUBMIT REPORT JANUARY 1, 1981.

KEY ISSUES

ASSESS POTENTIAL FOR THERMAL SHOCK OF RV RESULTING FROM
COLD SAFETY INJECTION FLOW

ASSESS FLUID STREAM MIXING IN THE DOWNCOMER

OPERATOR ACTIONS TO THROTTLE HPI FLOW RATES

STATUS

B&W SUBMITTED REPORT TO GPU NOVEMBER 21, 1980

UNDERGOING INTERNAL REVIEW

WILL BE SUBMITTED TO STAFF BY JANUARY 1, 1981

POOR ORIGINAL

INVESTIGATIONS COMPLETED

- 0 GENERIC BOUNDING ANALYSIS PERFORMED TO ENVELOPE ALL B&W OPERATING PLANTS
- 0 CONSERVATIVE EVALUATION
 - 0 MINIMUM ALLOWABLE BWST FLUID TEMPERATURE
NO FLOW MIXING IN COLD LEG PIPING OR RV DOWNCOMER
INSTANTANEOUS COOLDOWN OF RV METAL TO HPI FLUID TEMPERATURE
OPERATOR ACTION TO MAINTAIN 100F SUBCOOLING
MOST LIMITED PLANT SHOWS ADEQUATE RESULTS THROUGH
ADDITIONAL .5 EPFY
 - 0 ASSUME ~30F DOWNCOMER MIXING
ALL OTHER ASSUMPTIONS THE SAME
MOST LIMITED PLANT SHOWS ADEQUATE RESULTS THROUGH
ADDITIONAL ~1.5 EPFY

ONGOING ACTIONS

INVESTIGATE MIXING TESTING - EPRI, PRIVATE LABS
PLANT SPECIFIC ANALYSIS

POOR ORIGINAL