



CENTRAL FILES

PDR:HQ

LPDR

TIC

NSIC

STATE

ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

October 30, 1980

1-100-26
2-100-21

1980 NOV 28 PM 4 30
REGISTRATION
GENERAL SERVICES
MAIL ROOM

Mr. K. V. Seyfrit, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Comm.
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

SUBJECT: Arkansas Nuclear One - Units 1 & 2
Docket No. 50-313 and 50-368
License No. DPR-51 and NPF-6
IE Bulletin 80-10
(File: 1510.1, 2-1510.1)

Gentlemen:

Following discussions with the resident inspector, we wish to provide clarification by revising our response to Item 2 of IE Bulletin 80-10 dated July 2, 1980. Our response is now changed to read as follows.

ITEM 2 - RESPONSE

A routine sampling/analysis or monitoring program will be established by August 1, 1980 for the following systems:

- High Pressure Nitrogen Supply System
- Condensate Storage Tanks
- Low Pressure Nitrogen Supply System
- High Purity Hydrogen Supply System
- Instrument Air System

Very truly yours,

David C. Trimble

DCT:JTE:lp

8012120 106