



CENTRAL FILES
PDR:HQ
LPDR
TIC
NSIC
STATE

ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

August 8, 1980

15 APR 1980
REGISTRATION
SERVICES UNIT
1980 NOV 28 PM 1 37

1-080-06
2-080-06

Mr. K. V. Seyfrit, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Comm.
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

SUBJECT: Arkansas Nuclear One - Units 1 and 2
Docket Nos. 50-313 and 50-368
License Nos. DPR-51 and NPF-6
IE Bulletin 80-19 - Response
(File: 1510.1 and 2 1510.1)

Gentlemen:

The following information is provided in response to IE Bulletin 80-19.

In phone conversations on August 6 and 7, 1980, with I. Villalva of the NRC, the author of the subject bulletin, Mr. Villalva clarified the action required by the Bulletin to pertain only to those facilities which use C. P. Clare Model HG2X-1011 mercury-wetted relays in the logic matrix for their Reactor Protection System (RPS). Since neither ANO-1 nor 2 use this specific relay in logic matrices for their RPS, no action is required.

Very truly yours,

David C. Trimble
Manager, Licensing

DCT/DEJ/lp

cc: Mr. Victor Stello, Jr., Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Comm.
Russellville, Ar 72801

8012120 174