

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | C | B | E | P | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | \_\_\_\_\_ | 5  
7 8 9 14 15 25 26 30 57 58  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T  
0 1 | L | 6 | 0 | 5 | 0 | - | 0 | 3 | 2 | 4 | 7 | 1 | 1 | 1 | 2 | 8 | 0 | 8 | 1 | 2 | 0 | 8 | 8 | 0 | 9  
7 8 60 61 68 69 74 75 80  
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation following the completion of operations with 2B RHR pump, the  
0 3 | suppression pool level exceeded -27" with a maximum value of -26". Within 15 minutes  
0 4 | of its discovery, the level was returned to normal. This event did not affect the  
0 5 | health or safety of the public.  
0 6 |  
0 7 |

Technical Specifications 3.6.2.1, 6.9.1.9b

0 9 | C | F | 11 | B | 12 | A | 13 | V | A | L | V | E | X | 14 | C | 15 | A | 16 |  
7 8 9 10 11 12 13 18 19 20  
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
17 | LER/RO REPORT NUMBER | 8 | 0 | 21 22 | - | 23 | 0 | 9 | 7 | 24 26 | / | 27 | 0 | 3 | 28 29 | L | 30 | - | 31 | 0 | 32 | REVISION NO.  
18 | X | 19 | F | 20 | Z | 21 | Z | 22 | 0 | 0 | 0 | 0 | 23 | Y | 24 | Y | 25 | A | 26 | A | 3 | 9 | 5 | 27  
33 34 35 36 37 40 41 42 43 44 47  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event occurred when the 2B RHR pump discharge check valve, 2E11-F031, failed to  
1 1 | fully reseal following operation of the pump and allowed water from the RHR Keep-fill  
1 2 | system to raise the level > -27". The check valve was immediately resealed and the  
1 3 | system returned to normal.  
1 4 |

1 5 | F | 28 | 0 | 6 | 8 | 29 | NA | 44 | A | 31 | Operator Surveillance | 45 46 | 32 |  
7 8 9 10 12 13 44 45 46  
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION  
1 6 | 2 | 33 | 2 | 34 | NA | 44 | NA | 45 | NA | 46 | 36 |  
7 8 9 10 11 44 45 46  
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE  
1 7 | 0 | 0 | 0 | 37 | 2 | 38 | NA | 39 |  
7 8 9 11 12 13  
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION  
1 8 | 0 | 0 | 0 | 40 | NA | 41 |  
7 8 9 11 12  
PERSONNEL INJURIES NUMBER DESCRIPTION  
1 9 | 2 | 42 | NA | 43 |  
7 8 9 10  
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION  
2 0 | N | 44 | \_\_\_\_\_ | 45 |  
7 8 9 10  
PUBLICITY ISSUED DESCRIPTION  
NRC USE ONLY  
68 69 80

LER ATTACHMENT - RO # 2-80-97

Facility: BSEP Unit No. 2

Event Date: 11-12-80

A plant modification has been installed to use water from the suppression pool to supply the safety system piping Keep-fill systems. This should prevent any changes in torus level due to RHR check valve leakage. This modification will be made operational when the submitted technical specification change request to operate the system's isolation valves has been approved by the NRC.