

9ERA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DEC 01 1980

Docket No. 50-364

APPLICANT: Alabama Power Company
FACILITY: Joseph M. Farley Nuclear Plant, Unit 2
SUBJECT: SUMMARY OF JULY 31, AUGUST 1, AND OCTOBER 16, 1980 MEETINGS REGARDING
REVIEW OF OPERATING LICENSE APPLICATION

The staff in Procedures and Testing Review Branch (D. Wigginton and B. Siegel) have met with the applicant (Mr. D. Morey and Mr. L. Williams) at the Farley Nuclear Plant to review selected emergency operating procedures.

On July 31, 1980 and August 1, 1980, the staff discussed its comments and proposed modifications to the procedures, based on a detailed review. Procedures reviewed were those for loss of reactor coolant, steam generator tube rupture, reactor trip, anticipated transients without scram, loss of main feedwater and inadequate core cooling. Applicant revised its procedures, based on these comments. Three of these revised procedures were used in September 2 and September 3, 1980 to direct Farley Nuclear Plant operators through simulated accidents on the Zion simulator. These three procedures (loss of coolant, safety injection, and steam generator tube rupture) were further revised based on the results of the simulations.

On October 16, 1980, the staff, including Mr. E. Reeves, NRC Project Manager for Farley Unit 1, met with the applicant to walk through the small break loss of coolant accident emergency operating procedure in the Farley Unit 2 control room. This walk through was conducted using the updated procedure. As a result of this walk through, a few minor changes were made.

The summary and conclusions of the staff's review of selected emergency operating procedures will be reported in Supplement 5 to the Farley 2 SER.

L. L. Kintner
L. L. Kintner, Project Manager
Licensing Branch No. 2
Division of Licensing

cc: See next page

REGISTRATION
SERVICES UNIT
DEC 10 11 49 AM '80
REGISTRATION
SERVICES UNIT

8012180 007

F

Mr. F. L. Clayton, Jr., Senior Vice
President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

DEC 01 1980

cc: Mr. W. O. Whitt
Executive Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Mr. Ruble A. Thomas
Vice President
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

Mr. George F. Trowbridge
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. W. Bradford
NRC Resident Inspector
P. O. Box 1814
Dothan, Alabama 36302